



Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT
E. Fernandez St., Brgy. Lagao, General Santos City
Telephone No.: 552-3824; Telefax No.: 553-4960
Email Address: gscwaterdistrict@yahoo.com

GPM-034-2

SUPPLEMENTAL/BID BULLETIN


Addendum No. 14 *Series of 2020*

March 21, 2020

This Addendum No. 14 is issued to modify or amend items in the Technical Specifications. This shall form as an integral part of the Bid Documents for **Project 2020-002: Purchase of Assorted Sizes uPVC Pipes Series 8, Fixed Seal**

Amendment	From	To
3.0 Mechanical Properties d. Joints	Joints shall be used for sizes 63mm up to 225mm to be Machine installed Integral Fixed Seal. The seal should be glass reinforced polypropylene (PP) homogeneously bonded to highly flexible EPDM Rubber.	Joints shall be used for sizes 63mm up to 160mm to be Machine installed Integral Fixed Seal. The seal should be glass reinforced polypropylene (PP) homogeneously bonded to highly flexible EPDM Rubber.

For guidance and information of all concerned.


FDV:
FERDINAND S. FERRER
BAC Chairperson

Received by the Bidder:

Date: _____