



Pre-bid Conference (via Zoom)

Project No. 2021-04: Purchase of Assorted Sizes of Electromagnetic Flowmeter

December 4, 2020, 1:30pm

GSCWD Bldg., Boardroom, General Santos City

MINUTES OF THE PROCEEDINGS

I. Attendance (GSCWD)

Bids and Awards Committee

Engr. Rogelio A. Besana, Jr.	-	BAC Vice Chairperson
Francisco R. Alolod Jr., CPA	-	BAC Member
Maritess P. Primaylon	-	BAC Member
Rauline Kaye F. Autida	-	BAC Secretariat
Judy Lim-Pasman	-	BAC TWG

Bids and Awards Committee (via Zoom)

Ferdinand S. Ferrer, MPA	-	BAC Chairperson
Engr. Cornelio T. Turija, Jr	-	BAC Member
Agnes P. Tampico	-	BAC Secretariat, Head
Engr. Michael Gabales	-	BAC TWG Head
John Rey Cawit	-	BAC TWG
Edmund Badal	-	BAC TWG

Bidders

Jheroll Vince Santos	-	EastAsia Solutions Technologies Corp.
Redorick Mercado	-	EastAsia Solutions Technologies Corp.
Romar Manang	-	EastAsia Solutions Technologies Corp.
Ariel Alcantara	-	TZ-E Trading
Odick Mercado	-	TZ-E Trading
Hernaldo Flores	-	Leeleeng Commercial, Inc.

Absent

Samcelle B. Valenzuela	-	BAC Member
------------------------	---	------------

II. Call to Order

The conference was called to order at 1:30 pm and was presided by the BAC Chairperson, Mr. Ferdinand S. Ferrer, MPA.

BAC Secretary Rauline Kaye F. Autida went over the attendees. Three (3) prospect bidders attended the pre-bid conference, namely: EastAsia Solutions, TZ-E Trading, and Leeleng Commercial.

There were no representatives from the Commission on Audit, Kiwanis and PSME who were invited to observe and witness the conduct of the Pre-Bid Conference.

III. Highlights of the Proceedings

As to the Bidding Process

The Pre-bid Conference was conducted via webcasting (Zoom). BAC Member, Ms. Marites Primaylon, discussed the following points:

**GENERAL SANTOS CITY WATER DISTRICT**

E. Fernandez St., Brgy. Lagao, General Santos City

Telephone No.: 552-3824; Telefax No.: 553-4960

Email Address: gscwaterdistrict@yahoo.com

- The Total Approved Budget for the Contract (ABC) is **One Million Two Hundred Thousand Pesos Only (Php 1,200,000.00)**.
- It was discussed to the prospective bidder the two-envelope system and the components for each envelope. The first envelope is Technical Component Envelope & the second is the Financial Component Envelope. Checklist for the components for each envelope is provided in Section 8 of the BDS.
- The following are the components for each envelope:
 - A. TECHNICAL COMPONENT ENVELOPE**
Class "A" Documents

A.1 Legal Documents

- (a) **Valid PhilGEPS Registration Certificate (Platinum Membership) (all pages);** or

Registration certificate from Securities and Exchange Commission (SEC), Department of Trade and Industry (DTI) for sole proprietorship, or Cooperative Development Authority (CDA) for cooperatives or its equivalent document, and

Mayor's or Business permit issued by the city or municipality where the principal place of business of the prospective bidder is located, or the equivalent document for Exclusive Economic Zones or Areas; and

Tax clearance per E.O. No. 398, s. 2005, as finally reviewed and approved by the Bureau of Internal Revenue (BIR).

Note: In case any of the items are expired (except for Mayor's Permit), bidder must present copy of the renewed certificate; official receipts or any proof of payment shall not be accepted.

A. 2 Technical Documents

- (b) **Statement of the prospective bidder of all its ongoing government and private contracts,** including contracts awarded but not yet started, if any, whether similar or not similar in nature and complexity to the contract to be bid; and

- (c) **Statement of the bidder's Single Largest Completed Contract (SLCC) similar to the contract to be bid,** except under conditions provided for in Sections 23.4.1.3 and 23.4.2.4 of the 2016 revised IRR of RA No. 9184, within the relevant period as provided in the Bidding Documents; and

Note: ITB Clause 5.4 states, "The bidder must have completed, within the period specified in the Invitation to Bid and ITB Clause 12.1 (a)(ii), a single contract that is similar to this project, equivalent to at least 50% of the ABC. For this purpose, similar contracts shall refer to:
Electromagnetic Flowmeter.

ITB Clause 12.1 (a)(ii) states, "The bidder's SLCC similar to the contract to be bid should have been completed within *five (5) years* prior to the deadline for the submission and receipt of bids.

- (d) **Original copy of Bid Security.** If in the form of a Surety Bond, submit also a certification issued by the Insurance Commission; or Original copy of Notarized Bid Securing Declaration; and

Note: **The Bid Security** shall be limited to Bid Securing Declaration or at least one (1) other form in accordance with the following amount;

- Cash (2% of ABC) = Php 24,000.00
- Cashier's / Manager's Check issued by a Universal or Commercial Bank (2% of ABC) = Php 24,000.00
- Bank Draft / guarantee or irrevocable letter of credit issued by a Universal or Commercial Bank. (2% of ABC) = Php 24,000.00
- Surety Bond (5% of ABC) = Php 60,000.00 valid *until* April 16, 2021 and shall be accompanied by a certification by the Insurance Commission that the surety or insurance company is authorized to issue such instruments. Only those bid securities procured from commercial and universal banks shall be allowed.



(e) **Conformity with the Technical Specifications**, which may include production/delivery schedule, manpower requirements, and/or after-sales/parts, if applicable; and

Note: Bidder shall photocopy the Technical Specifications Form provided in Section VII in the BDS

Bidder shall submit the photocopied Technical Specification Form indicating "comply" per required parameter

Bidder shall provide the necessary additional requirements as stated in the Technical Specifications

(f) **Original duly signed Omnibus Sworn Statement (OSS)**; and if applicable, Original Notarized Secretary's Certificate in case of a corporation, partnership, or cooperative; or Original Special Power of Attorney of all members of the joint venture giving full power and authority to its officer to sign the OSS and do acts to represent the Bidder.

Note: Must be Notarized
Proforma found in the Bid Docs
Must be filled out properly

A. 3 Financial Documents

(g) **The Supplier's audited financial statements**, showing, among others, the Supplier's total and current assets and liabilities, stamped "received" by the BIR or its duly accredited and authorized institutions, for the preceding calendar year which should not be earlier than two (2) years [2018 & 2019] from the date of bid submission; and

(h) **The prospective bidder's computation of Net Financial Contracting Capacity (NFCC)**; or A committed Line of Credit from a Universal or Commercial Bank in lieu of its NFCC computation.

B. FINANCIAL COMPONENT ENVELOPE

- (a) Original of duly signed and accomplished Financial Bid Form; and
- (b) Original of duly signed and accomplished Price Schedule(s)

o Other reminders:

- Bids that exceed the ABC shall not be accepted.
- Prospective bidders are instructed to provide **one (1) original and three (3) copies** of the documents for each component. The BAC prefers bid documents be identified with ticklers for easy location of file/s to be evaluated during opening of bids.
- Other bidders can still join the bidding even if they have not attended the Pre-bid Conference.
- Bid shall be submitted to GSCWD for Opening of Bids on **December 16, 2020 at 12:00nn**; late bids shall be declared "late" and shall not be accepted.

As to ELECTRONIC BID SUBMISSION

Based on GPPB Resolution No. 09-2020, dated 7 May 2020

SUBMISSION AND RECEIPT OF BIDS

1. **Bidding Documents** must be in **Two (2) password protected compressed archive files** which shall be submitted simultaneously, the **first shall contain the Technical Component (Legal, Technical & Financial Documents)** and the **second shall contain the Financial Component** of the bid. Deadline and submission of bid for **Project 2021-04: Purchase of Assorted Sizes of Electromagnetic Flowmeter is December 16, 2020 at 12nn**. Bids shall be emailed at: gscwdprocurement@yahoo.com. Kindly secure confirmation from the recipient.

Note:

- A. Kindly compress the required documents into one file.
- B. Kindly use the following format for your electronic bid:
[Company name] Technical Component [part 1, part 2 (if applicable)]



[Company name] Financial Component

C. Bidders who opt to submit bid documents online shall also submit required hard copies to the General Santos City Water District.

2. **Bidding Documents** not in compressed archive folders and are **not password protected**, shall be **rejected**. However, bid files not properly compressed and password-protected, as required in the Bidding Documents, shall be accepted, provided that the bidder or its duly authorized representative shall acknowledge such condition of the bid as submitted. The BAC shall **assume no responsibility** for the misplacement of the contents of the improperly compressed or password-protected folder, or for its premature opening.

MODIFICATION OF BIDS

If a bidder modifies its Bid, it shall not be allowed to retrieve its original Bid, but shall only be allowed to send another Bid equally secured and properly identified. In the case of electronic submission, to be labeled as a “**modification**,” of the one previously submitted. The time indicated in the latest Bid receipt page generated shall be the official time of submission. Bids submitted after the **deadline shall not be accepted**.

BID OPENING

The passwords for accessing the **Bidding Documents** will be disclosed by the Bidders only **during the actual bid opening** which may be done in **person or face-to-face through videoconferencing, webcasting or similar technology**.


As to the Technical Specifications

The following are discussed by Edmund Badal:

SCOPE OF CONTRACT

The scope shall be supply, testing, delivery and commissioning of Three (3) sets assorted brand new Electromagnetic Flowmeter to General Santos City Water District (GSCWD).

Particulars	Requirements	
	Set 1	Set 2
SIZE mm (inches)	250 (10)	200 (8)
Number of Units	1	2
TYPE	Electromagnetic Flow meter	Electromagnetic Flow meter
BORE	Full Bore	Full Bore
POWER SUPPLY	115 - 230 VAC	115 - 230 VAC
MEASUREMENTS	Direct / Inverse Flow	Direct / Inverse Flow
Qmax m ³ /hr	600	400
Qnominal m ³ /hr	450	280
QTransitional m ³ /hr	13	8
Qmin m ³ /hr	8	5
CABLE	20 meters w/ complete accessories	20 meters w/ complete accessories
CONNECTION	Flanged Type, PN16	Flanged Type, PN 16
LINING	Hard Rubber for Potable Water	Hard Rubber for Potable Water
RATING	IP 67/NEMA 6	IP 67/NEMA 6



GENERAL SANTOS CITY WATER DISTRICT
E. Fernandez St., Brgy. Lagao, General Santos City
Telephone No.: 552-3824; Telefax No.: 553-4960
Email Address: gscwaterdistrict@yahoo.com

5.0 Adjournment

There having no other remaining topic to be discussed, the Pre-Bid Conference was adjourned at 3:30pm.

Prepared by:

RAULINE KAYE F. AUTIDA
BAC Secretary

Checked by:

AGNES P. TAMPICO
Head, BAC Secretariat

Reviewed by:

EDMUND BADAL
Head, TWG

ENGR. MICHAEL SABAES
Technical Working Group

Attested and approved by:

FERDINAND S. FERRER, MPA
BAC Chairperson

In conformity with the Bids and Awards Committee:

ENGR. ROGELIO A. BESANA, JR.
Vice Chairperson

BAC Members:

ENGR. CORNELIO T. TURIJA, JR.

SAMCELLE B. VALENZUELA

FRANCISCO R. ALOLOD, JR. CPA

MARITES P. PRIMAYLON