



PRELIMINARY WELL DESIGN

WELL NO. 24
CSWDO COMPOUND, BRGY. FATIMA,
GENERAL SANTOS CITY

WELL DATA:

DEPTH : 150 m
 TARGET CAP. : 70 LPS
 BLANK CASING : 400mmØ and 250mmØ
 WELL SCREEN : 250mmØ

NOTE:

1. ALL CASING AND SCREEN JOINTS ARE WELDED.
2. ALL LENGTHS ARE APPROXIMATE.
3. FINAL WELL DESIGN DEPEND ON THE RESULT OF ELECTRIC LOGGING.



GENERAL SANTOS CITY WATER DISTRICT
 E. FERNANDEZ ST., BRGY. LAGAO
 GENERAL SANTOS CITY

PREPARED BY:

(Signature)
ENGR. ROLLY A. GUNDAY

ØIC - Planning & Design Division

CHECKED AND REVIEWED BY:

(Signature)

ENGR. ROGELIO A. BESANA, JR.

AGM - Technical Operations & Services

APPROVED BY:

(Signature)
ENGR. ARN B. GELLANGARIN
 General Manager