

## Republic of the Philippines GENERAL SANTOS CITY WATER DISTRICT

E. Fernandez St., Brgy. Lagao, General Santos City Telephone No.: 552-3824; Telefax No.: 553-4960 Email Address: gscwaterdistrict@yahoo.com

## SUPPLEMENTAL/BID BULLETIN

Addendum No. 8 Series of 2021

April 12, 2021

This Addendum No. 8 is issued to modify or amend items in the Bid Documents. This shall form as an integral part of the Bid Documents for Project 2021-17: Purchase of 7,000pieces of 15mm@ Multi-Jet Brass Water Meter.

Amendment in the Schedule of Activities

Activity	From	То
Issuance and Availability of Bid	March 29 – April 26, 2021	March 29 – April 26, 2021
Documents	12:00nn	9:00am
Deadline of Submission and Receipt of	March 29 - April 26, 2021	March 29 – April 26, 2021
Bids	12:00nn	9:00am
Opening of Bids & Preliminary	April 26, 2021	April 26, 2021
Examination of Bids	01:30pm	9:30am
Bid Evaluation	April 27, 2021	April 27, 2021
Post Qualification		

Amendment in Section VII. Technical Specifications:

General Requirements	From	То
E. Dimension Weight without tailpiece	1.20 to 1.50kg	1.0 to 1.40kg
Additional Requirements	From	То
B. Serial Numbering	Shall be provided by GSCWD which shall be unique or no duplication in every meter.  Minimum of five (5) digits and shall be engraved in block type by the supplier. Shall be permanent and only one serial number will appear on the external top surface of the register box ring. Note: Serial numbering begins with 100601 onwards.	Shall be provided by GSCWD which shall be unique or no duplication in every meter.  Minimum of six (6) digits and shall be engraved in block type by the supplier. Shall be permanent and only one serial number will appear on the external top surface of the register box ring. Note: Serial numbering begins with 100601 onwards.
F. Requirements Schedule of Requirements	One percent (1%) of the total quantity required in each delivery of water meter shall undergo random water meter test in Meter Testing Laboratory. The winning bidder shall pay the corresponding cost of testing. One time testing of water meter is not allowed.	One percent (1%) of the total quantity required in each delivery of water meter shall undergo random water meter test in Meter Testing Laboratory. The winning bidder shall pay the corresponding cost of testing.

For guidance and information of all concerned.

FERDINAND S. FERRER
BAC Chairperson

Received by the Bidder: