



Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT
E. Fernandez Street, Barangay Lagao General Santos
Telephone No.: 552-3824; Telefax No.: 553-4960
Email Address: gscwdprocurement@yahoo.com

GPM-014-2

REQUEST FOR QUOTATION

RFQ #: 3-0120-080 DATE: 01/30/2020

SUPPLIER: _____
ADDRESS: _____
TELEPHONE NO. : _____
TIN NO. : _____

Dear Sir/Madam,

Pls. quote your lowest price on the item/s listed below subject to general condition stating the shortest time of delivery and submit your quotation duly signed by your representative not later than 02/05/2020, Pls. furnish this office the following articles subject to the terms and conditions contained therein.

ITEM NO.	DESCRIPTION	QTY.	UNIT	UNIT PRICE
1	MAGNETIC CONTACTOR : 75KW, 440V, 3PHASE / Control Circuit Voltage: 220VAC, 50/60HZ-ABC: PHP 137,000.00	6	unit	P
2	MAGNETIC CONTACTOR : 100KW, 440, 3PHASE / Control Circuit Voltage 220VAC, 50/60HZ-ABC: PHP 113,000.00 ##### nothing follows #####	4	unit	P

Date of Delivery: _____
Price Validity : _____
Terms of Payment: _____

Place of Delivery: GSCWD Bodega
*****No partial delivery allowed****
Note: 6% WITHHOLDING TAX DEDUCTION
PR NO.: 0120-032

Requested by:

RS
GESE R. OBAÑER
MATERIAL PROCUREMENT
OFFICER A

Price quoted by:

Supplier

Date



TECHNICAL SPECIFICATION

TITLE: PURCHASE OF ASSORTED SIZES OF MAGNETIC CONTACTOR

A.) MAGNETIC CONTACTOR OPERATING REQUIREMENTS

Particulars	Requirements
Number Of Unit	6
Motor Power Hp (UI)	75kW, 460V, 3P
Rated Operational Current	150A @ 440V, AC3
Rated Operational Voltage	690VAC, 3P, 50/60HZ
Control Circuit Voltage	220VAC, 50/60HZ
Auxiliary Contact	2NO + 2NC
Front Face	IP 20
Mounting Support	Plate / Rail
Breaking Capacity	1400A



B.) MAGNETIC CONTACTOR OPERATING REQUIREMENTS

Particulars	Requirements
Number Of Unit	4
Motor Power Hp (UI)	100kW, 440V, 3P
Rated Operational Current	185A @440V, AC3
Rated Operational Voltage	690VAC, 3P, 50/60HZ
Control Circuit Voltage	220VAC, 50/60HZ
Auxiliary Contact	2NO + 2NC
Front Face	IP 20
Mounting Support	Plate / Rail
Breaking Capacity	1480A



TERMS AND CONDITIONS

- 1.1 The supplier shall submit original catalogue or brochure.
- 1.2 The supplier shall submit a Certificate of Dealership/Distributorship from the Manufacturer.
- 1.3 The supplied Magnetic Contactor, including its accessories shall have one (1) year warranty against defects and the supplier shall provide a warranty certificate. Warranty period shall commence upon issuance of certificate of final acceptance.
- 1.4 The supplier shall provide a qualified technician to conduct the field testing and training of our personnel.

Prepared by:


EDMUND L. BADAL, REE
SWRFT-A

Noted by:


ROGELIO A. BESANA JR. C.E./RMP
Manager A – Engineering & Construction Dept.