



Republic of the Philippines  
**GENERAL SANTOS CITY WATER DISTRICT**  
 E. Fernandez St., Brgy. Lagao, General Santos City  
 Telephone No.: 552-3824; Telefax No.: 553-4960  
 Email Address: [gscwaterdistrict@yahoo.com](mailto:gscwaterdistrict@yahoo.com)

GPM-034-2

## SUPPLEMENTAL/BID BULLETIN

### *Addendum No. 3* *Series of 2020*

December 11, 2019

This Addendum No. 3 is issued to modify or amend items in the Technical Specifications. This shall form as an integral part of the Bid Documents for **Project 2020-05: Purchase of Ultrasonic Clamp-On Flowmeter (Fixed Seal)**.

**Amendment:**

Amendment	From	To
<b>1. Invitation to Bid</b> <b>Title</b>	Project 2020-05: Purchase of Ultrasonic Clamp-On Flowmeter (Fixed Seal)	Project 2020-05: Purchase of <b>Calibrated</b> Ultrasonic Clamp-On Flowmeter (Fixed Seal)
<b>VII. Technical Specifications</b> <b>H. Additional Requirements</b>	<p>a. The manufacturer should have ISO 17025 and 9001:2008 Certificate</p> <p>c. Supplier must submit Certificate of Calibration and shall not be included as additional requirement. The Certificate shall only be presented during the conduct of post-qualification of the lowest bidder.</p>	<p>a. The manufacturer should have ISO 17025 and 9001:2008 Certificate <b>or its upgraded version.</b></p> <p>c. Supplier must submit Certificate of Calibration and shall not be included as additional requirement. The Certificate shall only be presented <b>upon delivery,</b> of the lowest bidder.</p>

For guidance and information of all concerned.

  
**FERDINAND S. FERRER**  
*BAC Chairperson*

Received by the Bidder:

Date: \_\_\_\_\_