



SUPPLEMENTAL/BID BULLETIN

Addendum No. 9 *Series of 2020*


December 13, 2019

This Addendum No. 9 is issued to modify or amend items in the Technical Specifications. This shall form as an integral part of the Bid Documents for **Project 2020-08: Purchase of 9,500 pieces of 15mmØ of Multi-Jet Brass Water Meter.**

Amendment:

Amendment	From	To
I. General Requirements	H. EFFICIENCY TEST The GSCWD test bench shall be the official measuring equipment to be used for Efficiency Test hence, the results are final.	H. EFFICIENCY TEST The GSCWD test bench shall be the official measuring equipment to be used for Efficiency Test at Transitional and Minimum Flow. The said testing shall undergo once only, thus results are final.
	I. Meter fitted with strainer on inlet to protect against dirt	I. Strainer Screen Meter fitted with strainer on inlet to protect against dirt.
	E. Dimension Weight without tailpiece = 1.20 to 1.4 kg	E. Dimension Weight without tailpiece = 1.20 to 1.50 kg
	J. Meter Seal Steel cable wire (plastic coated) with tamper proof meter seal with GSCWD marking. Lead meter seal is not acceptable.	J. Meter Seal Steel cable wire or stainless steel (plastic coated) with tamper proof meter seal with GSCWD marking. Lead meter seal is not acceptable.
II. Additional Requirements	E. Other Package 1) With plastic end cap installed to both meter body thread ends. 2) It shall be packed by 10's per batch with the meter serial numbers indicated in four sides of the external portion of carton/box. 3) The tailpieces shall be of the same material composition as the meter body.	E. Other Package 1) With plastic end cap installed to both meter body thread ends. 2) Each meter individually packed in a small box containing 2 threaded tailpieces and 2 rubber gasket that fitted to its outlet design of the manufacturer. Also, the winning bidder must provide an additional 10% rubber gasket of the total delivered water meter. 3) It shall be packed by 10's per batch with the meter serial numbers indicated in four sides of the external portion of carton/box. 4) The tailpieces shall be of the same material composition as the meter.

For guidance and information of all concerned.


FERDINAND S. FERRER
BAC Chairperson

Received by the Bidder:

Date: