



Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT
E. Fernandez Street, Barangay Lagao General Santos
Telephone No.: 552-3824; Telefax No.: 553-4960
Email Address: gscwdprocurement@yahoo.com

GPM-014-2

REQUEST FOR QUOTATION

RFQ #: 3-0120-028 DATE: 01/13/2020

SUPPLIER: _____
ADDRESS: _____
TELEPHONE NO. : _____
TIN NO. : _____

Dear Sir/Madam,

Pls. quote your lowest price on the item/s listed below subject to general condition stating the shortest time of delivery and submit your quotation duly signed by your representative not later than 01/17/2020, Pls. furnish this office the following articles subject to the terms and conditions contained therein.

ITEM NO.	DESCRIPTION	QTY.	UNIT	UNIT PRICE
1	VARIABLE FREQUENCY DRIVE (VFD) : 125HP, 460VAC, 3PHASE-ABC: PHP 500,000.00 ##### nothing follows #####	1	sets	P

Date of Delivery: _____
Price Validity : _____
Terms of Payment: _____

Place of Delivery: GSCWD Bodega

****No partial delivery allowed****

Note: 6% WITHHOLDING TAX DEDUCTION

PR NO.: 0120-018

Requested by:

Price quoted by:

an
GESE A. CABAÑER
MATERIAL PROCUREMENT
OFFICER A

Supplier

Date



TECHNICAL SPECIFICATION

TITLE: PURCHASE OF ONE (1) SET BRAND NEW Digital Variable Frequency Drive MOTOR CONTROLLER COMPLETES WITH ACCESSORIES

1.0 SCOPE OF CONTRACT

The scope of work shall be supply, testing, delivery and commissioning of one (1) set Digital Variable Frequency Drive motor controller completes with accessories to General Santos City Water District (GSCWD).

2.0 MOTOR CONTROLLER REQUIREMENTS

2.1 Digital Variable Frequency Drive CONTROLLER SPECIFICATIONS:

1. Enclosure, Free Standing, IP55 ingress protection, gasketed with screened/louver ventilation and ventilation fan industrial type 220Vac, cable glands for supply power, motor supply and control cables.
2. Molded Case circuit breaker, 3 Pole, 200Amp, 480Vac minimum operating voltage with built in shunt trip coil @ 440Vac.
3. 3 phase Over/Under Voltage relay with phase rotation and delay 380vac – 500Vac.
4. 3 pole, MCB, 10Amp, 480Vac, dinrail mount. 2 pcs.
5. Transient Voltage surge suppressor (TVSS), 600Vac, 3 phase + N. 35Kaic with monitoring LED. Nema Standard.



6. 750VA, dry type transformer, 480Vac- 220Vac/110Vac, 1 phase, center tap.
7. LED Lamp. 220Vac with door limit switch.
8. Illuminated push buttons, 220Vac, start, stop and reset.
9. Local and remote selector switch. 3 position, maintained.
10. Liquid Level relay, hi and low for well application. 220Vac control voltage. Complete with liquid level relay probe.
11. Digital Variable Frequency Drive with torque control system, speed output frequency 0.1 - 599Hz and acceleration-deceleration ramps 0.01 – 9999s. 3 phase, 380-500Vac voltage range(+/-10-15% tolerance), 125hp @ 480vac, heavy duty application. Graphical terminal display, SCADA ready, built pumping control system and integrated EMC filter. With provision for external reset, external start stop, external speed control. Complete protection against phase rotation, over/under voltage, thermal overcurrent, lock rotor, ground fault, under current, definite time overcurrent. Digital monitoring of voltage, current, frequency, energy, kw and fault history included. With RS485 communication port.
12. Pre-wired for constant pressure system
13. Control wiring and power wiring design (cable type and rating Included) shall be included for review with the proposal. VFD, Breakers, TVSS specs shall also be submitted along with the quotation.



14. Installation supervision and commissioning and training must be included in the offer.

3.0 DELIVERY TERMS AND CONDITIONS

- 5.1 The winning bidder shall deliver one (1) set Digital Variable Frequency Drive motor controller completes with accessories within **Thirty (30)** calendar days upon receipt of Purchase Order (PO).
- 5.2 The winning bidder shall be subjected to Liquidated Damages (LD) for each day of delay as provided by the IRR of RA 9184.


4.0 SPECIAL PROVISION

- 6.1 That the winning bidder shall issue a warranty certificate of not less than one (1) year and the warranty shall commence from the date of commissioning of the pumping equipment.
- 6.2 That the winning bidder shall provide technical manuals of the Digital Variable Frequency Drive motor controller to GSCWD and shall conduct technical orientation on standard operating procedures to the GSCWD representatives.
- 6.3 That the bidder must have an available qualified and trained technicians 24/7 in case of equipment failure.

Prepared by:


EDMUND L. BADAL, REE
TWG - Member

Approval:


ROGELIO A. BESANA JR. C.E./RMP
Manager A - Engineering & Const'n. Dept.