



Republic of the Philippines  
GENERAL SANTOS CITY WATER DISTRICT  
E. Fernandez Street, Barangay Lagao General Santos  
Telephone No.: 552-3824; Telefax No.: 553-4960  
Email Address: gscwdprocurement@yahoo.com

GPM-014-2

**REQUEST FOR QUOTATION**

RFQ #: 3-0220-008      DATE: 02/04/2020

SUPPLIER: \_\_\_\_\_  
ADDRESS: \_\_\_\_\_  
TELEPHONE NO. : \_\_\_\_\_  
TIN NO. : \_\_\_\_\_

Dear Sir/Madam,

Pls. quote your lowest price on the item/s listed below subject to general condition stating the shortest time of delivery and submit your quotation duly signed by your representative not later than 02/10/2020, Pls. furnish this office the following articles subject to the terms and conditions contained therein.

ITEM NO.	DESCRIPTION	QTY.	UNIT	UNIT PRICE
1	METERING PUMP : PLEASE SEE ATTACHED SPECIFICATIONS-ABC: PHP 90,000.00 ##### nothing follows #####	3	sets	P

Date of Delivery: \_\_\_\_\_  
Price Validity : \_\_\_\_\_  
Terms of Payment: \_\_\_\_\_

Place of Delivery: GSCWD Bodega

\*\*\*\*\*No partial delivery allowed\*\*\*\*\*

Note: 6% WITHHOLDING TAX DEDUCTION

PR NO.: 0120-017


Requested by:

*all*  
**JESE A. BAREF**  
MATER. PROCUREMENT  
OFFICER A

Price quoted by:

\_\_\_\_\_  
Supplier

\_\_\_\_\_  
Date



## **PURCHASE OF THREE (3) SETS BRAND NEW METERING/DOSING PUMP**

### **1.0 SCOPE OF CONTRACT**

The scope of work shall be supply and delivery of three (3) sets brand new metering/dosing pump to General Santos City Water District (GSCWD).

### **2.0 SPECIFICATION REQUIREMENTS**

<b>Item No.</b>	<b>Particulars</b>	<b>Requirements</b>
1	MAXIMUM CAPACITY	30 GPD
2	MAXIMUM PRESSURE	100 PSIG
3	CONNECTIONS (TUBING)	1/4" I.D. 3/4" O.D.
4	REPRODUCIBILITY AT MAXIMUM CAPACITY	+/-3%
5	VISCOUSITY MAXIMUM CPS	1000
6	STROKE FREQUENCY MAX SPM	125
7	TURN DOWN RATIO	10:1
8	POWER INPUT	230VAC, 50-60HZ, 1 PHASE
9	AVERAGE CURRENT DRAW AT 230 VAC	0.3 AMPS
10	PEAK INPUT POWER	130 WATTS
11	AVERAGE INPUT POWER AT MAX SPM	50 WATTS

### **3.0 REQUIRED FEATURES**

- 3.1 Automatic Control, available with 4-20mADC direct or external pacing, with stop function.






- 3.2 Manual Control by on-line adjustable stroke rate and stroke length.
- 3.3 With Auto-Off-Manual switch.
- 3.4 With Highly Reliable timing circuit.
- 3.5 Circuit Protection against voltage and current upsets and with Panel Mounted Fuse.
- 3.6 Solenoid Protection by thermal overload with auto-reset.
- 3.7 Water Resistant, for outdoor and indoor applications. Indicator Lights, panel mounted.

#### **4.0 TERMS AND CONDITIONS**

- 4.1 Delivery period shall be within 60 calendar days upon receipt of the confirmed purchase order.
- 4.2 Warranty period of the supplied units shall be within one (1) year and shall commence from the date of acceptance.

Prepared by:

  
**DLUANIE R. ENERIO, ME**  
WUDO-A

Checked by:

  
**ROGELIO A. BESANA JR. C.E.,RMP**  
Manager A- Engineering & Construction Dept.