



Republic of the Philippines  
**GENERAL SANTOS CITY WATER DISTRICT**  
 E. Fernandez Street, Barangay Lagao General Santos  
 Telephone No.: 552-3824; Telefax No.: 553-4960  
 Email Address: gscwdprocurement@yahoo.com

GPM-014-2

**REQUEST FOR QUOTATION**

RFQ #: 3-0220-009      DATE: 02/04/2020

SUPPLIER: \_\_\_\_\_  
 ADDRESS: \_\_\_\_\_  
 TELEPHONE NO. : \_\_\_\_\_  
 TIN NO. : \_\_\_\_\_

Dear Sir/Madam,

Pls. quote your lowest price on the item/s listed below subject to general condition stating the shortest time of delivery and submit your quotation duly signed by your representative not later than 02/10/2020, Pls. furnish this office the following articles subject to the terms and conditions contained therein.

ITEM NO.	DESCRIPTION	QTY.	UNIT	UNIT PRICE
1	SUBMERSIBLE MOTOR* : ABC: PHP 430,000.00 ##### nothing follows #####	1	unit	P

Date of Delivery: \_\_\_\_\_  
 Price Validity : \_\_\_\_\_  
 Terms of Payment: \_\_\_\_\_

Place of Delivery: GSCWD Bodega  
 \*\*\*\*\*No partial delivery allowed\*\*\*\*\*  
 Note: 6% WITHHOLDING TAX DEDUCTION  
 PR NO.: 0120-063

Requested by:

Price quoted by:

**GESE A. CABANER**  
 MATERIAL PROCUREMENT  
 OFFICER A

\_\_\_\_\_  
 Supplier

\_\_\_\_\_  
 Date



## **TECHNICAL SPECIFICATION**

### **TITLE: PURCHASE OF ONE (1) UNIT BRAND NEW SUBMERSIBLE MOTOR**

#### **1.0 SCOPE OF CONTRACT**

The scope of work shall be supply and delivery of one (1) unit submersible motor to General Santos City Water District (GSCWD).

#### **2.0 SUBMERSIBLE MOTOR REQUIREMENTS**

<b>Particulars</b>	<b>Requirement</b>
<b>Motor Rating, HP (kW)</b>	100 / 75
<b>Frequency (Hz)</b>	60
<b>Rated Voltage (Volts)</b>	460
<b>Phase</b>	3
<b>Service Factor</b>	1.15
<b>Power Factor(4/4)</b>	0.80
<b>Design point</b>	3400-3600 RPM
<b>Winding</b>	Encapsulated in anti-tracking resin (non-rewindable)
<b>Stator area</b>	Hermetically-sealed
<b>Water-block lead</b>	Removable connection
<b>Flange design</b>	Double
<b>Shell</b>	Stainless Steel
<b>Shaft</b>	Splined stainless steel
<b>Thrust bearing</b>	water lubricated
<b>Diaphragm</b>	Pressure equalizing
<b>Slinger</b>	Sand Fighter
<b>Lead wire configurations</b>	3
<b>Bar rotor</b>	Copper
<b>Minimum Motor Resistance (Mega ohms)</b>	1000 (not spliced, not submerged)




### 3.0 TERMS AND CONDITIONS

- 5.1 The supplier shall deliver the submersible motor within **Ten (10)** calendar days upon receipt of Purchase Order (PO).
- 5.2 The submersible motor must comply with PEC standard as to their current rating with load and without load.
- 5.3 That the winning bidder shall issue a warranty certificate of not less than one (1) year and the warranty shall commence from the date of commissioning of the pumping equipment.
- 5.4 That the bidder must have an available qualified and trained technicians 24/7 in case of equipment failure.

Prepared by:

  
**DLUANIE R. ENERIO, ME**  
WUDO-A

Checked by:

  
**ROGELIO A. BESANA JR. C.E./RMP**  
Manager A – Engineering & Const'n. Dept.