



Republic of the Philippines  
GENERAL SANTOS CITY WATER DISTRICT  
E. Fernandez Street, Barangay Lagao General Santos  
Telephone No.: 552-3824; Telefax No.: 553-4960  
Email Address: gscwdprocurement@yahoo.com

GPM-014-2

**REQUEST FOR QUOTATION**

RFQ #: 3-0220-022      DATE: 02/11/2020

SUPPLIER: \_\_\_\_\_  
ADDRESS: \_\_\_\_\_  
TELEPHONE NO. : \_\_\_\_\_  
TIN NO. : \_\_\_\_\_

Dear Sir/Madam,

Pls. quote your lowest price on the item/s listed below subject to general condition stating the shortest time of delivery and submit your quotation duly signed by your representative not later than 02/17/2020, Pls. furnish this office the following articles subject to the terms and conditions contained therein.

ITEM NO.	DESCRIPTION	QTY.	UNIT	UNIT PRICE
1	LABOR & MATERIALS* : PLEASE SEE ATTACHED SCOPE OF SUPPLY-ABC: PHP 580,000.00 ##### nothing follows #####	1	LOT	P

Date of Delivery: \_\_\_\_\_  
Price Validity : \_\_\_\_\_  
Terms of Payment: \_\_\_\_\_

Place of Delivery: GSCWD Bodega

\*\*\*\*No partial delivery allowed\*\*\*\*

Note: 6% WITHHOLDING TAX DEDUCTION  
PR NO.:

Requested by:

Agnes P. Tampico  
SIRDG - A

Price quoted by:

\_\_\_\_\_  
Supplier

\_\_\_\_\_  
Date



## **SCOPE OF SUPPLY**

### **TITLE: Supply, Delivery and Installation of Flexible hose for Pumping Station No. 21, MSU Compound, Brgy. Tambler, General Santos City.**

#### **I. Description**

The scope of work shall be supply, delivery and installation of flexible hose assembly to be utilized as riser of submersible pump and motor.

#### **II. Scope of Work**

1. Provide necessary tools and equipment.
2. Provide trained technicians to conduct the installation.
3. Provide personal protective equipment for the personnel that will be performing the activity.
4. Perform commissioning of the newly installed unit.

#### **III. Scope of Supply**

1. Flexible Riser Specification
  - a. Nominal size : 6 inches (150mm)
  - b. Length : 70 meters
  - c. Burst pressure : 44 bars
  - d. Peak Tensile load : 16 tonnes
  - e. Weight : 2.5 kg/m
  - f. Maximum diametric swell : 15%
  - g. Maximum operating temperature : 60°C
  - h. Water pH range : 3 to 9
  - i. Safety Factor : 2:1
  - j. Made of tough Polyurethane Cover
  - k. With woven Polyester Fabric
  - l. Strips with loop every meter to secure power cable
  - m. Impregnated Polyurethane lining bonded to outer to eliminate separation.
  - n. Potable Water Approval : AS4020
2. Flexible Coupling : 2 PCS, 304 SS, CODE CF60A
3. Flexible Cable Ties : 140pcs
4. Flexible Break-off Plug : 1 set, Fitted, CODE BO00F

#### **IV. Terms & Conditions**

1. The customer GSCWD shall not be held liable for any damage in the equipment or tools incur during the said activity.




Republic of the Philippines  
**GENERAL SANTOS CITY WATER DISTRICT**  
E. Fernandez St., Lagao, General Santos City

---

2. Our maintenance personnel will be assisting your technicians in the field.
3. All relevant or incidental cost like food and allowances of the personnel shall be borne entirely by the supplier.
4. Warranty of the flexible hose including accessories shall be one (1) year from the date of commissioning.

Prepared by:

  
**DUANE R. ENERIO, ME**  
WUDO-A

Checked and Approved by:

  
**ROGELIO A. BESANA JR. C.E./RMP**  
Department Manager A – Engineering & Construction