



Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT
 E. Fernandez Street, Barangay Lagao General Santos
 Telephone No.: 552-3824; Telefax No.: 553-4960
 Email Address: gscwdprocurement@yahoo.com

GPM-014-2

REQUEST FOR QUOTATION

RFQ #: 3-0220-042 DATE: 2/19/2020

SUPPLIER: _____
 ADDRESS: _____
 TELEPHONE NO. : _____
 TIN NO. : _____

Dear Sir/Madam,

Pls. quote your lowest price on the item/s listed below subject to general condition stating the shortest time of delivery and submit your quotation duly signed by your representative not later than 2/25/2020, Pls. furnish this office the following articles subject to the terms and conditions contained therein.

ITEM NO.	DESCRIPTION	QTY.	UNIT	UNIT PRICE
1	ELECTROMAGNETIC FLOWMETER FULLBORE TYPE AC 10` ` : ##### nothing follows ##### PLS. SEE ATTACHED SPECIFICATION ABC P 200, m.v	1	sets	P

Date of Delivery: _____
 Price Validity : _____
 Terms of Payment: _____

Place of Delivery: GSCWD Bodega

*****No partial delivery allowed****

Note: 6% WITHHOLDING TAX DEDUCTION

PR NO.:

Requested by: *an*
 NADAL, ANDREW H

Price quoted by:

 Supplier

 Date



TECHNICAL SPECIFICATION

TITLE: PURCHASE OF BRAND NEW 1 UNIT 250MM Φ (10" Φ) ELECTROMAGNETIC FLOWMETER, FULLBORE AND FLANGE TYPE

SIZE	250mm Φ (10" Φ)
TYPE	Electromagnetic Flow meter
BORE	Full Bore
POWER SUPPLY	115 - 230 VAC
MEASUREMENTS	Direct / Inverse Flow
CABLE	10 meters w/ complete accessories
CONNECTION	Flanged Type, PN 16
LINING	Hard Rubber for Potable Water
RATING	IP 67/NEMA 6

TERMS AND CONDITIONS

1. The scope of work shall be supply, delivery and commissioning of **brand new 1 unit 250mm ϕ (10" ϕ) electromagnetic flowmeter, fullbore and flange type** to General Santos City Water District (GSCWD).
2. The **electromagnetic flowmeter** shall be tested in a laboratory determined by GSCWD before delivery to ensure conformance with the design parameters. The cost of the laboratory testing shall be borne entirely by the winning bidder.



3. The winning bidder is required to submit actual documents (manuals, data sheets, manufacturer's test results, name plate specifications and etc.) of the unit that is to be tested prior to the scheduling of laboratory testing.
4. The flowmeter shall be tested for accuracy in a laboratory for maximum, nominal, and transitional flow rates. The result shall be the basis for the flowmeter to **PASS** or **FAIL** in the accuracy test.
5. Laboratory testing shall be witnessed by three (3) GSCWD representatives together with the winning bidder's representatives for three (3) days. All relevant and incidental cost (Testing fee, transportation, accommodation, allowances and etc.) in the testing of the equipment shall be shouldered by the winning bidder.
6. In case the unit to be tested is different from the submitted documents and/or do not comply with the specifications set by GSCWD, laboratory testing shall not be conducted.
7. In case the unit failed to pass the testing requirements during laboratory testing, the winning bidder shall replace the unit subject to another laboratory testing without cost to GSCWD.
8. That during the installation and commissioning of the unit, the winning bidder shall be required to send a technician responsible of commissioning. All relevant and incidental cost (transportation, accommodation, allowances and etc.) in the commissioning of the equipment shall be shouldered by the winning bidder.
9. Field testing shall be made once the unit is ready for operation and when both the GSCWD and winning bidder have finished their scopes of work on the installed unit. GSCWD engineers shall conduct field testing with the presence of winning bidder's representative. Flowmeter must meet the testing requirements in terms of efficiency. In case the unit



unit failed to pass the field testing, the winning bidder shall make necessary corrections / changes to replace the unit without cost to GSCWD.

10. The winning bidder shall deliver the **brand new 1 unit 250mm ϕ (10" ϕ) electromagnetic flowmeter, fullbore and flange type** within **Thirty (30)** calendar days upon receipt of Purchase Order (PO). Laboratory testing is included in the 30- calendar day's delivery period.
11. The winning bidder shall be subjected to Liquidated Damages (LD) for each day of delay as provided by the IRR of RA 9184.
12. That the winning bidder shall issue a warranty certificate of not less than one (1) year and the warranty shall commence from the date of commissioning of the pumping equipment. That the bidder must have an available qualified and trained technicians 24/7 in case of equipment failure.

Prepared by:


EDMUND L. BADAL, REE
SWRFT-A

Checked by:


MARY ANN SANDY D. PINOS, ME
Precision Instrument Repair & Maintenance Services Chief



Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT (GSCWD)
GSCWD Bldg., E. Fernandez Street (Emergency Road), Lagao, General Santos City
Telephone No.: 552-3824/554-7231; Telefax No.: 553-4960
E-mail Address: gscwaterdistrict@yahoo.com

Noted by:

ROGELIO A. BESANA JR. C.E./RMP

Manager A – Engineering & Construction Dept.

Approved by:

ARN B. GELLANGARIN, PME

General Manager A