



Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT
E. Fernandez Street, Barangay Lagao General Santos
Telephone No.: 552-3824; Telefax No.: 553-4960
Email Address: gscwdprocurement@yahoo.com

GPM-014-2

REQUEST FOR QUOTATION

RFQ #: 3-0221-012 DATE: 02/03/2021

SUPPLIER: _____
ADDRESS: _____
TELEPHONE NO. : _____
TIN NO. : _____

Dear Sir/Madam,


Pls. quote your lowest price on the item/s listed below subject to general condition stating the shortest time of delivery and submit your quotation duly signed by your representative not later than 02/09/2021, Pls. furnish this office the following articles subject to the terms and conditions contained therein.

ITEM NO.	DESCRIPTION	QTY.	UNIT	UNIT PRICE
1	SUBMERSIBLE CABLE ROUND : 100MM ² , PLEASE SEE ATTACHED SPECIFICATIONS-ABC: PHP 398,000.00	65	mtrs	P
2	SUBMERSIBLE CABLE ROUND : 80MM ² , PLEASE SEE ATTACHED SPECIFICATIONS-ABC: PHP 332,000.00 ##### nothing follows #####	65	mtrs	P

Date of Delivery: _____
Price Validity : _____
Terms of Payment: _____

Place of Delivery: GSCWD Bodega
****No partial delivery allowed****
Note: 6% WITHHOLDING TAX DEDUCTION
PR NO.: 0121-086

Requested by:


OSEM R. CABAÑERO
MATERIAL PROCUREMENT
OFFICER A

Price quoted by:

Supplier

Date



TECHNICAL SPECIFICATION

TITLE: PURCHASE OF ASSORTED SIZES BRAND NEW SUBMERSIBLE CABLE

1.0 SCOPE OF CONTRACT

The scope shall be supply and delivery three (3) units assorted brand new submersible cable to General Santos City Water District (GSCWD).

2.0 Submersible cable specifications

PARTICULARS	REQUIREMENT	
	Set 1	Set 2
Type	Round	Round
Size (mm ²)	80	100
Length (meters)	65	65
No. of Leads	3	3
Maximum Operating Temperature (°C)	75	75
All Submersible Cables shall be PVC- insulated with PVC & PE jacket		



3.0 Other materials used for splicing Submersible Cable

Particulars	Requirements
Shrinkable Termination Kit/ Splicing Kit	3 sets (9 Pcs) kit No.82-A3
100mm ² Butt Connector (pieces)	3
80mm ² Butt Connector (pieces)	6
Rubber Tape	Eighteen (18) rolls; with ASTM D-4388 type 1,2 &3/ HH-I-3825B approval.
Electrical Tape	Eighteen (18) rolls ; Super 33+ Vinyl Electrical Tape

4.0 TERMS AND CONDITIONS


1. The scope of work shall be supply and delivery of assorted sizes brand new submersible cable to General Santos City Water District (GSCWD).
2. The winning bidder is required to submit actual documents (data sheets, manufacturer's test results, and etc.) of the units.
3. The winning bidder shall deliver the submersible cable within **Ninety (90)** calendar days upon receipt of Purchase Order (PO). Laboratory testing is included in the 90- calendar day's delivery period.
4. The winning bidder shall be subjected to Liquidated Damages (LD) for each day of delay as provided by the IRR of RA 9184.
5. The submersible cable must comply with PEC standard as to their current capacity.




6. That the winning bidder shall issue a warranty certificate of not less than one (1) year and the warranty shall commence from the date of commissioning of the Submersible Cables.
7. That the bidder must have an available qualified and trained technicians 24/7 in case of unit/units failure.

Prepared by:


EDMUND L. BADAL, REE
TWG – Member


DLUANIE R. ENERIO, ME
TWG – Member


JUDY LIM PASMAN
TWG – Member


MICHAEL G. GABALES, REE
TWG – HEAD

Approval:

ARN B. GELLANGARIN, PME
General Manager A

Recommending Approval:


ROGELIO A. BESANA JR. C.E./RMP
Manager A – Engineering & Const'n. Dept.