



Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT
 E. Fernandez Street, Barangay Lagao General Santos
 Telephone No.: 552-3824; Telefax No.: 553-4960
 Email Address: gscwdprocurement@yahoo.com

GPM-014-2

REQUEST FOR QUOTATION

RFQ #: 3-0321-004 DATE: 03/02/2021

SUPPLIER: _____
 ADDRESS: _____
 TELEPHONE NO. : _____
 TIN NO. : _____

Dear Sir/Madam,

Pls. quote your lowest price on the item/s listed below subject to general condition stating the shortest time of delivery and submit your quotation duly signed by your representative not later than 03/08/2021, Pls. furnish this office the following articles subject to the terms and conditions contained therein.

ITEM NO.	DESCRIPTION	QTY.	UNIT	UNIT PRICE
1	FLEXIBORE HOSE : 200MM DIAMETER/ PLEASE SEE ADDITIONAL SPECIFICATIONS-ABC: PHP 550,000.00	1	length	P
2	FLEXIBORE HOSE : 250MM DIAMETER/ PLEASE SEE ADDITIONAL SPECIFICATIONS-ABC: PHP 440,000.00 ##### nothing follows #####	1	length	P

Date of Delivery: _____
 Price Validity : _____
 Terms of Payment: _____

Place of Delivery: GSCWD Bodega
 *****No partial delivery allowed*****
 Note: 6% WITHHOLDING TAX DEDUCTION
 PR NO.: 0221-072

Requested by:

Price quoted by:

GEZEM R. CABAÑERO
 MATERIAL PROCUREMENT
 OFFICER A

 Supplier

 Date



SCOPE OF SUPPLY

TITLE: SUPPLY AND DELIVERY OF 8 INCHES FLEXIBLE HOSE ASSEMBLY

I. Description

The scope of work shall be supply and delivery of flexible hose assembly to be utilized as riser of submersible pump and motor.

II. Technical specifications of Flexible hose

1. Flexible Riser Specification

a. Nominal size	:	8 inches
b. Internal Diameter	:	200 mm
c. Length	:	60 meters
d. Burst pressure	:	42 bars
e. Maximum recommended operating pressure	:	21 bar
f. Peak Tensile load	:	22.0 tonnes
g. Maximum recommended tensile load	:	11 tonnes
h. Weight	:	3.4 kg/m
i. Outer diameter of coupling	:	270mm
j. Weight of coupling stainless steel	:	41 kg
k. Weight of water at 10% swell	:	31.00 kg/m
l. Maximum flow rate	:	148 liters/sec
m. Maximum operating temperature	:	60°C
n. Water pH range	:	3 to 9
o. Safety Factor	:	2:1
p. Made of tough Polyurethane Cover		
q. With woven Polyester Fabric		
r. Strips with loop every meter to secure power cable		
s. Impregnated Polyurethane lining bonded to outer to eliminate separation.		
t. Potable Water Approval	:	AS4020
2. Flexible Coupling	:	2 PCS, 304 SS, CODE CF60A
3. Flexible Cable Ties	:	140pcs
4. Flexible Break-off Plug	:	1 set, Fitted, CODE BO00F

IV. Terms & Conditions

1. The flexible hose assembly shall be delivered at GSCWD warehouse office within 90 calendar days. Liquidated damages shall be imposed on the delay after the delivery period.
2. Warranty of the flexible hose including accessories shall be five (5) years from the date of commissioning.




Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT
E. Fernandez St., Lagao, General Santos City

Prepared by:


DLUANIE R. ENERIO, ME
WUDO-A

Checked and Approved by:


ROGELIO A. BESANA JR. C.E./RMP
AGM - Operations and Technical Services



SCOPE OF SUPPLY

TITLE : SUPPLY AND DELIVERY OF 6 INCHES FLEXIBLE HOSE ASSEMBLY

I. Description

The scope of work shall be supply and delivery of flexible hose assembly to be utilized as riser of submersible pump and motor.

1. Flexible Riser Specification

- | | | |
|---|---|---------------------------|
| a. Nominal size | : | 6 inches |
| b. Internal Diameter | : | 152 mm |
| c. Length | : | 60 meters |
| d. Burst pressure | : | 44 bars |
| e. Maximum recommended operating pressure | : | 22 bar |
| f. Peak Tensile load | : | 22.0 tonnes |
| g. Maximum recommended tensile load | : | 8 tonnes |
| h. Weight | : | 2.5 kg/m |
| i. Outer diameter of coupling | : | 190mm |
| j. Weight of coupling stainless steel | : | 13 kg |
| k. Weight of water at 10% swell | : | 21.96 kg/m |
| l. Maximum flow rate | : | 90 liters/sec |
| m. Maximum operating temperature | : | 60°C |
| n. Water pH range | : | 3 to 9 |
| o. Safety Factor | : | 2:1 |
| p. Made of tough Polyurethane Cover | | |
| q. With woven Polyester Fabric | | |
| r. Strips with loop every meter to secure power cable | | |
| s. Impregnated Polyurethane lining bonded to outer to eliminate separation. | | |
| t. Potable Water Approval | : | AS4020 |
| 2. Flexible Coupling | : | 2 PCS, 304 SS, CODE CF60A |
| 3. Flexible Cable Ties | : | 140pcs |
| 4. Flexible Break-off Plug | : | 1 set, Fitted, CODE BO00F |


IV. Terms & Conditions

1. The flexible hose assembly shall be delivered at GSCWD warehouse office within 90 calendar days. Liquidated damages shall be imposed on the delay after the delivery period.
2. Warranty of the flexible hose including accessories shall be five (5) years from the date of commissioning.




Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT
E. Fernandez St., Lagao, General Santos City

Prepared by:


DLUANIER R. ENERIO, ME
WUDØ-A

Checked and Approved by:


ROGELIO A. BESANA JR. C.E./RMP
AGM – Operations and Technical Services