



Republic of the Philippines  
GENERAL SANTOS CITY WATER DISTRICT  
E. Fernandez Street, Barangay Lagao General Santos  
Telephone No.: 552-3824; Telefax No.: 553-4960  
Email Address: gscwdprocurement@yahoo.com

GPM-014-2

### REQUEST FOR QUOTATION

RFQ #: 3-0321-046      DATE: 03/22/2021

SUPPLIER: \_\_\_\_\_  
ADDRESS: \_\_\_\_\_  
TELEPHONE NO. : \_\_\_\_\_  
TIN NO. : \_\_\_\_\_

Dear Sir/Madam,

Pls. quote your lowest price on the item/s listed below subject to general condition stating the shortest time of delivery and submit your quotation duly signed by your representative not later than 03/26/2021, Pls. furnish this office the following articles subject to the terms and conditions contained therein.

ITEM NO.	DESCRIPTION	QTY.	UNIT	UNIT PRICE
1	INSULATION RESISTANCE TESTER (MEGER) : PLEASE SEE ATTACHED SPECIFICATIONS-ABC: PHP 50,000.00 ##### nothing follows #####	1	unit	P

Date of Delivery: \_\_\_\_\_  
Price Validity : \_\_\_\_\_  
Terms of Payment: \_\_\_\_\_

Place of Delivery: GSCWD Bodega

\*\*\*\*\*No partial delivery allowed\*\*\*\*

Note: 6% WITHHOLDING TAX DEDUCTION

PR NO.: 0321-045

Requested by:

**GESEM R. CABAÑERO**  
MATERIAL PROCUREMENT  
OFFICER A

Price quoted by:

\_\_\_\_\_  
Supplier

\_\_\_\_\_  
Date



## **TECHNICAL SPECIFICATION**

### **TITLE: PURCHASE OF MEGGER (INSULATION RESISTANCE METER)**

#### **1.0 SCOPE OF CONTRACT**

The scope shall be supply and delivery of Megger (Insulation Resistance Meter) to General Santos City Water District (GSCWD).

#### **2.0 Megger (Insulation Resistance Meter) Specifications**

Particulars	Requirements
Test Voltage	DC 1000V
Insulation Resistance	0 - 2000M $\Omega$
Accuracy	$\pm 5\%$ of reading (1st effective measurement range) $\pm 10\%$ of reading (2nd effective measurement range)
Size / Mass	H144×W99×D43mm. 310g / approx.
Safety	IEC61010 CAT.III 600V
DCV measurement range	60V
DCV Accuracy	$\pm 5\%$ of full scale





ACV	600V
ACV Accuracy	±5% of full scale (50~60Hz sine wave)
Rated Current	1.0~1.2mA
Battery	6LR61 (9V)×1
Test lead	TLF-120
*One-shot or continuous measurement push switch	
*Auto discharge function	
*Inner battery check range	
*Shoulder Strap	

## 5.0 TERMS AND CONDITIONS

- 5.1 The scope of work shall be supply and delivery of Megger (Insulation Resistance Meter) to General Santos City Water District (GSCWD).
- 5.2 The winning bidder shall deliver the Megger (Insulation Resistance Meter) within **Ninety (60)** calendar days upon receipt of Purchase Order (PO).
- 5.3 The winning bidder shall be subjected to Liquidated Damages (LD) for each day of delay as provided by the IRR of RA 9184.



5.4 That the winning bidder shall issue a warranty certificate of not less than one (1) year and the warranty shall commence from the date of delivery.

Prepared by:

**EDMUND L. BADAL, REE**  
TWG - Member

**JUDY LIM PASKAN**  
TWG - Member

**MICHAEL G. GABALES, REE**  
TWG - HEAD

Recommending Approval:

**ROGELIO A. BESANA JR. C.E./RMP**  
Manager A - Engineering & Const'n. Dept.

Approval:

**ARN B. GELLANGARIN, PME**  
General Manager A