



Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT
E. Fernandez Street, Barangay Lagao General Santos
Telephone No.: 552-3824; Telefax No.: 553-4960
Email Address: gscwdprocurement@yahoo.com

GPM-014-2

REQUEST FOR QUOTATION

RFQ #: 3-0421-041 DATE: 04/20/2021

SUPPLIER: _____
ADDRESS: _____
TELEPHONE NO. : _____
TIN NO. : _____


Dear Sir/Madam,

Pls. quote your lowest price on the item/s listed below subject to general condition stating the shortest time of delivery and submit your quotation duly signed by your representative not later than 04/26/2021, Pls. furnish this office the following articles subject to the terms and conditions contained therein.

ITEM NO.	DESCRIPTION	QTY.	UNIT	UNIT PRICE
1	MAGNETIC CONTACTOR* : 125HP, 440V, 185A, HOLDING COIL VOLTAGE:220V / PLEASE SEE ATTACH SPECIFICATION-ABC: PHP 165,000.00	6	pc	P
2	MAGNETIC CONTACTOR* : 100HP, 440V, 150A, HOLDING COIL VOLTAGE:220V / PLEASE SEE ATTACH SPECIFICATION-ABC: PHP 132,000.00	6	pc	P
3	MAGNETIC CONTACTOR* : 4KW, 220, 9A, HOLDING COIL VOLTAGE:220V / PLEASE SEE ATTACH SPECIFICATION-ABC: PHP 2,600.00 ##### nothing follows #####	2	pc	P

Date of Delivery: _____
Price Validity : _____
Terms of Payment: _____

Place of Delivery: GSCWD Bodega
*****No partial delivery allowed****
Note: 6% WITHHOLDING TAX DEDUCTION
PR NO.: 0421-011

Requested by:

GESSEM R. CABAÑERO
MATERIAL PROCUREMENT
OFFICER A

Price quoted by:

Supplier

Date



TECHNICAL SPECIFICATION

TITLE: PURCHASE OF ASSORTED SIZES OF MAGNETIC CONTACTOR

A.) 92kW MAGNETIC CONTACTOR OPERATING REQUIREMENTS

Particulars	Requirements
Number Of Unit	6
Motor Power Hp (UI)	92kW, 440V, 3P
Rated Operational Current	185A @440V, AC3
Rated Operational Voltage	690VAC, 3P, 50/60HZ
Control Circuit Voltage	220VAC, 50/60HZ
Auxiliary Contact	3NO + 2NC
Front Face	IP 20
Mounting Support	Plate / Rail
Breaking Capacity	1480A



Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT (GSCWD)
GSCWD Bldg., E. Fernandez Street (Emergency Road), Lagao, General Santos City
Telephone No.: 552-3824/554-7231; Telefax No.: 553-4960
E-mail Address: gscwaterdistrict@yahoo.com

B.) 75kW MAGNETIC CONTACTOR OPERATING REQUIREMENTS

Particulars	Requirements
Number Of Unit	6
Motor Power Hp (UI)	75kW, 440V, 3P
Rated Operational Current	150A @440V, AC3
Rated Operational Voltage	690VAC, 3P, 50/60HZ
Control Circuit Voltage	220VAC, 50/60HZ
Auxiliary Contact	3NO + 2NC
Front Face	IP 20
Mounting Support	Plate / Rail
Breaking Capacity	1400A



Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT (GSCWD)
GSCWD Bldg., E. Fernandez Street (Emergency Road), Lagao, General Santos City
Telephone No.: 552-3824/554-7231; Telefax No.: 553-4960
E-mail Address: gscwaterdistrict@yahoo.com

C.) 4kW MAGNETIC CONTACTOR OPERATING REQUIREMENTS

Particulars	REQUIREMENTS
Number Of Unit	2
Motor Power Hp (UI)	4kW, 440V, 3P
Rated Operational Current	9A @440V, AC3
Rated Operational Voltage	690VAC, 3P, 50/60HZ
Control Circuit Voltage	220VAC, 50/60HZ
Auxiliary Contact	1NO + 1NC
Front Face	IP 20
Mounting Support	Plate / Rail
Breaking Capacity	250A





Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT (GSCWD)
GSCWD Bldg., E. Fernandez Street (Emergency Road), Lagao, General Santos City
Telephone No.: 552-3824/554-7231; Telefax No.: 553-4960
E-mail Address: gscwaterdistrict@yahoo.com

TERMS AND CONDITIONS

- 1.1 The supplier shall submit original catalogue or brochure.
- 1.2 The supplier shall submit a Certificate of Dealership/Distributorship from the Manufacturer.
- 1.3 The supplied Magnetic Contactors, including its accessories shall have one (1) year warranty against defects and the supplier shall provide a warranty certificate. Warranty period shall commence upon issuance of certificate of final acceptance.
- 1.4 That the winning bidder shall have an available qualified and trained technicians 24/7 in case of equipment failure.

Prepared by:


EDMUND L. BADAL, REE
TWG - Member


JUDY LIM PASKAN
TWG - Member


MICHAEL C. GABALES, REE
TWG - HEAD

Recommending Approval:


ROGELIO A. BESANA JR. C.E./RMP
Assistant General Manager

Approval:


ARN B. GELLANGARIN, PME
General Manager A