



Republic of the Philippines  
**GENERAL SANTOS CITY WATER DISTRICT**  
 E. Fernandez Street, Barangay Lagao General Santos  
 Telephone No.: 552-3824; Telefax No.: 553-4960  
 Email Address: gscwdprocurement@yahoo.com

GPM-014-2

**REQUEST FOR QUOTATION**

RFQ #: 3-0620-024      DATE: 7/9/2020

SUPPLIER: \_\_\_\_\_  
 ADDRESS: \_\_\_\_\_  
 TELEPHONE NO. : \_\_\_\_\_  
 TIN NO. : \_\_\_\_\_

Dear Sir/Madam,

Pls. quote your lowest price on the item/s listed below subject to general condition stating the shortest time of delivery and submit your quotation duly signed by your representative not later than 7/15/2020, Pls. furnish this office the following articles subject to the terms and conditions contained therein.

ITEM NO.	DESCRIPTION	QTY.	UNIT	UNIT PRICE
1	SUBMERSIBLE CABLE ROUND : PLS. SEE ATTACHED SPECIFICATION(ABC PHP 500,000.00 ##### nothing follows #####	220	mtrs	P

Date of Delivery: \_\_\_\_\_  
 Price Validity : \_\_\_\_\_  
 Terms of Payment: \_\_\_\_\_

Place of Delivery: GSCWD Bodega  
 \*\*\*\*\*No partial delivery allowed\*\*\*\*\*  
 Note: 6% WITHHOLDING TAX DEDUCTION  
 PR NO.: 0520-018

Requested by:

Price quoted by:

**ANDREW H. NADAL JR.**  
 Administration Services Assistant A

\_\_\_\_\_  
 Supplier

\_\_\_\_\_  
 Date



## **TECHNICAL SPECIFICATION**

### **TITLE: PURCHASE OF BRAND NEW SUBMERSIBLE CABLE**

#### **1.0 SCOPE OF CONTRACT**

The scope shall be supply and delivery of submersible cable to General Santos City Water District (GSCWD).

#### **2.0 SUBMERSIBLE CABLE REQUIREMENTS**

<b>Particulars</b>	<b>Requirements</b>
Type	Round
Size (mm <sup>2</sup> )	50
Length (meters)	220
No. of Leads	3
Maximum Operating Temperature (°C)	75
Shrinkable Termination Kit/ Splicing Kit (3 sets)	kit No.82-A2
Butt Connector (pieces)	3
Rubber Tape	Six (6) rolls; with ASTM D-4388 type 1,2 &3 / HH-I-3825B approval.
Electrical Tape	Six (6) rolls ; Super 33+ Vinyl Electrical Tape





---

## 5.0 TERMS AND CONDITIONS

- 5.1 The scope of work shall be supply and delivery of submersible cable to General Santos City Water District (GSCWD).
- 5.2 The winning bidder is required to submit actual documents (manuals, data sheets, manufacturer's test results, etc.) of the unit.
- 5.3 That during the installation of the submersible cable, the winning bidder shall be required to send a technician responsible of splicing the cable to the Submersible Motor. All relevant and incidental cost (transportation, accommodation, allowances and etc.) in the commissioning of the equipment shall be shouldered by the winning bidder.
- 5.4 Field testing shall be made once the unit is ready for operation and when both the GSCWD and winning bidder have finished their scopes of work on the installed units. GSCWD engineers shall conduct field testing with the presence of winning bidder's representative. Submersible Cable must meet the minimum testing requirements in terms of capacity and efficiency. In case the unit failed to pass the field testing, the winning bidder shall make necessary corrections / changes to replace the unit without cost to GSCWD.



- 
- 5.5** The winning bidder shall deliver the submersible cable within **Thirty (30)** calendar days upon receipt of Purchase Order (PO).
- 5.6** The winning bidder shall be subjected to Liquidated Damages (LD) for each day of delay as provided by the IRR of RA 9184.
- 5.7** The submersible cable must comply with PEC standard as to their current rating and rated temperature.
- 5.8** That the winning bidder shall issue a warranty certificate of not less than one (1) year and the warranty shall commence from the date of commissioning of the submersible cable.
- 5.9** That the bidder must have an available qualified and trained technicians 24/7 in case of equipment failure.

Prepared by:

  
**EDMUND L. BADAL, REE**  
TWG - Member

  
**DLUANIE R. ENERIO, ME**  
TWG - Member




Republic of the Philippines  
GENERAL SANTOS CITY WATER DISTRICT (GSCWD)  
GSCWD Bldg., E. Fernandez Street, Lagao, General Santos City  
Telephone No.: 552-3824/554-7231; Telefax No.: 553-4960  
E-mail Address: gscwaterdistrict@yahoo.com



  
**JUDY LIM PASKAN**  
TWG - Member

  
**MICHAEL G. GABALES, REE**  
TWG - HEAD

Recommending Approval:

  
**ROGELIO A. BESANA JR. C.E./RMP**  
Manager A - Engineering & Const'n. Dept.

Approval:

  
**ARN B. GELLANGARIN, PME**  
General Manager A