



Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT
 E. Fernandez Street, Barangay Lagao General Santos
 Telephone No.: 552-3824; Telefax No.: 553-4960
 Email Address: gscwdprocurement@yahoo.com

GPM-014-2

REQUEST FOR QUOTATION

RFQ #: 3-0721-022 DATE: 07/06/2021

SUPPLIER: _____
 ADDRESS: _____
 TELEPHONE NO. : _____
 TIN NO. : _____

Dear Sir/Madam,


Pls. quote your lowest price on the item/s listed below subject to general condition stating the shortest time of delivery and submit your quotation duly signed by your representative not later than 07/12/2021, Pls. furnish this office the following articles subject to the terms and conditions contained therein.

ITEM NO.	DESCRIPTION	QTY.	UNIT	UNIT PRICE
1	SUBMERSIBLE CABLE ROUND : 80 SQUARE MM. PLEASE SEE ATTACHED SPECIFICATION-ABC: PHP 310,000.00 ##### nothing follows #####	65	mtrs	P

Date of Delivery: _____
 Price Validity : _____
 Terms of Payment: _____

Place of Delivery: GSCWD Bodega
 *****No partial delivery allowed*****
 Note: 6% WITHHOLDING TAX DEDUCTION
 PR NO.: 0421-092

Requested by:


E. CABAÑERO
 MATERIAL PROCUREMENT
 OFFICE A

Price quoted by:

 Supplier

 Date



TECHNICAL SPECIFICATION

TITLE: PURCHASE OF BRAND NEW SUBMERSIBLE CABLE

1.0 SCOPE OF CONTRACT

The scope shall be supply and delivery three (3) units assorted brand new submersible cable to General Santos City Water District (GSCWD).

2.0 Submersible cable specifications

Particulars	Requirements	Statement of Compliance
Type	Round	
Size (mm ²)	80	
Length (meters)	65	
No. of Leads	3	
Maximum Operating Temperature (°C)	75	
All Submersible Cables shall be PVC- insulated with PVC & PE jacket		



3.0 Other materials used for splicing Submersible Cable

Particulars	Requirements	Statement of Compliance
Shrinkable Termination Kit / Splicing Kit 3M brand	1 set (3 Pcs) kit No.82-A3	
80mm ² Butt Connector (pieces)	6	
Rubber Tape 3M brand	Six (6) rolls; with ASTM D-4388 type 1,2 & 3 / HH-I-3825B approval.	
Electrical Tape 3M brand	Six (6) rolls ; Super 33+ Vinyl Electrical Tape	

4.0 TERMS AND CONDITIONS

Item No.	Requirement	Statement of Compliance
1	The scope of work shall be supply and delivery of brand new submersible cable to General Santos City Water District (GSCWD).	
2	The winning bidder is required to submit actual documents (data sheets, manufacturer's test results, and etc.) of the units	
3	The winning bidder shall deliver the submersible cable within thirty (30) calendar days upon receipt of Purchase Order (PO).	
4	The winning bidder shall be subjected to Liquidated Damages (LD) for each day of delay as provided by the IRR of RA 9184.	
5	The submersible cable must comply with PEC standard as to their current capacity.	




Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT (GSCWD)
GSCWD Bldg., E. Fernandez Street, Lagao, General Santos City
Telephone No.: 552-3824/554-7231; Telefax No.: 553-4960
E-mail Address: gscwaterdistrict@yahoo.com



6	That the winning bidder shall issue a warranty certificate of not less than one (1) year and the warranty shall commence from the date of commissioning of the Submersible Cables.	
7	That the bidder must have an available qualified and trained technicians 24/7 in case of unit failure.	


Prepared by:


EDMUND L. BADAL, REE
TWG - Member


JUDY LIM PASKAN
TWG - Member


MICHAEL G. GABALES, REE
TWG - HEAD

Recommending Approval:


ROGELIO A. BESANA JR. C.E./RMP
Manager A - Engineering & Const'n. Dept.

Approval:


ARN B. GELLANGARIN, PME
General Manager A