



Republic of the Philippines GENERAL SANTOS CITY WATER DISTRICT

E. Fernandez Street, Barangay Lagao General Santos Telephone No.: 552-3824; Telefax No.: 553-4960 Email Address: gscwdprocurement@yahoo.com

DATE: 07/06/2021

REQUEST FOR QUOTATION

RFQ #:3-0721-023

SUPPLIER: ADDRESS: TELEPHONE NO. : TIN NO. :				
stating the sl representative	te your lowest price on the item/s listed hortest time of delivery and submit you not later than 07/12/2021 , Pls. furnish terms and conditions contained therein.	below sul ur quota this off	oject to tion dul Tice the	general conditi Ly signed by yo following articl
ITEM NO.	DESCRIPTION	QTY.	UNIT	UNIT PRICE
1 2	VARIABLE FREQUENCY DRIVE (VFD): 125HP, 460V, 3PHASE, 50KAIC. PLEASE ATTACHED SPECIFICATION-ABC: PHP 410,000.00 VARIABLE FREQUENCY DRIVE (VFD): 100HP,	1	sets	P
	460V, 3PHASE, 50KAIC. PLEASE ATTACHED SPECIFICATION-ABC: PHP 480,000.00 ######### nothing follows ###########			
Date of Delivery: Price Validity: Terms of Payment: Place of Delivery: *****No partial de Note: 6% WITHHOLDI PR NO.: 0421-102 Requested by:	livery allowed****	Price q	uoted by:	
ar			Supp	lier
GESEM R. CABASE MATERIAL PROCUREM	30			
The state of the s			T	12+0



Republic of the Philippines

GENERAL SANTOS CITY WATER DISTRICT (GSCWD)

GSCWD Bldg., E. Fernandez Street, Lagao, General Santos City Telephone No.: 552-3824/554-7231; Telefax No.: 553-4960 E-mail Address: gscwaterdistrict@yahoo.com

TECHNICAL SPECIFICATION

TITLE: PURCHASE OF TWO SETS VARIABLE FREQUENCY DRIVE MOTOR CONTROLLER

1.0 SCOPE OF CONTRACT

The scope of work shall be supply, and delivery of Two (2) sets of Variable Frequency Drive Motor Controller to General Santos City Water District (GSCWD).

2.0 125Hp Variable Frequency Drive Operating Requirement

PARTICULARS	REQUIREMENT	Statement of Compliance
Product or Component Type	Variable Frequency Drive	
Accessories	Variable Frequency Drive Only	
Motor power, Hp (Kw)	125 (93)	
AC Voltage Range	380v - 500v	
Voltage % Tolerance	+10% -15%	
Supply Number Of Phases	3 phases	
Prospective line Isc	50 kA	
Maximum Transient Current for 60 s	190 A	
Maximum Continuous Current	173A	



Acceleration- Deceleration Ramps	0.01 - 9999s	
Speed Output Frequency	0.1 - 599Hz	
Enclosure Rating	IP55	
display, SCADA ready, b and integrated EMC filte reset, external start st	plication. Graphical terminal puilt pumping control system r. With provision for external top, external speed control. against phase rotation,	

2.1 100Hp Variable Frequency Drive Operating Requirement

PARTICULARS	REQUIREMENT	Statement of Compliance
Product or Component Type	Variable Frequency Drive	
Accessories	With complete Accessories	
Motor power, Hp (Kw)	100 (75)	
AC Voltage Range	380v - 500v	and a state of the desired of the state of t
Voltage % Tolerance	+10% -15%	
Supply Number Of Phases	3 phases	



Prospective line Isc	50 kA	
Maximum Transient Current for 60 s	160 A	
Maximum Continuous Current	145A	
Acceleration- Deceleration Ramps	0.01 - 9999s	
Speed Output Frequency	0.1 - 599Hz	
Enclosure Rating	IP55	
system, heavy duty app display, SCADA ready, be and integrated EMC filter reset, external start start Complete protection over/under voltage, then	cy Drive with torque control lication. Graphical terminal wilt pumping control system by With provision for external op, external speed control against phase rotation, and overcurrent, lock rotor, current, definite time	
overcurrent. Digital mo	nitoring of voltage, current, and fault history included.	

3.0 100Hp Motor Controller Panel Requirements

Requirement	Statement of Compliance
Enclosure, Free Standing, IP55 ingress protection, gasketted with screened/louver ventilation and ventilation fan industrial type 220Vac, cable glands for supply power, motor supply and control cables.	



Molded Case circuit breaker, 3 Pole, 200Amps, 480Vac minimum operating voltage with built in shunt trip coil @ 440Vac.	
3 phase Over/Under Voltage relay with phase rotation and delay 380vac - 500Vac.	
3 pole, MCB, 10Amp, 480Vac, dinrail mount. 2 pcs.	
Transient Voltage surge suppressor (TVSS), 600Vac, 3 phase + N. 35Kaic with monitoring LED. Nema Standard.	
750VA, dry type transformer, 480Vac- 220Vac/110Vac, 1 phase, center tap.	
LED Lamp. 220Vac with door limit switch.	
Illuminated push buttons, 220Vac, start, stop and reset.	
Local and remote selector switch. 3 positions, maintained.	
Liquid Level relay, hi and low for well application. 220Vac control voltage. Complete with level relay probe.	



4.0 TERMS AND CONDITIONS

Requirements	Statement of Compliance
The winning bidder is required to submit actual documents (manuals, data sheets, manufacturer's test results, name plate specifications, single line diagram and etc.) of the units.	
That during the installation and commissioning of the unit/units, the winning bidder shall be required to send a technician responsible of commissioning the unit/units. All relevant and incidental cost (transportation, accommodation, allowances and etc.) in the commissioning of the equipment shall be shouldered by the winning bidder.	
Field testing shall be made once the unit is ready for operation and when both the GSCWD and winning bidder have finished their scopes of work on the installed unit. GSCWD engineers shall conduct field testing with the presence of winning bidder's representative. In case the unit/units failed to pass the field testing, the winning bidder shall make necessary corrections / changes to replace the unit without cost to GSCWD.	
Two (2) sets of VFD Motor Controller shall be delivered within Thirty (30) calendar days upon receipt of Purchase Order (PO).	
The winning bidder shall be subjected to Liquidated Damages (LD) for each day of delay as provided by the IRR of RA 9184.	
That the winning bidder shall issue a warranty certificate of not less than one (1) year and the warranty shall start from the date of commissioning of the equipment.	



Republic of the Philippines GENERAL SANTOS CITY WATER DISTRICT (GSCWD)

GSCWD Bldg., E. Fernandez Street, Lagao, General Santos City Telephone No.: 552-3824/554-7231; Telefax No.: 553-4960 E-mail Address: gscwaterdistrict@yahoo.com

That the bidder must have an available qualified and trained technicians 24/7 in case of equipment failure.

Prepared by:

EDMUND L. BADAL, REE

TWG Member

JUDY LIM PASMAN TWG – Member

MICHAEL G. GABALES, REE

Recommending Approval:

ROGELIO A. BESANA JR. C.E./RMP

Manager A - Engineering & Const'n. Dept.

ARN B. GELLANGARIN, PME

General Manager A

Approval