



Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT
 E. Fernandez Street, Barangay Lagao General Santos
 Telephone No.: 552-3824; Telefax No.: 553-4960
 Email Address: gscwdprocurement@yahoo.com

GPM-014-2

REQUEST FOR QUOTATION

RFQ #: 3-0819-039 DATE: 8/19/2019

SUPPLIER: _____
 ADDRESS: _____
 TELEPHONE NO. : _____
 TIN NO. : _____

Dear Sir/Madam,

Pls. quote your lowest price on the item/s listed below subject to general condition stating the shortest time of delivery and submit your quotation duly signed by your representative not later than 8/23/2019, Pls. furnish this office the following articles subject to the terms and conditions contained therein.

ITEM NO.	DESCRIPTION	QTY.	UNIT	UNIT PRICE
1	D.I. GATEVALVE F/F 300MM (12``) : HOT DIP BOLTS, NUTS & WASHERS (10 YEARS WARRANTY)-ABC: PHP 66,500.00	1	pc	P
2	D.I. GATE VALVE 250MM F/F : HOT DIP BOLTS, NUTS & WASHERS (10 YEARS WARRANTY)-ABC: PHP 52,000.00	1	pcs.	P
3	D.I. AIR RELEASE VALVE 4`` : HOT DIP BOLTS, NUTS & WASHERS (10 YEARS WARRANTY)-ABC: PHP 200,000.00 ##### nothing follows #####	2	pc	P

Date of Delivery: _____
 Price Validity : _____
 Terms of Payment: _____



Place of Delivery: GSCWD Bodega

****No partial delivery allowed****

Note: 6% WITHHOLDING TAX DEDUCTION

PR NO.: 0719-090

Requested by:



 OFFICER A

Price quoted by:

 Supplier

 Date



Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT

GSCWD Bldg., E. Fernandez Street, Brgy. Lagao, General Santos City

Telephone No. 552-3824-554-7231; Telefax No.: 553-4960

E-mail Address: gscwaterdistrict@yahoo.com

TECHNICAL SPECIFICATION

DOUBLE ORIFICE AIR RELEASE VALVE



DIMENSION:

- DN 100mm.
- Flange Drilling is PN16.
- Weight is 51.70 kgs.

USE:

- For water (not sewage) and neutral liquid applications.
- Valve designed for use up to 70°C.
- Where applicable for AS 4020 compliance, max temp = 40°C.

FEATURES:

- Cylindrical large Orifice float.
- Embodied unique aerokinetic feature.
- Does not shut prematurely
- Release of large volumes of air during pipeline filling.
- Allows inflow of large volumes of air when pipe is emptied.
- Release of air under pressure.
- Low maintenance
- Streamlined air flow

COMPONENT LIST:

- | | |
|-----------------------|----------------------------------|
| • Cowl | : Ductile Iron, 500-7 to AS 1831 |
| • Cover | : Ductile Iron, 500-7 to AS 1831 |
| • Seat ring | : ABS |
| • Seat Support Ring | : ABS plastic |
| • Float | : ABS plastic |
| • Float Guide | : ABS plastic |
| • Body (low pressure) | : Ductile Iron, 500-7 to AS 1831 |
| • Screw | : 316 Stainless Steel |
| • Hexagon nut | : 316 Stainless Steel |
| • Orifice Cover | : Nylon |
| • Orifice bracket | : Nylon |

- Gasket : EPDM WBS listed
- Fulcrum pin : 316 Stainless Steel
- Adjusting Screw : 316 Stainless Steel
- Float : ABS plastic
- Float and lever : ABS plastic
- Body : Ductile Iron, 500-7 to AS 1831

Prepared by:



EL SIEGFRED D. ALIM
Senior Draftsman

Checked by:



ENGR. MICHAEL G. GABALES
Manager A - PDD

Noted by:



ENGR. ROGELIO A. BESANA, JR.
Manager A - ECD