



Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT
E. Fernandez Street, Barangay Lagao General Santos
Telephone No.: 552-3824; Telefax No.: 553-4960
Email Address: gscwdprocurement@yahoo.com

GPM-014-2

REQUEST FOR QUOTATION

RFQ #: 3-0821-020 DATE: 08/12/2021

SUPPLIER: _____
ADDRESS: _____
TELEPHONE NO. : _____
TIN NO. : _____

Dear Sir/Madam,

Pls. quote your lowest price on the item/s listed below subject to general condition stating the shortest time of delivery and submit your quotation duly signed by your representative not later than 08/18/2021, Pls. furnish this office the following articles subject to the terms and conditions contained therein.

ITEM NO.	DESCRIPTION	QTY.	UNIT	UNIT PRICE
1	DISTRIBUTION TRANSFORMER 75 KVA 240/480V : PLEASE SEE ATTACHED SPECIFICATION-ABC: 500,000.00 ##### nothing follows #####	3	unit	P

Date of Delivery: _____
Price Validity : _____
Terms of Payment: _____

Place of Delivery: GSCWD Bodega

*****No partial delivery allowed****

Note: 6% WITHHOLDING TAX DEDUCTION

PR NO.: 0521-049

Requested by:

GESEM R. CABERO
MATERIAL PROCUREMENT
OFFICER A

Price quoted by:

Supplier

Date



TECHNICAL SPECIFICATION

TITLE: Purchase of Pole Mounted Transformer

1.0 SCOPE OF CONTRACT

The scope shall be supply and delivery of three (3) units Pole Mounted Transformer to General Santos City Water District (GSCWD).

2.0 Transformer Specification

Particular	Requirements
Type	Pole mounted type
Mineral	oil Immerse / High Fire Point Fluid
Rated Power	75kVA Single Phase
No. of units	3 units
Primary Voltages	7620/13200 volts
Secondary Voltages	240/480 volts
Tap changer	External Tap Changer
Polarity	Additive Polarity
Bushing	Double Bushing



3.0 TERMS AND CONDITIONS

1. The scope of work shall be supply and delivery of Pole Mounted Transformer to General Santos City Water District (GSCWD).
2. The winning bidder is required to submit actual documents (data sheets, manufacturer's test results, and etc.) of the units.
3. In case the unit/units failed to pass the minimum requirements during commissioning, the winning bidder shall replace the unit/units without cost to GSCWD.
4. Power Utility company (Socoteco II) will conduct the insulation resistance test and resistance testing with the presence of the winning bidder and GSCWD engineers. The testing cost shall be shouldered by the winning bidder.
5. The winning bidder shall deliver the Pole Mounted Transformer within **Thirty (30)** calendar days upon receipt of Purchase Order (PO).
6. The winning bidder shall be subjected to Liquidated Damages (LD) for each day of delay as provided by the IRR of RA 9184.
7. That the winning bidder shall issue a warranty certificate of not less than one (1) year and the warranty shall commence from the date of commissioning of the pumping equipment.
8. That the bidder must have an available qualified and trained technicians 24/7 in case of unit/units failure.

Prepared by:


EDMUND L. BADAL, REE
TWG - Member



Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT (GSCWD)
GSCWD Bldg., E. Fernandez Street, Lagao, General Santos City
Telephone No.: 552-3824/554-7231; Telefax No.: 553-4960
E-mail Address: gscwaterdistrict@yahoo.com


MICHAEL G. GABALES, REE
TWG - HEAD

Recommending Approval:


ROGELIO A. BESANA JR. C.E./RMP
Assistant General Manager

Approval:


ARN B. GELLANGARIN, PME
General Manager A