



Republic of the Philippines  
GENERAL SANTOS CITY WATER DISTRICT  
E. Fernandez Street, Barangay Lagao General Santos  
Telephone No.: 552-3824; Telefax No.: 553-4960  
Email Address: gscwdprocurement@yahoo.com

GPM-014-2

### REQUEST FOR QUOTATION

RFQ #: 3-0919-053      DATE: 09/25/2019

SUPPLIER: \_\_\_\_\_  
ADDRESS: \_\_\_\_\_  
TELEPHONE NO. : \_\_\_\_\_  
TIN NO. : \_\_\_\_\_

Dear Sir/Madam,

Pls. quote your lowest price on the item/s listed below subject to general condition stating the shortest time of delivery and submit your quotation duly signed by your representative not later than 10/01/2019, Pls. furnish this office the following articles subject to the terms and conditions contained therein.

ITEM NO.	DESCRIPTION	QTY.	UNIT	UNIT PRICE
1	SOFT START/SOFT STOP (ELECTROMECHANICAL EQUIPMENT) : ONE SET 125HP MOTOR CONTROL PANEL SS/SS, 3PHASE-ABC: PHP 250,000.00 ##### nothing follows #####	1	unit	P

Date of Delivery: \_\_\_\_\_  
Price Validity : \_\_\_\_\_  
Terms of Payment: \_\_\_\_\_

Place of Delivery: GSCWD Bodega  
\*\*\*\*\*No partial delivery allowed\*\*\*\*  
Note: 6% WITHHOLDING TAX DEDUCTION  
PR NO.: 0919-046

Requested by:

Price quoted by:

CANCIA

\_\_\_\_\_  
Supplier

\_\_\_\_\_  
Date



## **TECHNICAL SPECIFICATION**

### **TITLE: PURCHASE OF ONE (1) SET BRAND NEW SOFT STARTER MOTOR CONTROLLER COMPLETES WITH ACCESSORIES**

#### **1.0 SCOPE OF CONTRACT**

The scope of work shall be supply, testing, delivery and commissioning of one (1) set Soft start/soft stop motor controller completes with accessories to General Santos City Water District (GSCWD).

#### **2.0 MOTOR CONTROLLER REQUIREMENTS**

##### **2.1 SOFT START/SOFT STOP CONTROLLER SPECIFICATIONS:**

1. Enclosure, Free Standing, IP55 ingress protection, gasketted with screened/louver ventilation with cable glands for supply power, motor supply and control cables.
2. Molded Case circuit breaker, 3 Pole, 200Amp, 480Vac minimum operating voltage with built in shunt trip coil @ 440Vac.
3. 3 phase Over/Under Voltage relay with phase rotation and delay 380vac – 500Vac.
4. 3 pole, MCB, 10Amp, 480Vac, dinrail mount. 2 pcs.
5. Transient Voltage surge suppressor(TVSS), 600Vac, 3 phase + N. 35Kaic with monitoring LED. Nema Standard.
6. 750VA, dry type transformer, 480Vac- 220Vac/110Vac, 1 phase, center tap.



7. Ventilation fan. Industrial type. 220Vac.
8. LED Lamp. 220Vac with door limit switch.
9. Illuminated push buttons, 220Vac, start, stop and reset.
10. Local and remote selector switch. 3 positions, maintained.
11. Liquid Level relay, hi and low for well application. 220Vac control voltage. Complete with liquid level relay probe.
12. Bypass Contactor. 3 pole. AC3 Category, 150amps. 220Vac control voltage with 2N.O and 2 N.C. auxiliary contacts.
13. Digital Softstarter with torque control system and softstop application. 3 phase, 200-500Vac voltage range(+30% tolerance), 125hp @ 480vac, heavy duty application. With provision for external bypass contactor control, external reset, external start stop. Complete protection against phase rotation, over/under voltage, thermal overcurrent, lock rotor, ground fault, under current, definite time overcurrent. Digital monitoring of voltage, current. PF, energy, kw and fault history included. With RS485 communication port.
14. Control wiring and power wiring design (cable type and rating included) shall be included for review with the proposal. Softstarter, Breakers, TVSS and Bypass contactor specs shall also be submitted along with the quotation.
15. Installation supervision and commissioning and training must be included in the offer.



### 3.0 DELIVERY TERMS AND CONDITIONS

- 5.1 The winning bidder shall deliver one (1) set Soft start/soft stop motor controller completes with accessories within **Ninety (30)** calendar days upon receipt of Purchase Order (PO).
- 5.2 The winning bidder shall be subjected to Liquidated Damages (LD) for each day of delay as provided by the IRR of RA 9184.

### 4.0 SPECIAL PROVISION

- 6.1 That the winning bidder shall issue a warranty certificate of not less than one (1) year and the warranty shall commence from the date of commissioning of the pumping equipment.
- 6.2 That the winning bidder shall provide technical manuals of the Soft start/soft stop motor controller to GSCWD and shall conduct technical orientation on standard operating procedures to the GSCWD representatives.
- 6.3 That the bidder must have an available qualified and trained technicians 24/7 in case of equipment failure.

Prepared by:

  
**EDMUND L. BADAL, REE**  
TWG – Member

Approval:

  
**ROGELIO A. BESANA JR. C.E./RMP**  
Manager A – Engineering & Const'n. Dept.