

Republic of the Philippines GENERAL SANTOS CITY WATER DISTRICT

E. Fernandez Street, Barangay Lagao General Santos Telephone No.: 552-3824; Telefax No.: 553-4960 Email Address: gscwdprocurement@yahoo.com

REQUEST FOR QUOTATION

RFQ #:3-0921-006

DATE: 09/10/2021

SUPPLIER: ADDRESS: TELEPHONE NO. : TIN NO. :				
stating the sh representative	e your lowest price on the item/s listed be nortest time of delivery and submit your not later than 09/16/2021, Pls. furnish terms and conditions contained therein.	elow suk r quotat this off	oject to ion dul ice the	general condition y signed by your following articles
ITEM NO.	DESCRIPTION	QTY.	UNIT	UNIT PRICE
1.	UPS : PLEASE SEE ATTACHED SPECIFICATION-ABC: PHP 500,000.00 ##############################	1	pc	P
Date of Delivery: Price Validity : Terms of Payment: Place of Delivery: *****No partial de Note: 6% WITHHOLDI PR NO.: 0821-058	livery allowed****			
Requested by:		Price q	uoted by:	
GESEM R. CABARES MATERIAL PROCUREME OFFICER A	RO NT			lier ate

Republic of the Philippines



GENERAL SANTOS CITY WATER DISTRICT (GSCWD)

GSCWD Bldg., E. Fernandez Street (Emergency Road), Lagao, General Santos City Telephone No.: 552-3824/554-7231; Telefax No.: 553-4960 E-mail Address: gscwaterdistrict@yahoo.com

TECHNICAL SPECIFICATION

TITLE:

PURCHASE OF ONE (1) BRANDED BRAND NEW SMART UPS

I. SCOPE OF CONTRACT

The scope of work shall be supply and delivery **ONE (1) BRANDED BRAND NEW SMART UPS** to General Santos City Water District.

II. TECHNICAL

FEATURES	SMART UPS		
MAX CONFIGURABLE POWER (WATTS)	10KVA		
INPUT VOLTAGE	220/230/240 VAC		
OUTPUT VOLTAGE	CONFIGURABLE FOR 200/230/240 NOMINAL OUTPUT VOLTAGE		
FORM FACTOR	RACK MOUNTED TYPE		
BATTERIES	VALVE REGULATED, NON-SPILLABLE, LED ACID		

III. TERMS AND CONDITIONS:

- 1. The supplier shall provide complete needed installation and latest software/firmware to have a working ONE (1) BRANDED BRAND NEW SMART UPS.
- 2. The supplier shall provide three (3) years warranty on equipment two (2) on battery and 2 years repair, replace and support.

Prepared by:

TECHNICAL WORKING GROUP FOR INFORMATION COMMUNICATION AND

TECHNOLOGY INFRASTRUCTURE GROUP

PHYLL PATRICK FRAGATA, CPE

TWG - Member

MICHAEL SABALES, REE

TWG - Head