



Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT
E. Fernandez Street, Barangay Lagao General Santos
Telephone No.: 552-3824; Telefax No.: 553-4960
Email Address: gscwdprocurement@yahoo.com

GPM-014-2

REQUEST FOR QUOTATION

RFQ #: 3-0921-051 DATE: 09/15/2021

SUPPLIER: _____
ADDRESS: _____
TELEPHONE NO. : _____
TIN NO. : _____

Dear Sir/Madam,

Pls. quote your lowest price on the item/s listed below subject to general condition stating the shortest time of delivery and submit your quotation duly signed by your representative not later than 09/21/2021, Pls. furnish this office the following articles subject to the terms and conditions contained therein.

ITEM NO.	DESCRIPTION	QTY.	UNIT	UNIT PRICE
1	CONSTRUCTION OF WAREHOUSE MEZZANINE : PLEASE SEE ATTACHED SHOP DRAWING-ABC: PHP 997,725.00 ##### nothing follows #####	1	LOT	P

Date of Delivery: _____
Price Validity : _____
Terms of Payment: _____


Place of Delivery: GSCWD Bodega

*****No partial delivery allowed****

Note: 6% WITHHOLDING TAX DEDUCTION

PR NO.: 0921-044

Requested by:


GESEM R. CABANERO
MATERIAL PROCUREMENT
OFFICER A

Price quoted by:

Supplier

Date



GENERAL SANTOS CITY WATER DISTRICT

E. Fernandez Street (Emergency Road, Lagao, General Santos City)
Telephone No. 552-3824-554-7231; Telefax No. : 553-4960
E-mail : gscwaterdistrict@yahoo.com

SCOPE OF WORK

Project Title: **CONSTRUCTION OF WAREHOUSE MEZZANINE**

Location: **Purok Udagre, Brgy. Conel, General Santos City**

The work consist of the following:

- 1) The work consist of supply of materials, labor, equipment, tools and supervision for the completion of the proposed project as shown on plan or technical drawings.
- 2) The Contractor shall inspect the site of the work in order to satisfy themselves by personal examination and/or by such other means as they may prefer, of the location of the proposed work and the visualization of the work to be done.
- 3) Cutting and removal of existing concrete pavement to give way for column foundation. The area around the proposed project as indicated, specified and shown in the plan for each particular site must be cleared of debris and other perishable or objectionable matter.
- 4) Excavation Works
 - a) Excavation shall include the removal of materials of whatever nature encountered that would interfere with the proper execution and completion of the work. All excavations shall be carried to the grade of the bottom of the concrete footing or as indicated on technical drawings.
- 5) Backfill
 - a) The materials excavated shall be place as backfill on the footing, etc. and above shall be compacted as described. Others excess will be hauled to a place designated by the Owner.
- 6) Concrete Works
 - a) Cement shall conform to the "Standard specifications for Portland Cement" and shall be type I. The cement shall be in accordance with DPWH standards and shall not be more than three (3) months from date of manufacture.
 - b) Concrete strength shall be 3,000 psi (20.68 Mpa) at 28 days to be used for concrete floor, wall footings, columns/pedestals and foundations.
 - c) Aggregates shall be well-graded, clean, hard particles of gravel or crushed rock.
 - d) All reinforcing steel bars used shall be of deformed type, new, free from rust, oil, defects, greases or kinks. They shall conform to the latest edition of National Structural Code for Buildings with minimum grade equal to 275 Mpa (Grade 40) unless otherwise shown in the plan.
 - e) Concrete forms should be water tight, strong enough and rigid to sustain the weight of concrete.
- 7) Steel Works
 - a) The Contractor shall furnish, fabricate and install metal works as specified herein and as shown in the plans. Miscellaneous metal works is defined as all items required to be fabricated from structural steel shapes, plates, bars and their products. The Contractor shall accomplish the work in a complete and finished manner and insure the highest quality of workmanship in accordance with the plan and specification.
 - b) Welding electrode shall conform to AWS ASI or A 5.5 E70 xx electrodes. Manufacturer's certification shall conform to this specification.
 - c) Bolt and nuts for main members shall be high strength bolts conforming to ASTM A-325 or its equivalent. Bolt shall be marked for that such kind of bolt. For secondary members ASTM A-307 bolts or its equivalent may be used. Care shall be taken so that different types of bolts do not get interchanged. All bolts shall be provided with plain washers.
 - d) Structural steel shall conform to the "Standard Specifications for Structural Steel" (ASTM Designation A-36). All materials to be provided and used by the contractor shall be new, previously unused, and in first class condition.

construction. Welding in Shop and field shall be done only by certified welders to perform the work required as shown in the approved drawings. Surfaces to be welded shall be free from the loosed side, rust, grease, paint and other foreign materials.

8) Painting Works

- a) The metal surfaces shall be clean, dry, and free from mill scale, rust, grease, oil, or any other substance that could affect the quality of the painting. It shall be well puttied and sand papered.
- b) All surfaces to be painted and, before beginning any work, shall be ensure that work of other trade has been left or installed in workmanlike condition to receive paint.
- c) Steel works to be encased in concrete shall not be painted. All other steel works shall be given one coat of shop paint of red oxide primer of high-quality brand applied thoroughly and evenly to dry surface, which have been cleaned by brush, spray roller coating, flow coating or dipping at the section of the fabricator.
- d) Each coat of paint shall be applied at proper consistency and brushed/rolled evenly, free of brush marks, sags, runs, and with no evidence of poor workmanship. No painting shall be done under conditions of weather, moisture, or temperature unsuited to good work, nor until previous coat is hard and dry.
- e) All steel work after complete erection shall be field painted (second coat) with the type and color specified in the section of painting of this specification. Paintings shall not be done on any steel surface that is not clean and dry.

9) All works shall be done in a safe manner to avoid unnecessary loss of life and damage to property.

10) Contractor shall provide safety equipment, gadgets, barricades, safety signboards, and other devices as necessary to prevent accident, damage or injury to the public.


11) A qualified superintendent shall be present in the work and shall provide competent supervision of the work until its completion.

12) The employees of the Contractor are not employees of the Owner. Hence, the Owner shall not be liable or responsible for any personal injury or damage including death cause by any of the employees of the Contractor during the lawful performances of their duties.

13) Liquidated Damages

- a) The Contractor shall pay liquidated damages to the Owner if he fails to complete the work within the time agreed upon. It is understood that said payment is not a penalty but a fixed sum representing the liquidated damages for each calendar day of delay. Computation of the said liquidated damages shall conform to the provision of RA 9184.

Prepared by:


ROLLY A. GUNDAY, CE
OIC – Planning & Design Division

Checked & Reviewed by:


ROGELIO A. BESANA, JR., CE/RMP
AGM, Operations & Technical Services

Approved by:


ARN B. GELLANGARIN, PME
General Manager A