



Republic of the Philippines  
**GENERAL SANTOS CITY WATER DISTRICT**  
E. Fernandez Street, Barangay Lagao General Santos  
Telephone No.: 552-3824; Telefax No.: 553-4960  
Email Address: gscwdprocurement@yahoo.com

GPM-014-2

**REQUEST FOR QUOTATION**

REQ #: 3-1020-001      DATE: 10/7/2020

SUPPLIER: \_\_\_\_\_  
ADDRESS: \_\_\_\_\_  
TELEPHONE NO. : \_\_\_\_\_  
TIN NO. : \_\_\_\_\_

Dear Sir/Madam,

Pls. quote your lowest price on the item/s listed below subject to general condition stating the shortest time of delivery and submit your quotation duly signed by your representative not later than 10/13/2020, Pls. furnish this office the following articles subject to the terms and conditions contained therein.

ITEM NO.	DESCRIPTION	QTY.	UNIT	UNIT PRICE
1	MAGNETIC CONTACTOR* : PLS. SEE ATTACHED SPECS. ABC Php74,000.00 ##### nothing follows #####	3	pc	P

Date of Delivery: \_\_\_\_\_  
Price Validity : \_\_\_\_\_  
Terms of Payment: \_\_\_\_\_

Place of Delivery: GSCWD Bodega

\*\*\*\*\*No partial delivery allowed\*\*\*\*

Note: 6% WITHHOLDING TAX DEDUCTION

PR NO.: 0820-032

Requested by:

  
**ANDREW H. NADAL JR.**  
Administration Services Assistant A

Price quoted by:

\_\_\_\_\_  
Supplier

\_\_\_\_\_  
Date



## TECHNICAL SPECIFICATION

### TITLE: PURCHASE OF ASSORTED SIZES OF MAGNETIC CONTACTOR

#### A.) MAGNETIC CONTACTOR OPERATING REQUIREMENTS

Particulars	Requirements
Number Of Unit	3
Motor Power Hp (UI)	100kW, 440V, 3P
Rated Operational Current	185A @440V, AC3
Rated Operational Voltage	690VAC, 3P, 50/60HZ
Control Circuit Voltage	220VAC, 50/60HZ
Auxiliary Contact	2NO + 2NC
Front Face	IP 20
Mounting Support	Plate / Rail
Breaking Capacity	1480A




## TERMS AND CONDITIONS

- 1.1 The supplier shall submit original catalogue or brochure.
- 1.2 The supplier shall submit a Certificate of Dealership/Distributorship from the Manufacturer.
- 1.3 The supplied Magnetic Contactor, including its accessories shall have one (1) year warranty against defects and the supplier shall provide a warranty certificate. Warranty period shall commence upon issuance of certificate of final acceptance.
- 1.4 The supplier shall provide a qualified technician to conduct the field testing and training of our personnel.

Prepared by:

  
**EDMUND L. BADAL, REE**  
TWG - Member

  
**DLUANIE R. ENERIO, ME**  
TWG - Member



Republic of the Philippines  
GENERAL SANTOS CITY WATER DISTRICT (GSCWD)  
GSCWD Bldg., E. Fernandez Street (Emergency Road), Lagao, General Santos City  
Telephone No.: 552-3824/554-7231; Telefax No.: 553-4960  
E-mail Address: gscwaterdistrict@yahoo.com

---

*Judy Lim Paskan*  
**JUDY LIM PASKAN**  
TWG – Member

*Michael G. Gables, Ree*  
**MICHAEL G. GABALES, REE**  
TWG – HEAD

Recommending Approval:

*Rogelio A. Besana Jr.*  
**ROGELIO A. BESANA JR. C.E./RMP**  
Manager A – Engineering & Const'n. Dept.

Approval:

*Arn B. Gellangarin*  
**ARN B. GELLANGARIN, PME**  
General Manager A