



Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT
E. Fernandez Street, Barangay Lagao General Santos
Telephone No.: 552-3824; Telefax No.: 553-4960
Email Address: gscwdprocurement@yahoo.com

GPM-014-2

REQUEST FOR QUOTATION

RFQ #: 3-1021-043 DATE: 10/12/2021

SUPPLIER: _____
ADDRESS: _____
TELEPHONE NO. : _____
TIN NO. : _____

Dear Sir/Madam,


Pls. quote your lowest price on the item/s listed below subject to general condition stating the shortest time of delivery and submit your quotation duly signed by your representative not later than 10/18/2021, Pls. furnish this office the following articles subject to the terms and conditions contained therein.

ITEM NO.	DESCRIPTION	QTY.	UNIT	UNIT PRICE
1	GENERATOR SET : PLEASE SEE ATTACHED SPECIFICATION-ABC: PHP 600,000.00 ##### nothing follows #####	1	unit	P

Date of Delivery: _____
Price Validity : _____
Terms of Payment: _____

Place of Delivery: GSCWD Bodega
*****No partial delivery allowed****
Note: 6% WITHHOLDING TAX DEDUCTION
PR NO.: 0821-062

Requested by:


GESEM R. CABAÑERO
MATERIAL PROCUREMENT
OFFICER A

Price quoted by:

Supplier

Date



TECHNICAL SPECIFICATION

TITLE: PURCHASE OF ONE (1) SET BRAND NEW SUPER SILENT TYPE 25 KVA SINGLE PHASE STANDBY POWERED GENERATING SET WITH AUTOMATIC TRANSFER SWITCH (ATS) AND COMPLETE ACCESSORIES

1.0 GENERAL SCOPE

The scope of work shall be supply, delivery, testing and commissioning of One (1) unit 25KVA Brand New Standby Super Silent type Power Generating Set with automatic transfer switch to General Santos City Water District.

2.0 GENERAL SPECIFICATIONS

Item	Technical Specification	Statement and Compliance
1	Four (4) cylinder, in-line, direct injection, electronic actuated governor, water radiator cooling system, electric starting. Self-exciting, self-regulating, IP23 Protection, Insulation Class H, Single bearing and with built in Automatic Voltage Regulator	
2	25 KVA Standby Rating, Single (1) Phase, 230 VAC, Super Silent Type, 60Hz, 1800 rpm, 1.0 Power Factor	
3	Digital with display of all parameters. Equipped with automatic shut-off sensors for engine low oil pressure high coolant temperature, overcrank, over/under speed and over/under frequency. Also equipped with EMERGENCY Push Button Shut-Off Switch	
4	One (1) year on parts and services or 1000 running hours whichever comes first under normal used and operating condition.	
5	Supply, delivery, installation, integration, testing and commissioning of Automatic Transfer Switch including batteries and accessories for 25KVA genset	



	which will be automatically activated during utility power outage.	
6	Supply, delivery, installation, testing and commissioning of needed power cable and accessories going to Centralized Operating Center	


3.0 ADDITIONAL REQUIREMENTS

The supplier shall also provide the following:

- a. One (1) complete set of special tools required for maintenance of generator set. Special tools are those which solely the manufacturer provides for special purposes, or otherwise, to reach inaccessible parts.
- b. Two (2) complete sets of filters (Air, Fuel, Water, & Lube) and shall be placed in a suitable storage box.
- c. One copy of Maintenance Manual listing routine maintenance procedures and troubleshooting guides listing possible breakdowns and repairs for the unit. Manual shall include factory service manuals, complete parts lists, simplified schematic diagrams of each system as installed, and originals from which posted instructions were made.

Prepared by:

TECHNICAL WORKING GROUP FOR INDUSTRIAL AND ELECTRICAL EQUIPMENT


EDMUND L. BADAL, REE
TWG - Member


MICHAEL G. GABALES, REE
TWG - HEAD

Recommending Approval:


FERDINAND S. FERRER, MPA
Assistant General Manager for Administration

Approval:


ARN B. GELLANGARIN, PME
General Manager