


CEMENT MORTAR COATED AND LINED SPIRAL WELDED STEEL PIPE, BELL & SLIP ON ENDS

DIAMETER			MIN. WALL THICKNESS t (min.)	EXPANDED END			CEMENT LINING	CEMENT COATING	EFFECTIVE PIPE LENGTH	QTY.	Unit
ND	OD	F I D		EE-ID	EE-OD	E					
300	335.56	300.00	4.78	338.56	348.12	76.20	13	25.40	6000.00	298	PCS.
200	221.56	200.00	4.78	224.56	234.12	76.20	6	25.40	6000.00	20	PCS.
150	171.56	150.00	4.78	174.56	184.12	76.20	6	25.40	6000.00	5	PCS.



DETAIL DRAWING

NOTE:
 ALL UNITS IN" mm" UNLESS OTHERWISE SPECIFIED
 CEMENT MORTAR LINING & COATING AS PER LWUA STANDARD
 PIPE MATERIAL: GRADE SS 400 B APPROVED EQUIVAENT.
 MANUFACTURING SPECS: ASTM A-139

<p>GENERAL SANTOS CITY WATER DISTRICT E. FERNANDEZ STREET, BRGY. LAGAO, GEN. SANTOS CITY ENGINEERING & CONSTRUCTION DEPARTMENT PLANNING AND DESIGN DIVISION TEL. NO.: (083) 552 - 3824</p>	PROJECT TITLE	CHECKED BY:	REVIEWED BY:	APPROVED BY:	CONTENT:	SHEET NO.
	PURCHASE OF ASSORTED SIZES OF CEMENT COATED AND CEMENT LINED SPIRAL WELDED STEEL PIPES	 ENGR. ROLLY A. GUNDA OFFICER-IN-CHARGE-PDD	 ENGR. ROGELIO A. BESANA, JR. MANAGER A - ECD	 ENGR. ARN B. GELLANGARIN GENERAL MANAGER	AS SHOWN DRAWN: NPR CHECKED: RAG REVISION: DATE: 07 / 08 / 2021	1