



## **TECHNICAL SPECIFICATION**

### **TITLE: PURCHASE OF BRAND NEW SUBMERSIBLE PUMP AND MOTOR, SUBMERSIBLE CABLE, AND VARIABLE FREQUENCY DRIVE MOTOR CONTROLLER WITH COMPLETE ACCESSORIES**

#### **1.0 SCOPE OF CONTRACT**

The scope shall be supply, testing, delivery and commissioning of brand new Submersible Pump and Motor, Submersible Cable, and Variable Frequency Drive Motor Controller with complete accessories to General Santos City Water District (GSCWD).

#### **2.0 SUBMERSIBLE PUMP OPERATING REQUIREMENTS**

<b>Particulars</b>	<b>Requirements</b>	<b>Statement of Compliance</b>
<b>Minimum Capacity at design Head, lps(gpm)</b>	<b>70 (1110)</b>	
<b>Design Head TDH, m(ft)</b>	<b>45(148)</b>	
<b>Size of Discharge pipe, mm (in)</b>	<b>150 (6)</b>	
<b>Minimum Pump Efficiency at design head, percent</b>	<b>72%</b>	
<b>Design Speed (RPM)</b>	<b>3400-3600</b>	



<b>Pump Valve Casing, Diffuser and Suction casing Type</b>	<b>316 Stainless Steel</b>	
<b>Impeller, Shaft Bearing</b>	<b>316 Stainless Steel - EPDM Rubber</b>	
<b>Pump Shaft</b>	<b>316 Stainless Steel</b>	
<b>Conical Valve, Suction Screen</b>	<b>316 Stainless Steel</b>	
<b>Flanged coupling Type</b>	<b>316 Stainless Steel</b>	
<b>Bowl Intermediate</b>	<b>316 Stainless Steel</b>	

### 3.0 SUBMERSIBLE MOTOR OPERATING REQUIREMENTS

<b>Particulars</b>	<b>Requirements</b>	<b>Statement of Compliance</b>
<b>Motor Power Rating HP</b>	<b>As Required</b>	
<b>Rated Voltage</b>	<b>460</b>	
<b>Phase</b>	<b>3</b>	
<b>Service Factor</b>	<b>1.15</b>	
<b>Power Factor(4/4)</b>	<b>0.8</b>	
<b>Design point</b>	<b>3400-3600RPM</b>	
<b>Winding</b>	<b>Encapsulated in anti-tracking resin (non-rewindable)</b>	
<b>Stator area</b>	<b>Hermetically-sealed</b>	
<b>Water-block lead</b>	<b>Removable connection</b>	
<b>Flange design</b>	<b>Double</b>	
<b>Shell</b>	<b>Stainless Steel</b>	
<b>Shaft</b>	<b>Splined stainless steel</b>	
<b>Thrust bearing</b>	<b>water lubricated</b>	



<b>Diaphragm</b>	<b>Pressure equalizing</b>	
<b>Slinger</b>	<b>Sand Fighter</b>	
<b>Lead wire configurations</b>	<b>3</b>	
<b>Bar rotor</b>	<b>Copper</b>	
<b>Minimum Motor Resistance (Mega ohms)</b>	<b>1000 for not spliced, not submerged</b>	

#### 4.0 Submersible cable requirements

<b>Particulars</b>	<b>Requirement</b>	<b>Statement of Compliance</b>
<b>Type</b>	<b>Round</b>	
<b>Size (mm<sup>2</sup>)</b>	<b>60</b>	
<b>Length (meters)</b>	<b>70</b>	
<b>No. of Leads</b>	<b>3</b>	
<b>Maximum Operating Temperature (°C)</b>	<b>75</b>	
<b>All Submersible Cables shall be PVC- insulated with PVC &amp; PE jacket</b>		

#### 4.1 Other materials used for splicing Submersible Cable

<b>Particulars</b>	<b>Requirements</b>	<b>Statement of Compliance</b>
<b>Shrinkable Termination Kit / Splicing Kit (Brand 3M)</b>	<b>Three (3) sets kit No.82-A2</b>	
<b>60mm<sup>2</sup> Butt Connector (pieces)</b>	<b>Six (6) pcs</b>	
<b>Rubber Tape (Brand 3M)</b>	<b>Six (6) rolls; with</b>	



	<b>ASTM D-4388 type 1,2&amp;3 / HH-I-3825B approval.</b>	
<b>Electrical Tape (Brand 3M)</b>	<b>Six (6) rolls ; Super 33+ Vinyl Electrical Tape</b>	
<b>Royal Cord (Philflex)</b>	<b>12AWG/3C - 100mtrs</b>	
<b>Electrodes (water level sensor)</b>	<b>Six (6) pcs</b>	

#### 5.0 Variable Frequency Drive Motor Controller Operating Requirement

<b>Particulars</b>	<b>Requirement</b>	<b>Statement of Compliance</b>
<b>Product or Component Type</b>	<b>Variable Frequency Drive</b>	
<b>Rated Power, Hp</b>	<b>One Step Higher On Computed Motor Power (Hp)</b>	
<b>AC Voltage Range</b>	<b>380v - 500v</b>	
<b>Voltage % Tolerance</b>	<b>+10% -15%</b>	
<b>Supply Number Of Phases</b>	<b>3 phases</b>	
<b>Prospective line Isc (kAIC rating)</b>	<b>50 kA</b>	
<b>Maximum Transient Current for 60 s</b>	<b>117A</b>	



<b>Maximum Inrush Current</b>	<b>176A</b>	
<b>Nominal Current</b>	<b>106A</b>	
<b>Acceleration-Deceleration Ramps</b>	<b>0.01 - 9999s</b>	
<b>Speed Output Frequency</b>	<b>0.1 - 599Hz</b>	
<b>Enclosure Rating</b>	<b>IP55</b>	
<b>Digital Variable Frequency Drive with torque control system, heavy duty application. Graphical terminal display, SCADA ready, built pumping control system and integrated EMC filter. With provision for external reset, external start stop, external speed control. Complete protection against phase rotation, over/under voltage, thermal overcurrent, lock rotor, ground fault, under current, definite time overcurrent. Digital monitoring of voltage, current, frequency, energy, kW and fault history included. With RS485 communication port.</b>		



### 5.1 Other Motor Controller Operating Requirements

Item No.	Requirements	Statement of Compliance
1	Enclosure, <b>FreeStanding</b> , IP55 ingress protection, gasketed with screened/louver ventilation and ventilation fan industrial type 220Vac, cable glands for supply power, motor supply and control cables.	
2	Molded Case circuit breaker, 3 Pole, 250Amp, 480Vac minimum operating voltage with built in shunt trip coil @ 440Vac.	
3	3 phase Over/Under Voltage relay with phase rotation and delay 380vac – 500Vac.	
4	3 pole, MCB, 10Amp, 480Vac, dinrail mount. (Two (2) pcs.)	
5	Transient Voltage surge suppressor (TVSS), 600Vac, 3 phase + N. 35Kaic with monitoring LED. <b>Nema Standard.</b>	
6	750VA dry type transformer, step down transformer 480Vac 220Vac/110Vac, 1 phase, center tap.	
7	LED Lamp. 220Vac with door limit switch.	
8	Illuminated push buttons, 220Vac, start, stop and reset.	
9	Local and remote selector switch. 3 positions, maintained.	
10	Liquid Level relay, high and low for well application and reservoir water level, stop at full tank and auto run at low water level. 220Vac control voltage. Must be wired interlock to the system and terminated to terminal block. (2 pcs) Complete with level relay probe.	



<b>11</b>	Control Panel must have installed <b>GSM SMS Alarm and Controller Unit</b> with one USB port, 2 relay Output, and 8 Digital Input. All digital input and relay output must be wired and terminated to terminal block.	
-----------	---	--

## 6.0 TERMS AND CONDITIONS

Item No.	Requirements	Statement of Compliance
1	The scope of work shall be supply, delivery and commissioning of brand new Submersible Pump and Motor, Submersible Cable and Variable Frequency Drive Motor Controller with complete accessories to General Santos City Water District (GSCWD).	
2	<b>OEM and locally assembled</b> submersible pump is not allowed.	
3	All bidders are required to submit and include documents but not limited to manuals, data sheets, and <b>Manufacturers Certificate</b> in there bidding documents.	
4	The winning bidder is required to submit actual documents but not limited to manuals, data sheets, manufacturer's Test Certificate (include serial number & model number/type), Manufacturer's Certificate, name plate specifications, of the unit that are to be tested prior to the scheduling of laboratory testing.	
5	The submersible pump and motor shall be tested in a laboratory before delivery to ensure conformance with the design parameters. The cost of the laboratory testing	



	shall be borne entirely by the winning bidder.	
6	Laboratory testing shall be witnessed by four (4) GSCWD representatives together with the winning bidder's representatives for three (3) days. All relevant and incidental cost (Testing fee, transportation, accommodation, allowances and etc.) in the testing of the equipment shall be shouldered by the winning bidder.	
7	In case the unit to be tested are different from the submitted documents and/or do not comply with the specifications set by GSCWD, laboratory testing shall not be conducted. The winning bidder shall make necessary adjustment to comply with the set specifications and re-schedule another laboratory testing without cost to GSCWD.	
8	In case the unit/units failed to pass the minimum requirements during laboratory testing, the winning bidder shall make appropriate adjustment to comply with the set specifications without cost to GSCWD.	
9	That during the installation and commissioning of the units, the winning bidder shall be required to send a technician responsible of Variable Frequency Drive set up and splicing the cables with the motor cable leads and commissioning thereafter with the presence of GSCWD technical representatives. <b>The insulation resistance of submersible motor reading must be greater than or equal to 1000 mega-ohms before splicing.</b> All relevant and incidental costs (transportation, accommodation, allowances and etc.) during commissioning of	






	the equipment shall be shouldered by the winning bidder.	
10	Electrical installation of main circuit breaker and grounding shall be performed by GSCWD technicians.	
11	<p>Field testing shall be made once the units are ready for operation and when both the GSCWD and winning bidder have finished their scopes of work on the installed units. GSCWD engineers shall conduct field testing with the presence of winning bidder's representative.</p> <p><b>A.)</b>Submersible Pump must meet the minimum requirements in terms of capacity, head, <b>and efficiency with tolerance of -2%.</b></p> <p><b>B.)</b> Submersible motor shall operate with in its rated current and shall not consumed the safety factor (115% of rated current).</p> <p><b>C.)</b>The motor controller shall operate and does not trip-off in normal condition. All external motor protections must properly interlock and functional.</p> <p>In case the unit/units failed to pass the field testing, the winning bidder shall make necessary corrections / changes or replace the unit/units without cost to GSCWD.</p>	
12	The winning bidder shall deliver the units within <b>Ninety (90)</b> calendar days upon receipt of Purchase Order (PO). Laboratory testing is included in the 90- calendar day's delivery period.	



13	The winning bidder shall be subjected to Liquidated Damages (LD) for each day of delay as provided by the IRR of RA 9184.	
14	The submersible motor and cable must comply with PEC standard as to their current rating.	
15	That the winning bidder shall issue a warranty certificate of not less than one (1) year and the warranty shall commence from the date of commissioning of the pumping equipment.	
16	That the winning bidder shall have an available qualified and trained technicians 24/7 in case of equipment failure.	

Prepared by:

  
**EDMUND L. BADAL, REE**  
TWG - Member

  
**JUDY LIM PASMÁN**  
TWG - Member

  
**MICHAEL G. CABALES, REE**  
TWG - HEAD

Recommending Approval:

  
**ROGELIO A. BESANA JR. C.E./RMP**  
Assistant General Manager

Approval:

  
**ARN B. GELLANGARIN, PME**  
General Manager A