GSCWD Bldg., E. Fernandez Street, Lagao, General Santos City Telephone No.: 552-3824/554-7231; Telefax No.: 553-4960 E-mail Address: gscwaterdistrict@yahoo.com

TECHNICAL SPECIFICATION

TITLE: PURCHASE OF BRAND NEW SUBMERSIBLE PUMP AND MOTOR, SUBMERSIBLE CABLE AND SOFT START SOFT STOP MOTOR CONTROLLER WITH COMPLETE ACCESSORIES

1.0 SCOPE OF CONTRACT

The scope shall be supply, testing, delivery and commissioning ofbrand new Submersible Pump and Motor, Submersible Cable and Soft Starter Motor Controller with complete accessories to General Santos City Water District (GSCWD).

2.0 SUBMERSIBLE PUMP OPERATING REQUIREMENTS

Particulars	Requirements	Statement of Compliance
Minimum Capacity at design Head, lps(gpm)	70 (1110)	
Design Head TDH, m(ft)	100(148)	
Size of Discharge pipe, mm (in)	150 (6)	
Minimum Pump Efficiency at design head, percent	72%	
Design Speed (RPM)	3400-3600	



GSCWD Bldg., E. Fernandez Street, Lagao, General Santos City Telephone No.: 552-3824/554-7231; Telefax No.: 553-4960 E-mail Address: gscwaterdistrict@yahoo.com

Pump Valve Casing, Diffuser and Suction casing Type	316 Stainless Steel	
Impeller, Shaft Bearing	316 Stainless Steel – EPDM Rubber	
Pump Shaft	316 Stainless Steel	
Conical Valve, Suction Screen	316 Stainless Steel	
Flanged coupling Type	316 Stainless Steel	
Bowl Intermediate	316 Stainless Steel	

3.0 SUBMERSIBLEMOTOR OPERATING REQUIREMENTS

Particulars	Requirements	Statement of Compliance
Motor Power Rating HP	As Required	
Rated Voltage	460	
Phase	3	
Service Factor	1.15	
Power Factor(4/4)	0.8	
Design point	3400-3600RPM	
Winding	Encapsulated in anti- tracking resin (non- rewindable)	
Stator area	Hermetically-sealed	
Water-block lead	Removable connection	
Flange design	Double	
Shell	Stainless Steel	
Shaft	Splined stainless steel	
Thrust bearing	water lubricated	

GENERAL SANTOS CITY WATER DISTRICT (GOCYTE GENERAL SANTOS CITY GENERAL SANTOS CITY (GOCYTE GENERAL SANTOS CITY GENERAL C

Diaphragm	Pressure equalizing	
Slinger	Sand Fighter	
Lead wire configurations	3	
Bar rotor	Copper	
Minimum Motor Resistance (Mega ohms)	1000 for not spliced, not submerged	

4.0 Submersible cable requirements

Particulars	Requirement	Statement of Compliance
Туре	Round	
Size (mm²)	100	
Length (meters)	90	
No. of Leads	3	
Maximum Operating Temperature (°C)	75	
All Submersible Cables s with PVC &		

4.1 Other materials used for splicing Submersible Cable

Particulars	Requirements	Statement of Compliance
Shrinkable Termination Kit / Splicing Kit (Brand 3M)	Three (3) sets kit No.82-A3	
100mm ² Butt Connector (pieces)	Six (6) pcs	

Rubber Tape (Brand 3M)	Six (6) rolls; with ASTM D-4388 type 1,2&3 / HH-I-3825B approval.	
Electrical Tape (Brand 3M)	Six (6) rolls ; Super 33+ Vinyl Electrical Tape	
Royal Cord (Philflex)	12AWG/3C - 100mtrs	
Electrodes (water level sensor)	Six (6) pcs	

5.0 Soft Start Soft Stop Motor Controller Operating Requirement

Particulars	Requirement	Statement of Compliance
Product or Component Type	Soft Stater Soft Stop	
Rated Power, Hp	One Step Higher On Computed Motor Power(Hp)	
AC Voltage Range	380v - 600v	
Voltage % Tolerance	+10% -15%	
Supply Number Of Phases	3 phases	
Short Circuit Current Rating (kAIC rating)	50 kA	

Limiting Current	Adjustment range: 150% to 700% of the nominal motor current	
Protection Class	Severe Duty Application	
Soft Start Current Rating	170A	
Acceleration- Ramps	Adjustment range: 1 to 60s	
application. With external start sto- phase rotation, overcurrent, lock current, definite monitoring of volt	op control system, heavy duty provision for external reset, p. Complete protection against over/under voltage, thermal crotor, ground fault, under time overcurrent. Digital age, current, frequency, energy, istory included. With RS485 ort.	

5.1 Other Motor Controller Operating Requirements

Item No.	Requirements	Statement of Compliance
1	Enclosure, Wall Mounted , IP55 ingress protection, gasketted with screened/louver ventilation and ventilation fan industrial type 220Vac, cable glands for supply power, motor supply and control cables.	

2	Molded Case circuit breaker, 3 Pole, 300Amp, 480Vac minimum operating voltage with built in shunt trip coil @ 440Vac.	
3	3 phase Over/Under Voltage relay with phase rotation and delay 380vac – 500Vac.	
4	3 pole, MCB, 10Amp, 480Vac, dinrail mount. (Two (2) pcs.)	
5	Transient Voltage surge suppressor (TVSS), 600Vac, 3 phase + N. 35Kaic with monitoring LED. NemaStandard .	
6	750VA, dry type transformer, 480Vac 220Vac/110Vac, 1 phase, center tap.	
7	LED Lamp. 220Vac with door limit switch.	
8	Illuminated push buttons, 220Vac, start, stop and reset.	
9	Local and remote selector switch. 3 positions, maintained.	
10	Liquid Level relay, high and low for well application and reservoir water level, stop at full tank and auto run at low water level. 220Vac control voltage. Must be wired interlock to the system and terminated to terminal block. (2 pcs) Complete with level relay probe.	
11	Control Panel must have installed GSM SMS Alarm and Controller Unit withone USB port, 2 relay Output, and 8 Digital Input. All digital input and relay output must be wired and terminated to terminal block.	



6.0 TERMS AND CONDITIONS

Item No.	Requirements	Statement of Compliance
1	The scope of work shall be supply, delivery and commissioning of brand new Submersible Pump and Motor, Submersible Cable and Variable Frequency Drive Motor Controller with complete accessories to General Santos City Water District (GSCWD).	
2	OEM and locally assembled submersible pump is not allowed.	
3	All bidders are required to submit and include documents but not limited to manuals, data sheets, and Manufacturers Certificate in there bidding documents.	
4	The winning bidder is required to submit actual documents but not limited to manuals, data sheets, manufacturer's Test Certificate (include serial number & model number/type), Manufacturer's Certificate, name plate specifications, of the unit that are to be tested prior to the scheduling of laboratory testing.	
5	The submersible pump and motor shall be tested in a laboratory before delivery to ensure conformance with the design parameters. The cost of the laboratory testing shall be borne entirely by the winning bidder.	

Republic of the General Santos City Water District (Godwing General Santos City Telephone No.: 552-3824/554-7231; Telefax No.: 553-4960 E-mail Address: gscwaterdistrict@yahoo.com

Laboratory testing shall be witnessed by four (4) GSCWD representatives together with the winning bidder's representatives for three (3) days. All relevant and incidental cost (Testing fee, transportation, accommodation, allowances and etc.) in the testing of the equipment shall be shouldered by the winning bidder.	
In case the unit to be tested are different from the submitted documents and/or do not comply with the specifications set by GSCWD, laboratory testing shall not be conducted. The winning bidder shall make necessary adjustment to comply with the set specifications and re-schedule another laboratory testing without cost to GSCWD.	
In case the unit/units failed to pass the minimum requirements during laboratory testing, the winning bidder shall make appropriate adjustment to comply with the set specifications without cost to GSCWD.	
That during the installation and commissioning of the units, the winning bidder shall be required to send a technician responsible of Variable Frequency Drive set up and splicing the cables with the motor cable leads and commissioning thereafter with the presence of GSCWD technical representatives. The insulation resistance of submersible motor reading must be greater than or equal to 1000 mega-ohms before splicing. All relevant and incidental costs (transportation, accommodation, allowances and etc.) during commissioning of	
	(4) GSCWD representatives together with the winning bidder's representatives for three (3) days. All relevant and incidental cost (Testing fee, transportation, accommodation, allowances and etc.) in the testing of the equipment shall be shouldered by the winning bidder. In case the unit to be tested are different from the submitted documents and/or do not comply with the specifications set by GSCWD, laboratory testing shall not be conducted. The winning bidder shall make necessary adjustment to comply with the set specifications and re-schedule another laboratory testing without cost to GSCWD. In case the unit/units failed to pass the minimum requirements during laboratory testing, the winning bidder shall make appropriate adjustment to comply with the set specifications without cost to GSCWD. That during the installation and commissioning of the units, the winning bidder shall be required to send a technician responsible of Variable Frequency Drive set up and splicing the cables with the motor cable leads and commissioning thereafter with the presence of GSCWD technical representatives. The insulation resistance of submersible motor reading must be greater than or equal to 1000 mega-ohms before splicing. All relevant and incidental costs (transportation, accommodation,

	winning bidder.	
10	Electrical installation of main circuit breaker and grounding shall be performed by GSCWD technicians.	
11	Field testing shall be made once the units are ready for operation and when both the GSCWD and winning bidder have finished their scopes of work on the installed units. GSCWD engineers shall conduct field testing with the presence of winning bidder's representative. A.)Submersible Pump must meet the minimum requirements in terms of capacity, head, and efficiency with tolerance of -2%. B.) Submersible motor shall operate with in its rated current and shall not consumed the safety factor (115% of rated current). C.)The motor controller shall operate and does not trip-off in normal condition. All external motor protections must properly interlock and functional. In case the unit/units failed to pass the field testing, the winning bidder shall make necessary corrections / changes or replace the unit/units without cost to GSCWD.	
12	The winning bidder shall deliver the units within Ninety (90) calendar days upon receipt of Purchase Order (PO). Laboratory testing is included in the 90- calendar day's delivery period.	

Republic of the Philippines





GENERAL SANTOS CITY WATER DISTRICT (GSCT)

GENERAL SANTOS CITY WATER DISTRICT (GSCT)

GSCWD Bldg., E. Fernandez Street, Lagao, General Santos City

Telephone No.: 552-3824/554-7231; Telefax No.: 553-4960

E-mail Address: gscwaterdistrict@yahoo.com

13	The winning bidder shall be subjected to Liquidated Damages (LD) for each day of delay as provided by the IRR of RA 9184.	
14	The submersible motor and cable must comply with PEC standard as to their current rating.	
15	That the winning bidder shall issue a warranty certificate of not less than one (1) year and the warranty shall commence from the date of commissioning of the pumping equipment.	
16	That the winning bidder shall have an available qualified and trained technicians 24/7 in case of equipment failure.	

Prepared by:

EDMUNDIX BADAL, REE

JUDY LIM PASMAN TWG - Member

Approval:

GABALES, REE

Recommending Approval:

ROGELIO A. BESANA JR. C.E./RMP

Assistant General Manager

ARN B. GELLANGARIN, PME

General Manager A