



PRELIMINARY WELL DESIGN

WELL NO. 26
 RESERVOIR SITE, BRGY. SINAWAL,
 GENERAL SANTOS CITY

WELL DATA:

DEPTH : 180 m
 TARGET CAP. : 70 LPS
 BLANK CASING : 400mmØ and 300mmØ
 WELL SCREEN : 300mmØ

NOTE:

1. ALL CASING AND SCREEN JOINTS ARE WELDED.
2. ALL LENGTHS ARE APPROXIMATE.
3. FINAL WELL DESIGN DEPEND ON THE RESULT OF ELECTRIC LOGGING.



GENERAL SANTOS CITY WATER DISTRICT
 E. FERNANDEZ ST., BRGY. LAGAO
 GENERAL SANTOS CITY

PREPARED BY:

Maria Celia N. Dandan
ENGR. MARIA CELIA N. DANDAN
 OIC - Planning & Design Division

CHECKED AND REVIEWED BY:

Rogelio A. Besana, Jr.
ENGR. ROGELIO A. BESANA, JR.
 AGM - Operations & Technical Services

APPROVED BY:

Arn B. Gellangarin
ENGR. ARN B. GELLANGARIN
 General Manager