



Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT
 E. Fernandez St., Brgy. Lagao, General Santos City
 Telephone No. (083) 552-3824/ Telefax No. (083) 553-4960
 E-mail Address: gscwaterdistrict@yahoo.com
www.gensanwater.gov.ph

SUPPLEMENTAL/BID BULLETIN

Clarification No. 2 Series of 2022

September 6, 2022

For purposes of clarification, the following is the response to the query of the prospective bidder in the recently conducted during the Pre-bid Conference of **Project 2022-30: Purchase of Supervisory Control And Data Acquisition (SCADA) System for Three (3) Pumping Stations and One (1) Reservoir for General Santos City Water District.**


| Clarification | TWG Response |
|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <p>“Sa additional requirements (Technical Specifications)... kailangan po ba kaming magbigay / mag-attach ng certificates?</p> <p>Halimbawa po on After Sales Service - ISO Certificates</p> <p>Bidders Qualification – Bidder must have a Regional Presence or Regional Service/ Support Partner/Center within Mindanao.</p> <p>After Sales Service - Contractor shall have 24/7 availability of technicians within Mindanao Island.</p> <p>Accepted nyo ba [ang] Remote Troubleshooting [in] real time?</p> | <p>Attachments must be provided as proof of compliance to the Technical Specifications.</p> <p>Bidders must provide certifications from the manufacturer for the listed After Sales Service requirements.</p> <p>Bidder must certify that they have an existing office within Mindanao.</p> <p>Bidder must have certify that they have an affiliated / partner company in Mindanao. Since SCADA is an automated system, the GSCWD has to ensure a 24/7 technical support to prevent operations delay.</p> <p>The GSCWD denies the suggestion.</p> |
| <p>Site Inspection</p> | <p>The BAC Secretariat will assist for scheduling of the Site Inspection.</p> <p>Bidder must provide a certificate of site inspection duly signed as proof of site visit.</p> |
| <p>ISO Certificates</p> | <p>Bidder may submit either of the certificates: ISO 9001:2015 Certificate of the Manufacturer and Local Distributor (Supplier) for all components (SCADA System, PLC and Sensors) or ISO 27001 Certificate from</p> |



Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT
E. Fernandez St., Brgy. Lagao, General Santos City
Telephone No. (083) 552-3824/ Telefax No. (083) 553-4960
E-mail Address: gscwaterdistrict@yahoo.com
www.gensanwater.gov.ph

| | |
|------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------|
| | the manufacturer (information security management system). |
| “Magshare po ba ng details and inventory of existing devices na i-integrate?” | Yes. Existing devices such as generators, soft starters, flowmeters, and fault monitoring devices, shall be shared during the site visit. |
| “How about for the softstarters? Are those units available for communication protocol? Such as Profibus, Modbus etc.?” | Yes. The soft starters communication is available. |
| “Good afternoon po. Yung sa for addendum po, separate po ba ang budget dun or kasama po sa ABC?” | Yes. The amendment is included in the ABC. |
| “Any specific country of origin for the major materials?” | None. |

For your information and guidance.


Ferdinand S. Ferrer MPA
BAC Chairperson

Received by the Bidder:

Date: _____