



SUPPLEMENTAL/BID BULLETIN

Addendum No. 8 Series of 2023


October 18, 2023

This Addendum No. 8 s. 2023 is issued to modify or amend items. This shall form as an integral part of the Bid Documents for **Project 2023-12: Purchase of Assorted Sizes uPVC Pipes Series 8 & Series 10, Fixed Seal** for General Santos City Water District.

Amendment in the Section VII. Technical Specifications

From	To
3. d. Joints Joints shall be used for sizes 63mm up to 225mm to be Machine installed Integral Fixed Seal. The seal should be glass reinforced polypropylene (PP) homogenously bonded to highly flexible EPDM Rubber.	3. d. Joints Joints shall be used for sizes 110mm up to 225mm to be Machine installed Integral Fixed Seal. The seal should be glass reinforced polypropylene (PP) homogenously bonded to highly flexible EPDM Rubber.

For guidance and information of all concerned.


Engr. Rogelio A. Besana, Jr.
BAC Chairperson

Received by the Bidder:

Date: _____