



## **TECHNICAL SPECIFICATION**

### **TITLE: PURCHASE OF BRAND NEW SUBMERSIBLE PUMPS AND MOTOR COUPLED WITH SUBMERSIBLE CABLE**

#### **1.0 SCOPE OF CONTRACT**

The scope shall be supply, testing, delivery and commissioning of two (2) brand new Submersible Pumps, and one (1) Submersible Motor Coupled with Submersible Cable to General Santos City Water District (GSCWD).

#### **2.0 SUBMERSIBLE PUMP OPERATING REQUIREMENTS**

<b>Particulars</b>	<b>Requirements</b>	<b>Statement of Compliance</b>
<b>No. of Units</b>	<b>2</b>	
<b>Minimum Capacity at design Head, lps(gpm)</b>	<b>70 (1100)</b>	
<b>Design Head TDH, m(ft)</b>	<b>54(177)</b>	
<b>Size of Discharge pipe, mm (in)</b>	<b>150 (6)</b>	
<b>Minimum Pump Efficiency at design head, percent</b>	<b>72%</b>	
<b>Design Speed (RPM)</b>	<b>3400-3600</b>	
<b>Pump Valve Casing, Diffuser and Suction casing Type</b>	<b>304 Stainless Steel</b>	



<b>Impeller, Shaft Bearing</b>	<b>304 Stainless Steel – EPDM Rubber</b>	
<b>Pump Shaft</b>	<b>304 Stainless Steel</b>	
<b>Conical Valve, Suction Screen</b>	<b>304 Stainless Steel</b>	
<b>Flanged coupling Type</b>	<b>304 Stainless Steel</b>	
<b>Bowl Intermediate</b>	<b>304 Stainless Steel</b>	

### 3.0 SUBMERSIBLE MOTOR OPERATING REQUIREMENTS

<b>Particulars</b>	<b>Requirements</b>	<b>Statement of Compliance</b>
<b>No. of Unit</b>	<b>1</b>	
<b>Motor Power Rating HP</b>	<b>75</b>	
<b>Rated Voltage</b>	<b>460</b>	
<b>Phase</b>	<b>3</b>	
<b>Service Factor</b>	<b>1.15</b>	
<b>Power Factor(4/4)</b>	<b>0.8</b>	
<b>Design point</b>	<b>3400-3600RPM</b>	
<b>Winding</b>	<b>Encapsulated in anti-tracking resin (non-rewindable)</b>	
<b>Stator area</b>	<b>Hermetically-sealed</b>	
<b>Water-block lead</b>	<b>Removable connection</b>	
<b>Flange design</b>	<b>Double</b>	
<b>Shell</b>	<b>Stainless Steel</b>	



Shaft	Splined stainless steel	
Thrust bearing	water lubricated	
Diaphragm	Pressure equalizing	
Slinger	Sand Fighter	
Lead wire configurations	3	
Bar rotor	Copper	
Minimum Motor Resistance (Mega ohms)	1000 for not spliced, not submerged	

#### 4.0 Submersible cable requirements

Particulars	Requirement	Statement of Compliance
Type	Round	
Size (mm <sup>2</sup> )	60	
Length (meters)	90	
No. of Leads	3	
Maximum Operating Temperature (°C)	75	
All Submersible Cables shall be PVC- insulated with PVC & PE jacket		



#### 4.1 Other materials used for splicing Submersible Cable

Particulars	Requirements	Statement of Compliance
Shrinkable Termination Kit / Splicing Kit (Brand 3M)	Three (3) sets kit No.82-A2	
60mm <sup>2</sup> Butt Connector (pieces)	Six (6) pcs	
Rubber Tape (Brand 3M)	Six (6) rolls; with ASTM D-4388 type 1,2 &3 / HH-I-3825B approval.	
Electrical Tape (Brand 3M)	Six (6) rolls ; Super 33+ Vinyl Electrical Tape	
Royal Cord (Philflex)	12AWG/3C – 100mtrs	
Electrodes (water level sensor)	Six (6) pcs	

#### 5.0 TERMS AND CONDITIONS

Item No.	Requirements	Statement of Compliance
1	The scope of work shall be supply, delivery and commissioning of brand new Submersible Pump and Motor Coupled with Submersible Cable to General Santos City Water District (GSCWD).	
2	<b>OEM</b> and <b>locally assembled</b> submersible pump shall not be allowed. The serial number, manufacturer's logo and Manufacturers name shall be engraved on the submersible pump surface.	



<b>3</b>	All bidders are required to submit and include documents but not limited to manuals, data sheets, and <b>Manufacturers Certificate</b> in there bidding documents.
<b>4</b>	The winning bidder is required to submit actual documents but not limited to manuals, data sheets, manufacturer's Test Certificate (include serial number & model number/type), Manufacturer's Certificate, name plate specifications, of the unit that are to be tested prior to the scheduling of laboratory testing.
<b>5</b>	The submersible pump and motor shall be tested in a laboratory before delivery to ensure conformance with the design parameters. The cost of the laboratory testing shall be borne entirely by the winning bidder.
<b>6</b>	Laboratory testing shall be witnessed by three (3) GSCWD representatives together with the winning bidder's representatives for three (3) days. All relevant and incidental cost (Testing fee, transportation, accommodation, allowances and etc.) in the testing of the equipment shall be shouldered by the winning bidder.
<b>7</b>	In case the unit to be tested are different from the submitted documents and/or do not comply with the specifications set by GSCWD, laboratory testing shall not be conducted. The winning bidder shall make necessary adjustment to comply with the set specifications and re-schedule another laboratory testing without cost to GSCWD.
<b>8</b>	In case the unit/units failed to pass the minimum requirements during laboratory testing, the winning bidder shall make appropriate adjustment to comply with the set specifications without cost to GSCWD during field testing.
<b>9</b>	That during the installation and commissioning of the units, the winning bidder shall be required to



	<p>send a technician responsible of splicing the cables with the motor cable leads and commissioning thereafter with the presence of GSCWD technical representatives. <b>The insulation resistance of submersible motor reading must be greater than or equal to 1000 mega-ohms before splicing.</b> All relevant and incidental costs (transportation, accommodation, allowances and etc.) during commissioning of the equipment shall be shouldered by the winning bidder.</p>	
<b>10</b>	<p>Field testing shall be made once the units are ready for operation and when both the GSCWD and winning bidder have finished their scopes of work on the installed units. GSCWD engineers shall conduct field testing with the presence of winning bidder's representative.</p> <p><b>A.)</b> Submersible Pump must meet the minimum requirements in terms of capacity, head, <b>and efficiency with tolerance of -2%.</b></p> <p><b>B.)</b> Submersible motor shall operate with in its rated current and shall not consumed the safety factor (115% of rated current)</p> <p>In case the unit/units failed to pass the field testing, the winning bidder shall make necessary corrections / changes to replace the unit/units without cost to GSCWD.</p>	
<b>11</b>	<p>The winning bidder shall deliver the units within <b>one hundred twenty (120)</b> calendar days upon receipt of Purchase Order (PO). Laboratory testing is included in the 120- calendar day's delivery period.</p>	
<b>12</b>	<p>The winning bidder shall be subjected to Liquidated Damages (LD) for each day of delay as provided by the IRR of RA 9184.</p>	
<b>13</b>	<p>The submersible motor and cable must comply with PEC standard as to their current rating.</p>	



14	That the winning bidder shall issue a warranty certificate of not less than two (2) years and the warranty shall commence from the date of commissioning of the pumping equipment.	
15	That the winning bidder shall have an available qualified and trained technicians 24/7 in case of equipment failure.	

Prepared by:

  
**EDMUND L. BADAL, REE**  
TWG - Member

  
**MICHAEL G. GABALES, REE**  
TWG - HEAD

Recommending Approval:

  
**ROGELIO A. BESANA JR., CE, RMP**  
AGM- Operation and Technical Services

Approval:

  
**FRANCISCO R. ALOLOD, JR., CPA, CESE**  
Acting General Manager