



TECHNICAL SPECIFICATION

TITLE: PURCHASE OF ASSORTED SUBMERSIBLE CABLE

1.0 SCOPE OF CONTRACT

The scope shall be supply and delivery of one (1) set brand new Submersible Cable to General Santos City Water District (GSCWD).

2.0 Submersible cable requirements

Particulars	Requirement	Statement of Compliance
Type	Round	
Size (mm²)	100	
Length (meters)	100	
No. of Leads	3	
Maximum Operating Temperature (°C)	75	
Submersible Cables shall be PVC-insulated with PVC & PE jacket		

3.0 TERMS AND CONDITIONS

1. The scope of work shall be supply and delivery of One (1) sets brand new Submersible Cable to General Santos City Water District (GSCWD).
2. The winning bidder is required to submit actual documents (manuals, data sheets, manufacturer's test results, name plate Specifications and etc.)
3. The winning bidder shall deliver the submersible cable within Sixty (60) calendar days upon receipt of Purchase Order (PO).
4. The winning bidder shall be subjected to Liquidated Damages (LD) for each day of delay as provided by the IRR of RA 9184.
5. The submersible cable must comply with PEC standard as to their current rating.



Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT (GSCWD)
GSCWD Bldg., E. Fernandez Street, Lagao, General Santos City
Telephone No.: 552-3824/554-7231; Telefax No.: 553-4960
E-mail Address: gscwaterdistrict@yahoo.com

-
6. That the winning bidder shall issue a warranty certificate of not less than one (1) year.

Prepared by:


EDMUND L. BADAL, REE
TWG - Member


~~MICHAEL G. CABALES, REE~~
~~TWG HEAD~~

Recommending Approval:


ROGELIO A. BESANA JR., CE, RMP
AGM- Operation and Technical Services

Approval:


FRANCISCO R. ALOLOD, JR., CPA, CESE
Acting General Manager