



TECHNICAL SPECIFICATION

TITLE: PURCHASE OF VARIABLE FREQUENCY DRIVE MOTOR CONTROLLER WITH COMPLETE ACCESSORIES AND FREE STANDING ENCLOSURE

1.0 SCOPE OF CONTRACT

The scope shall be supply and delivery of brand new Variable Frequency Drive Motor Controller with complete accessories and free standing enclosure to General Santos City Water District (GSCWD).

2.0 Variable Frequency Drive Motor Controller Operating Requirement

Particulars	Requirement	Statement of Compliance
Product or Component Type	Variable Frequency Drive	
Motor power, Hp (Kw)	150 (110)	
No. of units	1	
AC Voltage Range	380v – 500v	
Voltage % Tolerance	+10% -15%	
Total Harmonic Current Distortion (THDi)	<3%	
Supply Number Of Phases	3 phases	
Efficiency at Nominal Power	98%	
Power Factor:	Unity	



Prospective line Isc (kAIC rating)	65 kA
Nominal Current	180A
Acceleration-Deceleration Ramps	0.01 – 9999s
Speed Output Frequency	0.1 - 599Hz
Enclosure Rating	IP55
Digital Variable Frequency Drive with torque control system, heavy duty application. Graphical terminal display, SCADA ready, built pumping control system and integrated EMC filter. With provision for external reset, external start stop, external speed control. Complete protection against phase rotation, over/under voltage, thermal overcurrent, lock rotor, ground fault, under current, definite time overcurrent. Digital monitoring of voltage, current, frequency, energy, kW and fault history included.	
Voltage boost & Powerloss Ride-Through	
Built-in Active Harmonics Filter	
With RS485 communication port.	
Local Control Panel with Mobilephone Bluetooth connectivity.	

3.0 Other Motor Controller Operating Requirements

Item No.	Requirements	Statement of Compliance
1	Enclosure, Free Standing , IP42 ingress protection, gasketed with screened/louver ventilation and ventilation fan industrial type 220Vac, cable glands for supply power, motor supply and control cables.	
2	Molded Case circuit breaker, 3 Pole, 300Amp, 480Vac minimum operating voltage with built in shunt trip coil @ 440Vac.	
3	3 phase Over/Under Voltage relay with phase rotation and delay 380vac – 500Vac.	
4	3 pole, MCB, 10Amp, 480Vac, dinrail mount. (Two (2) pcs.)	
5	Transient Voltage surge suppressor (TVSS), 600Vac, 3 phase + N. 35Kaic with monitoring LED. Nema Standard.	



6	Dry type transformer, 480Vac to 220Vac/110Vac, 1 phase, center tap.	
7	LED Lamp. 220Vac with door limit switch.	
8	Illuminated push buttons, 220Vac, start, stop and reset.	
9	Local and remote selector switch. 3 positions, maintained.	
10	Liquid Level relay, high and low for well application and reservoir water level, stop at full tank and auto run at low water level. Also with a water level controller that regulates motor speed based on the water level in the reservoir. The motor speed decreases from 60 Hz to 40 Hz as the water level rises. If the water level falls below the point corresponding to 40 Hz, the motor stops.	
11	Control Panel must have installed GSM SMS Alarm and Controller Unit with one USB port, 2 relay Output, and 8 Digital Input. All digital input and relay output must be wired and terminated to terminal block.	

4.0 TERMS AND CONDITIONS

Item No.	Requirements	Statement of Compliance
1	The scope of work shall be supply and delivery of Variable Frequency Drive Motor Controller to General Santos City Water District (GSCWD).	
2	All bidder is required to submit and include documents but not limited to manuals, data sheets, and Manufacturers Certificate in there bidding documents.	
3	Field testing shall be made once the units are ready for operation and when both the GSCWD and winning bidder have finished their scopes of work on the installed units. GSCWD engineers shall conduct field testing with the presence of winning bidder's representative.	
4	The winning bidder shall deliver the units within Ninety (90) calendar days upon receipt of Purchase Order (PO).	



Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT (GSCWD)
GSCWD Bldg., E. Fernandez Street, Lagao, General Santos City
Telephone No.: 552-3824/554-7231; Telefax No.: 553-4960
E-mail Address: gscwaterdistrict@yahoo.com

5	The winning bidder shall be subjected to Liquidated Damages (LD) for each day of delay as provided by the IRR of RA 9184.	
6	That the winning bidder shall issue a warranty certificate of not less than one (1) year and the warranty shall commence from the date of commissioning of the pumping equipment.	
7	That the winning bidder shall have an available qualified and trained technicians 24/7 with in Mindanao area in case of equipment failure.	

Prepared by:


EDMUND L. BADAL, REE

TWG - Member


MICHAEL G. CABALES, REE

TWG - HEAD

Recommending Approval:


ROGELIO A. BESANA JR. C.E./RMP

Assistant General Manager

Approval:


FRANCISCO R. ALOLOD, JR., CPA, CESE

Acting General Manager