

Republic of the Philippines GENERAL SANTOS CITY WATER DISTRICT

E. Fernandez St., Brgy. Lagao, General Santos City Telephone No.: 552-3824; Telefax No.: 553-4960 Email Address: gscwaterdistrict@yahoo.com

SUPPLEMENTAL/BID BULLETIN

Addendum No. 03 Series of 2025

January 10, 2025

This Addendum No. 03 is issued to modify or amend items. This shall form as an integral part of the Bid Documents for Project 2025-17 (EPA): Purchase of Assorted Pipes and Fittings Through Framework Agreement.

Amendment Section VII. Technical Specification	From	То
Lot 1: Brass Fittings	Fittings shall have a composition of 85% Copper, 5% Tin, 5% Lead, and 5% Zinc, corresponding to UNS C83600 and conforming to the requirements of the American Society for Testing and Materials (ASTM) B584, and must be tested at the Metals Industry Research and Development Center (MIRDC) with certificate to verify compliance, and should be done prior to delivery.	Fittings shall have a composition of 62-67% Copper, 3.5-4.5% Tin, 3.0-5.0% Lead, 3.0-9.0 Zinc, corresponding to UNSC97600 and conforming to the requirements of the American Society for Testing and Materials (ASTM) B584, and must be tested at the Metals Industry Research and Development Center (MIRDC) with certificate to verify compliance, and should be done prior to delivery.

For guidance and information of all concerned.

	Checo Xxxx
	FERDINAND S. FERRER, MPA
88	BAC Chairperson
	Received by the Bidder:
	Date: