



Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT
E. Fernandez St., Brgy. Lagao, General Santos City
Telephone No.: 552-3824; Telefax No.: 553-4960
Email Address: gscwaterdistrict@yahoo.com

GPM-034-2

SUPPLEMENTAL/BID BULLETIN


Addendum No. 02
Series of 2025

January 10, 2025

This Addendum No. 02 is issued to modify or amend items. This shall form as an integral part of the Bid Documents for **Project 2025-17 (EPA): Purchase of Assorted Pipes and Fittings Through Framework Agreement.**

Amendment Section VII. Technical Specification	From	To
Scope of Work	3. All bidders are required to submit documents including, but not limited to, manuals, data sheets, and a Manufacturer's Authorization Certificate (ISO 9001 and 14001).	3. All bidders are required to submit documents including, but not limited to, manuals, data sheets, and a Manufacturer's Authorization Certificate (ISO 9001).
Lot 1: Brass Fittings	Fittings shall have a composition of 85% Copper, 5% Tin, 5% Lead, and 5% Zinc, corresponding to UNS C83600 and conforming to the requirements of the American Society for Testing and Materials (ASTM) B584, and must be tested at the Metals Industry Research and Development Center (MIRDC) with certificate to verify compliance, and should be done prior to delivery.	Fittings shall have a composition of 65% Copper, 5% Tin, 5% Lead, and 5% Zinc, corresponding to UNS C83600 and conforming to the requirements of the American Society for Testing and Materials (ASTM) B584, and must be tested at the Metals Industry Research and Development Center (MIRDC) with certificate to verify compliance, and should be done prior to delivery.

For guidance and information of all concerned.


FERDINAND S. FERRER, MPA
BAC Chairperson

Received by the Bidder:

Date: _____