



Republic of the Philippines  
**GENERAL SANTOS CITY WATER DISTRICT**  
 E. Fernandez St., Brgy. Lagao, General Santos City  
 Telephone No. (083) 552-3824 / Telefax No. (083) 553-4960  
 E-mail Address: gscwaterdistrict@yahoo.com  
[www.gensanwater.gov.ph](http://www.gensanwater.gov.ph)

PROJECT TITLE:

**REHABILITATION OF 1500 CU.M CYLINDRICAL GROUND STEEL TANK**

LOCATION

**SM VILLAGE, BRGY. SINAWAL, GENERAL SANTOS CITY**

OWNER

**GENERAL SANTOS CITY WATER DISTRICT**

**ABC: Php 3,802,996.00**

### TECHNICAL SPECIFICATIONS

Item Description
<p><b>1. Scope of Work</b></p> <p>a. The scope of work for this project consists of supply and delivery of necessary materials, appurtenances, labor, equipment, tools, power, water consumables and supervision for the completion of the proposed project as shown on plan and technical drawings specified in the scope of work herein.</p> <p>b. The <b>project duration</b> is <b>One Hundred Twenty (120) Calendar Days</b> and shall commence Five (5) Days after the receipt of Notice to Proceed.</p> <p>c. The contractor shall fabricate and install needed fittings and other appurtenances as shown and specified.</p>
<p><b>2. Bidders/Contractors Project Experience Requirements</b></p> <p>a. Bidders'/Contractors' Qualification</p> <p><b>Bidders/Contractors shall be fully experienced and reputable in the field of construction. Contractor's minimum size range is Small B and shall be unexpired during Opening of Bids. And Contractor's classification is under General Engineering/General Building with a minimum category D.</b></p> <p>b. Bidders'/Contractors' Competence &amp; Experience</p> <p>a. Similar Contract should be projects with civil, frame structure and structural steel works in any Government or Private Institutions duly supported by a owner's certificate of completion within Five (5) years from the date of Opening of Bid.</p> <p>b. The bidder must have completed an SLCC that is similar to the contract to be bid, and whose value, adjusted to current prices using the PSA consumer price indices, must be at least fifty percent</p>



Republic of the Philippines  
**GENERAL SANTOS CITY WATER DISTRICT**  
 E. Fernandez St., Brgy. Lagao, General Santos City  
 Telephone No. (083) 552-3824/ Telefax No. (083) 553-4960  
 E-mail Address: gscwaterdistrict@yahoo.com  
[www.gensanwater.gov.ph](http://www.gensanwater.gov.ph)

(50%) of the ABC to be bid: Provided, however, That contractors under Small A and small B categories without similar experience on the contract to be bid may be allowed to bid if the cost of such contract is not more that the Allowable Range of Contract Cost (ARCC) of their registration.

d. Bidders/Contractor without negative slippage of more than 15% in all its ongoing government or private infrastructure projects or a negative slippage of at least ten percent (10%) in each of two (2) or more contracts.

### 3. Definitions

a. OWNER

The word "Owner" refers to the General Santos City Water District.

b. ENGINEER

The word "Engineer" refers to the individual or firm authorized by the Owner to oversee the execution of the Contract.

c. CONTRACTOR

The word "Contractor" refers to the party entering into the contract for the performance of the work required.

d. CONTRACT

The word "Contract" refers to the contract documents and shall include the basic contract entered into by the owner and the contractor for the performance of the work.

e. SPECIFICATION

The word "Specification" refers to the General Conditions, Special Provisions and Technical Specifications of the contract together with all addenda and change orders issued with respect thereto.

f. DRAWINGS

The word "Drawing" or "Contract Drawing" refers to those drawings accompanying the Specification and subsequent approved drawings, which show the location, nature, extent and form of the work together with applicable detail.

g. WORK

The word "Work" refers to the labor, material, equipment, transportation and all incidental costs necessary to complete the Contract.

h. SITE

The word "Site" refers to the lands and other places on, under, in or through which the work is to be executed or carried out and any other lands or places provided by the Owner for the purpose of the Contract.

i. APPROVAL

The word "Approval" refers to concurrence in writing, including subsequent written confirmation of the previous verbal approval.

j. WORKING / CALENDAR DAY

The term "Working Day" refers to working days in the government service.





Republic of the Philippines  
**GENERAL SANTOS CITY WATER DISTRICT**  
E. Fernandez St., Brgy. Lagao, General Santos City  
Telephone No. (083) 552-3824/ Telefax No. (083) 553-4960  
E-mail Address: [gscwaterdistrict@yahoo.com](mailto:gscwaterdistrict@yahoo.com)  
[www.gensanwater.gov.ph](http://www.gensanwater.gov.ph)

The term "Calendar Day" refers to the days in a week including Saturdays, Sundays and Holidays. Whenever the word "Day" is issued, it shall refer to calendar day.

#### **4. SPECIFICATION, DRAWINGS AND DISCREPANCIES**

The intent of the Specifications and Drawings is that the contractor shall furnish all the required plant, labor, materials, equipment and services, unless otherwise specified provided.

The Specifications and Drawings are complementary and what is called for in one shall be as binding as if called for in both.

Any discrepancies, errors or omission found in the Specifications or Drawings shall be reported in writing within three (3) days from the discovery to the Engineer who will issue the correction in writing within the same period. The contractor shall not take advantage of any such discrepancies, errors or omissions but shall comply with the corrective measures regarding the same as prescribed by the Engineer.

Whenever called for in these Specifications or on the Drawings, or where required by the Engineer, the Contractor shall furnish to the Owner for review two (2) prints of each shop drawing.

The term "Shop Drawing" as used herein shall be understood to include detail design calculations, fabrications and installations, drawings, lists, graphs, operating instructions. Shop drawing shall be submitted to the Engineer for review and approval within fifteen (15) calendar days from receipt of the Notice of Award.

All shop drawings submittal shall be accompanied by transmittal form.

In case of conflict between the Specifications and the Drawings, the Specifications shall govern over the Drawings.



Republic of the Philippines  
**GENERAL SANTOS CITY WATER DISTRICT**  
 E. Fernandez St., Brgy. Lagao, General Santos City  
 Telephone No. (083) 552-3824/ Telefax No. (083) 553-4960  
 E-mail Address: gscwaterdistrict@yahoo.com  
[www.gensanwater.gov.ph](http://www.gensanwater.gov.ph)

## 5. RESPONSIBILITIES

### a. Engineer

The Engineer, acting as the authorized representative of the Owner, will decide such questions which may arise as to the quality and acceptability of materials and equipment furnished, work performed, rate of progress of work, interpretation of Specifications and Drawings, and those relating to the acceptability in fulfillment of the Contract by the Contractor.

### b. Contractor's Employees

The employees of the Contractor are not employees of the Owner. Hence, the Owner shall not be liable or responsible for any personal injury or damage including death caused by any of the employees of the contractor during the lawful performances of their duties.

The contractor shall, at all times, stand solely liable and/or responsible for the enforcement of and compliance with all existing laws, rules and regulations applicable, and the contractor hereby agrees and binds itself to save and hold the Owner free and harmless from any or all liabilities in respect thereto and/or arising there from.

### c. Contractor's Superintendence

A qualified superintendent shall be present in the work and shall provide competent supervision of the work, until its completion. The superintendent shall have full authority to act in behalf of the contractor, and all directions given by the Owner or authorize representative to the superintendent shall be considered given to the contractor.

## 6. SUSPENSION OF WORK

The Engineer, acting on behalf of the Owner may, by written notice to the Contractor, suspend the work in whole or in part for such period or periods as he may deem necessary, owing to such factors as delay in delivery of Owner furnished equipment or materials, or such other conditions as are considered unfavorable for prosecuting the work, or failure on the part of the Contractor to carry out the provisions of the Contract or to provide materials or workmanship meeting the requirements of the Specification.

## 7. PROJECT MONITORING

### a. Monthly Progress Report

The Contractor is required to submit to the Owner Two (2) copies of Monthly Progress Report which shall include the following;

- 1) Items of work accomplished for the month;
- 2) Cumulative summary of work accomplished to date;
- 3) Items of work scheduled for the following month.





Republic of the Philippines  
**GENERAL SANTOS CITY WATER DISTRICT**  
 E. Fernandez St., Brgy. Lagao, General Santos City  
 Telephone No. (083) 552-3824/ Telefax No. (083) 553-4960  
 E-mail Address: [gscwaterdistrict@yahoo.com](mailto:gscwaterdistrict@yahoo.com)  
[www.gensanwater.gov.ph](http://www.gensanwater.gov.ph)

4) Project photos for the month.

The first Monthly Progress Report will cover the time from the date when the Notice to Proceed is issued until the end of the following month. Subsequently, monthly reports shall be submitted monthly thereafter until provisional acceptance of the project.

If the Contractor fails to submit Monthly Progress Report, the Owner may withhold approval of progress payment until the reports are received.

b. Monthly Coordination Meeting

There will be a regular coordination meeting be conducted twice a month to discuss issues and concerns of the project.

The signatory to the Omnibus Sworn Statement who is the duly authorized representative of the winning bidder shall be required to attend the monthly coordination meeting; otherwise, the attendee/representative present

During the meeting shall be acknowledged only upon presentation of a duly notarized Special Power of Attorney.

**8. LAWS, LICENSES, SAFETY AND OTHER REQUIREMENTS**

a. Permit and Licenses

The procurement and payment of all necessary permits such as Zoning, Building, Electrical, Mechanical, Plumbing, Sanitary, etc., in the project implementation shall be the responsibility of the Owner.

b. Inspection of Project Site

The Contractor shall inspect the site of the work in order to satisfy themselves by personal examination and/or by such other means as they may prefer, of the location of the proposed work and the actual visualization of the work to be done. He should be aware of the conditions which might affect the execution of this contract and has made provisions therefore in his bid.

c. Public Safety and Health Regulations

The Contractor shall comply with safe work practices and all health and safety regulations of the state and the locality. Furnish protective and lifesaving equipment for persons working at the site and provide a **Contractor's All Risk Insurance third party liabilities and Personal Accident Insurance for all his workers.**

Coverages: (Per Person in 1 Year)	Limit of Cover
Accidental Death & Disablement (AD&D)	Php 100,000.00
Unprovoked Murder & Assault (UM&A)	Php 50,000.00



Republic of the Philippines  
**GENERAL SANTOS CITY WATER DISTRICT**  
 E. Fernandez St., Brgy. Lagao, General Santos City  
 Telephone No. (083) 552-3824/ Telefax No. (083) 553-4960  
 E-mail Address: gscwaterdistrict@yahoo.com  
[www.gensanwater.gov.ph](http://www.gensanwater.gov.ph)

Accidental Medical Reimbursement (AMR)	Php 30,000.00
Burial Benefit due to Accident	Php 30,000.00

Whenever necessary, it shall furnish, erect and maintain fences, barricades, lights, signs and other devices as are necessary to prevent accidents and avoid damage or injury to the public.

The Contractor shall be liable to all claims and/or liabilities arising during the public implementation. Should the Contractor fail to faithfully observe the Safety Provisions herein specified, the Owner may exercise remedial rights as stipulated under this Contract.

d. **Laws and Regulations**

The Contractor shall observe and comply National, Provincial and Local laws, ordinances, and regulations, which on the manner affect those engaged or employed on the work, the material used in the work, or in the conduct of the work.

The Contractor shall indemnify and save harmless the Owner against all claims or liabilities arising from violation of any such laws, ordinance, order, or regulation, whether by itself or by its employees.

e. **Third Party Liability**

The Owner shall in no case be held civilly or criminally liable due to the act or omission of the Contractor during the contract period or during the implementation of the required work thereof. Any liability that may arise to the third party shall be the sole responsibility of the contractor.

**9. GENERAL SPECIFICATIONS**

**a. Scrapping and Re-welding of Bottom Plate**

This item shall consist of the removal of paint from mild steel plates and subsequent re-welding of the plates that have been previously welded or subjected to welding work. The work involves cleaning the surface, scrapping the old paint, and re-welding the joints to restore mechanical properties, strength, and integrity.

**b. Removal of Existing Structure and Obstruction**

This item shall consist of the removal wholly or in part, and satisfactory disposal of steel frames, steel plate, pipes and any other obstructions which are not designated or permitted to remain.

All salvable material shall be removed, without unnecessary damage, in sections or pieces which may be readily transported, and shall be stored by the contractor at specified places permitted by the Engineer. Salvage material which are damaged thru negligence shall be replaced or restored at the contractor's expense.

**c. Steel Works – Erection of Stainless Steel Structure**





Republic of the Philippines  
**GENERAL SANTOS CITY WATER DISTRICT**  
 E. Fernandez St., Brgy. Lagao, General Santos City  
 Telephone No. (083) 552-3824/ Telefax No. (083) 553-4960  
 E-mail Address: gscwaterdistrict@yahoo.com  
[www.gensanwater.gov.ph](http://www.gensanwater.gov.ph)

Stainless steel grade 304 shall conform to the Standard Specifications Structural Steel (ASTM A276). All materials to be provided and used by the contractor shall be new, previously unused, and in good condition.

This work shall consist of furnishing, fabricating, hauling, erecting and welding of metal structure and accessories constructed in accordance with the plans and this specifications.

#### Welding

All welding shall be the shielded metal arc welding method and shall conform to the AWS "Code for Arc and Gas Welding in Building Construction". Welder's minimum qualification shall be TESDA equivalent passers with Certificate provided.

All welds in the structural attachments shall be made in a manner to ensure complete fusion with the base material, within the limits specified for each joint, and in accordance with the qualified procedure.

1. For the installation of plate, structural steel & web member weld shall be at:
  - a. Inside Joint – 1<sup>st</sup> Pass
  - b. Outside Joint – 2 -3 Passes
2. Welding shall not be performed when the surfaces of the parts to be welded are wet from rain, or when rain is falling on such surfaces, or during periods of high winds, unless the welder or welding operator and work are protected properly.
3. Peening of weld layers may be used to prevent undue distortion. Surface layers shall not be peened. Peening shall be performed with light blows from a power hammer with a blunt-nosed tool.
4. The surface bends shall merge smoothly into each other in all welds.
5. The reinforcement of butt welds shall, as practicable, be preferably not more than 1.6mm (1/16 in). In no case shall the face of the weld lie below the surface of the plates being joined.
6. Gouging at the root of the welds and gouging of welds to remove defects may be performed with a round-nosed tool or by arc or oxygen gouging.
7. Each bead of multiple pass weld shall be cleared of slag and other loose deposits before the next bead is applied.

#### *Preparation of Surface to be welded*

Surfaces to be welded shall be free from loose scale, slag, heavy rust, grease, paint, and any other foreign material except tightly adherent mill scale. A light film of deoxaluminite or equivalent spatter film compound may be disregarded. Such surfaces shall be smooth, uniform, and free from fins,



Republic of the Philippines  
**GENERAL SANTOS CITY WATER DISTRICT**  
 E. Fernandez St., Brgy. Lagao, General Santos City  
 Telephone No. (083) 552-3824/ Telefax No. (083) 553-4960  
 E-mail Address: gscwaterdistrict@yahoo.com  
[www.gensanwater.gov.ph](http://www.gensanwater.gov.ph)

seams, and other defects that adversely affect proper welding. A fine film of rust adhering on cut or sheared edge after wire brushing need not be removed.

**d. Electrical Works**

All electrical installations shall be in accordance with the latest edition of the Philippine Electrical Code and shall comply with all laws and regulations applicable to the authorities.

Work under this section shall include the supply, installation, testing and delivery in perfect running conditions of the electrical installations for subject project.

These installations comprise, but are not limited to, the following chapters:

- Panel Board (NEMA Standard Enclosure/Outdoor)
- Complete electrical installations for all lighting fixture

The supply shall include all the equipment, accessories and other materials not enumerated in these specifications but found necessary for the completion and perfect functioning of the installations. Work shall be executed in a first-class work-manlike manner in accordance with these specifications, the drawings and notes indicated therein, the instructions of the Engineer, the provisions of the Bill of Quantities delivered in place and tested to the full satisfaction of the Engineer.

All wires shall be concealed and all electrical devices shall be of good kind and quality.

Electrical switches, outlets, convenient outlets shall be placed as indicated on the plans and necessary. Electrical fixtures are of highest standard quality such as National, GE, Toshiba or other brands of the same quality. All Electrical fixture shall be referred to the Owner.

All other specifications shall be referred to the approved plan.

**e. On-Site Inspection and Testing**

All materials furnished and all work performed under the contract shall be subject to inspection by the Owner. The contractor shall be held strictly to the true intent of the Specifications and Drawing in regard to quality of materials, workmanship and diligent execution of the Contract.

Work done in the absence of prescribed inspection may be required to be removed and replaced under the proper inspection; and the entire cost of removal and replacement, including the cost of all materials which may be used in the work shall be borne by the Contractor.

The cost of carrying out the normal inspection and test of material should be at the Contractor's Expense.

**f. MISCELLANEOUS WORKS**

**PAINING AND COATING**





Republic of the Philippines  
**GENERAL SANTOS CITY WATER DISTRICT**  
 E. Fernandez St., Brgy. Lagao, General Santos City  
 Telephone No. (083) 552-3824/ Telefax No. (083) 553-4960  
 E-mail Address: gscwaterdistrict@yahoo.com  
[www.gensanwater.gov.ph](http://www.gensanwater.gov.ph)

The following surfaces are to be painted but not limited to:

- a. All structural and miscellaneous steel
- b. Steel plate, column, girt, exterior and interior surfaces
- c. All above ground piping and other metal surfaces
- d. All exposed concrete

#### *SURFACE PREPARATION*

All structural steel shall be free from dirt, scale, and rust removed by scrapping, wire brushing and sandblasting. All welded joints should be cleared of slag and weld spatter. Before painting, ferrous metal surfaces, including galvanized ferrous metal surfaces, shall be pretreated with approved phosphoric acid etching cleaner in accordance with manufacturer's direction.

#### **g. SPECIAL CONDITIONS**

##### a. Laboratory Testing Fee

All laboratory testing fee and transportation shall be shouldered by the contractor.

##### b. Project Turnover

During project's turn-over, Contractor is required to submit as-built plan. The contractor's deliverables are 100 percent accomplished either on each part and the site restored as is prior to construction.

##### c. Logbook and Weather Chart

A logbook and weather chart shall be maintained by the Contractor at all times in the project site reflecting the daily work activity, weather condition, manpower, equipment, visitors and circumstances affecting the program of work to be signed by both the Engineer and Contractor.

##### d. Equipment per lot.

Contractor shall provide the following minimum equipment but not limited to:

Quantity	Description
3	Engine Driven Welding Machine or Transformer Type
1	Boom Truck/Crane
1	Oxy-Acetylene cutting outfit
1	Power Brush/Grinder

The Contractor shall be required to include the list of their equipment in the technical documents and specify whether the same is leased or owned. The Contractor shall provide a Memorandum of Agreement or Lease Contract if leased. The bidder shall attach official receipts or sales invoices for owned equipment. Affidavits or any form of Certification executed under oath shall not be accepted and



Republic of the Philippines  
**GENERAL SANTOS CITY WATER DISTRICT**  
 E. Fernandez St., Brgy. Lagao, General Santos City  
 Telephone No. (083) 552-3824/ Telefax No. (083) 553-4960  
 E-mail Address: gscwaterdistrict@yahoo.com  
[www.gensanwater.gov.ph](http://www.gensanwater.gov.ph)

is grounds for disqualification. During post-qualification, GSCWD shall conduct an inspection to verify the availability of the listed equipment. The absence of any one of the required equipment is grounds for disqualification.

During post-qualification, GSCWD shall conduct inspection to verify the availability of the listed equipment. Absence of any one of the required equipment is ground for disqualification.

e. List of Manpower

Quantity	Description
1	Project Engineer/Civil Engineer
1	Safety Officer
1	Foreman
3	Welder
5	Laborer/Helper

The bidder shall submit its organizational structure for the project including unexpired licenses of professionals to be assigned and stipulate specific functions wherein One (1) professional can hold only up to Two (2) key positions. The personnel listed in the bid must be the same individuals performing the designated tasks on-site. **If there are any changes during the time of implementation to the assigned key personnel (Foreman, Safety Officer, Project Engineer), the bidder must notify GSCWD with a formal written request outlining those changes.** This process ensures accountability and clarity regarding who is responsible for each function throughout the project. Welders shall also submit unexpired corresponding National Competency (NC) certificate from TESDA. Original document must be available and presented during the conduct of post-qualification. The absence of needed documents is subject to disqualification.

Note: During the actual implementation of the project, assigned welders are required to carry out actual welding tasks with GSCWD Representative.

Bidders who opt to bid for this project and has ongoing awarded GSCWD project/s shall have a different set of key personnel and equipment to be assigned to this project otherwise, the same shall be ground for disqualification.

f. On-Site Inspection and Testing





Republic of the Philippines  
**GENERAL SANTOS CITY WATER DISTRICT**  
 E. Fernandez St., Brgy. Lagao, General Santos City  
 Telephone No. (083) 552-3824/ Telefax No. (083) 553-4960  
 E-mail Address: gscwaterdistrict@yahoo.com  
[www.gensanwater.gov.ph](http://www.gensanwater.gov.ph)

All materials furnished and all work performed under the contract shall be subject to inspection by the Owner. The contractor shall be held strictly to the true intent of the Specifications and Drawing in regard to quality of materials, workmanship and diligent execution of the Contract.

Work done in the absence of prescribed inspection may be required to be removed and replaced under the proper inspection; and the entire cost of removal and replacement, including the cost of all materials which may be used in the work shall be borne by the Contractor.

The cost of carrying out the normal inspection and test of material should be at the Contractor's Expense.

#### **h. SPECIAL PROVISION**

##### **1. LIQUIDATED DAMAGES**

The Contractor shall pay liquidated damages to the Owner if he fails to complete the work within the time agreed upon. It is understood that said payment is not a penalty but a fixed sum representing the liquidated damages for each calendar day of delay.

Computation of the said liquidated damages shall conform to the provision of RA 9184(GPPB Resolution No. 02-2020) Harmonizing the rules on imposition of liquidated damages.

Note:

In computing for liquidated damages, the Procuring Entity determines the usability of the project. A project or portion thereof may be deemed usable when it starts to provide the desired benefits as certified by the targeted end-users and the concerned Procuring Entity.

Liquidated damages is an amount equal to at least one tenth (1/10) of one (1) percent of the cost of the unperformed portion of the works for everyday of delay.

If the project is rendered unusable after the expiry date, it shall be considered as unperformed, hence the Liquidated Damages shall be computed based on the total contract price.

##### **2. Time Extension**

The Contractor may be entitled to an extension of Contract time;

- a. If the work has been suspended by the Owner in whole or in part.
- b. Under force majeure (i.e. flood, blockade, earthquake, civil disorder, etc.) provided, in either case, the Contractor be not at fault and is not negligent under the terms of the contract.



Republic of the Philippines  
**GENERAL SANTOS CITY WATER DISTRICT**  
 F. Fernandez St., Brgy. Lagao, General Santos City  
 Telephone No. (083) 552-3824/ Telefax No. (083) 553-4960  
 E-mail Address: gscwaterdistrict@yahoo.com  
[www.gensanwater.gov.ph](http://www.gensanwater.gov.ph)

The extension of time allowed shall be determined by the Owner. Extension of Contract shall be granted for rainy/unworkable days considered unfavorable for the prosecution of the works at the site or based on the actual conditions obtained at the site.

No extension of Contract time whatsoever shall be granted to the Contractor due to non-availability of equipment or materials to be furnished by the Contractor, labor problems and such other cause for which the Government is not directly responsible, or when the affected activities do not fall within the critical path of the network.

To receive consideration, a request for time extension must be made in writing to the Owner through the Engineer stating therein the reason for said request and must be received by the Owner at least **Thirty (30) days prior to the expiration of the Contract time**. Failure to observe this reglementary period shall be a ground for outright denial of the request for time extension.

### 3. Variation in Quantities

Bidders are reminded that the quantities are estimated and are for the purpose of comparing bids. The successful bidder shall complete all work items at the unit prices quoted in his bid, regardless of the variation between bid quantities and actual quantities required for completion of the work. Payment will be based on actual quantities furnished, installed or constructed.

### 4. PLANS AND SPECIFICATIONS

All works, that may be called for in the specifications and not shown in the plans or vice versa, shall be executed and finished as if described in both. Should any work required which is not denoted on either plans and specifications either directly or indirectly, it is understood that same shall be implied and required and shall be performed and furnished such materials and layout as fully as if it has been so described.

The plans and specifications shall be considered complementary and any details mentioned in one but not in the other, or vice versa, shall be interpreted to be applicable in both.

If no numerical label of the dimension(s) of any part of details appeared on the plan, the drawings shall be carefully followed in accordance to the scale thus indicated, otherwise all numerical data of dimensions of details when so provided must be followed and not the scale of the drawing.








Republic of the Philippines  
**GENERAL SANTOS CITY WATER DISTRICT**  
 E. Fernandez St., Brgy. Lagao, General Santos City  
 Telephone No. (083) 552-3824 / Telefax No. (083) 553-4960  
 E-mail Address: gscwaterdistrict@yahoo.com  
[www.gensanwater.gov.ph](http://www.gensanwater.gov.ph)

### TECHNICAL WORKING GROUP FOR INFRASTRUCTURE


Prepared by:

  
**Danilo M. Morador Jr., CE**  
 TWG - Member


  
**Maria Celia N. Dandan, CE**  
 TWG - Member

  
**Michael G. Santos, REE**  
 TWG - Head

Recommending Approval:

  
**Rogelio A. Besana Jr., CE, RMP**  
 AGM- Operations & Technical Services

Approved:

  
**Francisco R. Alplod Jr., CPA, CESE**  
 Acting General Manager