



Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT
E. Fernandez Street, Barangay Lagao General Santos
Telephone No.: 552-3824; Telefax No.: 553-4960
Email Address: gscwdprocurement@yahoo.com

GPM-014-4

REQUEST FOR QUOTATION

RFQ #: 3-0124-106 DATE: 1/22/2024

SUPPLIER: _____
ADDRESS: _____
TELEPHONE NO. : _____
TIN NO. : _____

Dear Sir/Madam,

Pls. quote your lowest price on the item/s listed below subject to general condition stating the shortest time of delivery and submit your quotation duly signed by your representative not later than 1/26/2024, Pls. furnish this office the following articles subject to the terms and conditions contained therein.

Instructions :

1. Accomplish this Request for Quotation duly, correctly, and completely.
2. Do not alter the contents of this form in any way.
3. If Technical Specifications/ Terms of Reference is provided, prospect bidder (supplier / service provider) must indicate and signify compliance to every parameter in the specification.

| ITEM NO. | DESCRIPTION | QTY. | UNIT | UNIT PRICE |
|----------|---|------|------|------------|
| 1 | CENTRIFUGAL PUMP 1HP : CHLORINE BOOSTER PUMP 1HP, 220V,1PHASE, PLEASE SEE ATTACHED SPECIFICATION-ABC: PHP 175,000.00 ##### nothing follows ##### | 5 | unit | P |

Date of Delivery: _____
Price Validity : _____
Mode of Payment: _____

Place of Delivery: GSCWD Bodega

****No partial delivery allowed****

Note: 6% WITHHOLDING TAX DEDUCTION

PR NO.: 0124-065

Requested by:

ANDREW H. NADAL, JR.
Material Procurement Officer A

Price quoted by:

Supplier

Date



TECHNICAL SPECIFICATION

TITLE: PURCHASE OF BRAND NEW CHLORINE BOOSTER PUMP

1.0 SCOPE OF CONTRACT

The scope shall be supply and delivery of brand new Chlorine Booster Pump to General Santos City Water District (GSCWD).

2.0 OPERATING REQUIREMENTS

| Particulars | Requirements | Statement of Compliance |
|---|---------------------------|-------------------------|
| Maximum Flow, Lps (gpm) | 3.7 (60) | |
| Maximum head, m(ft) | 35.9(118) | |
| Discharge / Suction Connection, (inch) | 1 ½" NPT | |
| Design Speed (RPM) | 3400-3600 | |
| Pump Casing | Cast Iron | |
| Impeller Material | Glass filled noryl | |
| Maximum Water Temperature | 140°F | |
| Motor Rated Power (Hp) | 1 | |
| Rated Voltage | 115/230 | |
| Phase | 1 | |
| Design point | 3400-3600RPM | |
| Protection | Thermal Protection | |

3.0 TERMS AND CONDITIONS

| Item No. | Requirements | Statement of Compliance |
|----------|--|-------------------------|
| 1 | The scope of work shall be supply and delivery of brand new Chlorine Booster Pump to General Santos City Water District (GSCWD). | |
| 2 | All bidder is required to submit and include documents but not limited to manuals, data | |



| | | |
|---|--|--|
| | sheets, and Manufacturers Certificate in there bidding documents. | |
| 3 | Field testing shall be made once the units are ready for operation and when both the GSCWD and winning bidder have finished their scopes of work on the installed units. GSCWD engineers shall conduct field testing with the presence of winning bidder's representative. | |
| 4 | The winning bidder shall deliver the units within Thirty (30) calendar days upon receipt of Purchase Order (PO). | |
| 5 | The winning bidder shall be subjected to Liquidated Damages (LD) for each day of delay as provided by the IRR of RA 9184. | |
| 6 | That the winning bidder shall issue a warranty certificate of not less than one (1) year and the warranty shall commence from the date of commissioning of the pumping equipment. | |
| 7 | That the winning bidder shall have an available qualified and trained technicians 24/7 with in Mindanao area in case of equipment failure. | |

Prepared by:


EDMUND L. BADAL, REE
TWG - Member


MICHAEL G. GABALES, REE
TWG - HEAD