



Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT
 E. Fernandez Street, Barangay Lagao General Santos
 Telephone No.: 552-3824; Telefax No.: 553-4960
 Email Address: gscwdprocurement@yahoo.com

GPM-014-3

REQUEST FOR QUOTATION

RFQ #: 3-0223-025 DATE: 02/02/2023

SUPPLIER: _____
 ADDRESS: _____
 TELEPHONE NO. : _____
 TIN NO. : _____

Dear Sir/Madam,

Pls. quote your lowest price on the item/s listed below subject to general condition stating the shortest time of delivery and submit your quotation duly signed by your representative not later than 02/08/2023, Pls. furnish this office the following articles subject to the terms and conditions contained therein.

ITEM NO.	DESCRIPTION	QTY.	UNIT	UNIT PRICE
1	FLOWMETER ELECTROMAGNETIC FULL BORE TYPE AC 8" : PLEASE SEE ATTACHED SPECIFICATION-ABC: PHP 900,000.00 ##### nothing follows #####	2	unit	P

Delivery term: _____
 Price Validity : _____
 Terms of Payment: _____

Place of Delivery: GSCWD Bodega
 *****No partial delivery allowed*****
 Note: 6% WITHHOLDING TAX DEDUCTION
 PR NO.: 0123-087

Requested by:

[Signature]
RESERVA
OFFICER A
MATERIAL PROCUREMENT

Price quoted by:

 Supplier

 Date



TECHNICAL SPECIFICATION

TITLE: PURCHASE OF FULL BORE ELECTROMAGNETIC FLOWMETER

1.0 SCOPE OF CONTRACT

The scope shall be supply, testing, delivery and commissioning of Two (2) sets brand new Full Bore Electromagnetic Flowmeter to General Santos City Water District (GSCWD).

Particulars	Requirements	Statement of Compliance
SIZE mm (inches)	200 (8)	
Number Of Unit	2	
Type	Electromagnetic Flow meter	
Power Supply	85 - 265 Vac, 24Vac / 24Vdc	
Measurements	Direct / Inverse Flow	
Qmax (m ³ /hr)	400 to 1250	
Qnominal (m ³ /hr)	280 to 1000	
QTransitional (m ³ /hr)	6 to 8.5	
Qmin (m ³ /hr)	4 to 5.5	
Cable	20 meters w/ complete accessories	
Connection	Flanged Type, PN 16	
Lining	Hard Rubber for Potable Water	
Rating	IP 67/NEMA 6	
Security	Read-only switch and ultra-secure service password	
Current Output	4 to 20 mA	
Digital Outputs	Three (3) configurable pulse/ frequency and alarm outputs	



TERMS AND CONDITIONS

Item No.	Requirements	Statement of Compliance
1	The scope of work shall be supply, testing, delivery and commissioning of brand new Full Bore Electromagnetic Flowmeter to General Santos City Water District (GSCWD).	
2	The new Full Bore Electromagnetic Flowmeter shall be compatible with the existing loggers used by GSCWD. No additional software and hardware needed for easy and friendly integration with the logger.	
3	All bidder is required to submit and include documents but not limited to manuals, data sheets, name plate specifications, and Manufacturers Authorization Certificate specific to this project in there bidding documents.	
4	The brand new Full Bore Electromagnetic Flowmeter shall be tested in a laboratory before delivery to ensure conformance with the design parameters. The cost of the laboratory testing shall be borne entirely by the winning bidder.	
5	The flowmeter shall be tested for accuracy in a laboratory for maximum, minimum, nominal, and transitional flow rates . The result shall be the basis for the flowmeter to PASS or FAIL in the accuracy test. Max permitted error: From Q_{min} to Q_t = $\pm 0.2\%$ to $\pm 0.4\%$ From Q_t to Q_{max} = $\pm 2\%$	
6	Laboratory testing shall be witnessed by three (3) GSCWD representatives together with the winning bidder's representatives for three (3) days. All relevant and incidental cost (Testing fee, transportation, accommodation, allowances and etc.) in the testing of the equipment shall be shouldered by the winning bidder.	
7	In case the unit/units failed to pass the testing requirements during laboratory testing, the winning bidder shall make necessary adjustment to correct and comply with the specifications set by GSCWD without additional cost to GSCWD.	
8	That during the installation and commissioning of the units, the winning bidder shall be required to send a technician responsible of commissioning the three units. All relevant and incidental cost (transportation, accommodation, allowances	



	and etc.) in the commissioning of the equipment shall be shouldered by the winning bidder.	
9	Field testing shall be made once the unit is ready for operation and when both the GSCWD and winning bidder have finished their scopes of work on the installed unit. GSCWD engineers shall conduct field testing with the presence of winning bidder's representative. Flowmeters must meet the testing requirements in terms of efficiency. In case the unit/units failed to pass the field testing, the winning bidder shall make necessary corrections / changes or replace the unit without cost to GSCWD.	
10	The winning bidder shall deliver the two (2) set brand new electromagnetic flowmeter , within Sixty (60) calendar days upon receipt of Purchase Order (PO). Laboratory testing is included in the 60- calendar day's delivery period.	
11	The winning bidder shall be subjected to Liquidated Damages (LD) for each day of delay as provided by the IRR of RA 9184.	
12	That the winning bidder shall issue a warranty certificate of not less than one (1) year and the warranty shall commence from the date of commissioning of the unit. That the bidder must have an available qualified and trained technicians 24/7 in case of equipment failure.	

Prepared by:


EDMUND L. BADAL, REE
TWG - Member


MICHAEL G. GABALES, REE
TWG - HEAD

Recommending Approval:


ROGELIO A. BESANA JR. C.E./RMP
Assistant General Manager

Approval:


ARN B. GELLANGARIN, PME
General Manager A