



Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT
E. Fernandez Street, Barangay Lagao General Santos
Telephone No.: 552-3824; Telefax No.: 553-4960
Email Address: gscwdprocurement@yahoo.com

GPM-014-3

REQUEST FOR QUOTATION

RFQ #: 3-0223-082 DATE: 02/20/2023

SUPPLIER: _____
ADDRESS: _____
TELEPHONE NO. : _____
TIN NO. : _____


Dear Sir/Madam,

Pls. quote your lowest price on the item/s listed below subject to general condition stating the shortest time of delivery and submit your quotation duly signed by your representative not later than 02/24/2023, Pls. furnish this office the following articles subject to the terms and conditions contained therein.

ITEM NO.	DESCRIPTION	QTY.	UNIT	UNIT PRICE
1	CENTRIFUGAL PUMP 1HP : CHLORINE BOOSTER PUMP: 230V, 1HP, 60HZ, Q:18GPM, HEAD:118FT, PLEASE SEE ATTACHED SPECIFICATION-ABC: PHP 150,000.00 ##### nothing follows #####	5	unit	P

Delivery term: _____
Price Validity : _____
Terms of Payment: _____


Place of Delivery: GSCWD Bodega
*****No partial delivery allowed****
Note: 6% WITHHOLDING TAX DEDUCTION
PR NO.: 0223-021

Requested by:

GEM R. CABAÑERO
GENERAL PROCUREMENT
OFFICER A

Price quoted by:

Supplier

Date



TECHNICAL SPECIFICATION

TITLE: PURCHASE OF BRAND NEW CHLORINE BOOSTER PUMP

1.0 SCOPE OF CONTRACT

The scope shall be supply and delivery of brand new Chlorine Booster Pump to General Santos City Water District (GSCWD).

2.0 OPERATING REQUIREMENTS

Particulars	Requirements	Statement of Compliance
Maximum Flow, Lps (gpm)	3.7 (60)	
Maximum head, m(ft)	35.9(118)	
Discharge / Suction Connection, (inch)	1 ½" NPT	
Design Speed (RPM)	3400-3600	
Pump Casing	Cast Iron	
Impeller Material	Glass filled noryl	
Maximum Water Temperature	140°F	
Motor Rated Power (Hp)	1	
Rated Voltage	115/230	
Phase	1	
Design point	3400-3600RPM	
Protection	Thermal Protection	

3.0 TERMS AND CONDITIONS

Item No.	Requirements	Statement of Compliance
1	The scope of work shall be supply and delivery of brand new Chlorine Booster Pump to General Santos City Water District (GSCWD).	
2	All bidder is required to submit and include documents but not limited to manuals, data	



	sheets, and Manufacturers Certificate in there bidding documents.	
3	Field testing shall be made once the units are ready for operation and when both the GSCWD and winning bidder have finished their scopes of work on the installed units. GSCWD engineers shall conduct field testing with the presence of winning bidder's representative.	
4	The winning bidder shall deliver the units within Thirty (30) calendar days upon receipt of Purchase Order (PO).	
5	The winning bidder shall be subjected to Liquidated Damages (LD) for each day of delay as provided by the IRR of RA 9184.	
6	That the winning bidder shall issue a warranty certificate of not less than one (1) year and the warranty shall commence from the date of commissioning of the pumping equipment.	
7	That the winning bidder shall have an available qualified and trained technicians 24/7 with in Mindanao area in case of equipment failure.	

Prepared by:


EDMUND L. BADAL, REE
TWG - Member


MICHAEL G. GABALES, REE
TWG - HEAD

Recommending Approval:


ROGELIO A. BESANA JR. C.E./RMP
Assistant General Manager

Approval:


ARN B. GELLANGARIN, PME
General Manager A