



Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT
E. Fernandez Street, Barangay Lagao General Santos
Telephone No.: 552-3824; Telefax No.: 553-4960
Email Address: gscwdprocurement@yahoo.com

GPM-014-4

REQUEST FOR QUOTATION

RFQ #: 3-0224-016 DATE: 2/7/2024

SUPPLIER: _____
ADDRESS: _____
TELEPHONE NO. : _____
TIN NO. : _____

Dear Sir/Madam,

Pls. quote your lowest price on the item/s listed below subject to general condition stating the shortest time of delivery and submit your quotation duly signed by your representative not later than 2/11/2024, Pls. furnish this office the following articles subject to the terms and conditions contained therein.

Instructions :

1. Accomplish this Request for Quotation duly, correctly, and completely.
2. Do not alter the contents of this form in any way.
3. If Technical Specifications/ Terms of Reference is provided, prospect bidder (supplier / service provider) must indicate and signify compliance to every parameter in the specification.

ITEM NO.	DESCRIPTION	QTY.	UNIT	UNIT PRICE
1	TESTER : COMPLETE SET DIGITAL EARTH TESTER (20 OHM TO 2000OHM) PLEASE SEE ATTACHED SPECIFICATION-ABC: PHP 60,000.00 ##### nothing follows #####	2	pc	P

Date of Delivery: _____
Price Validity : _____
Mode of Payment: _____

Place of Delivery: GSCWD Bodega

****No partial delivery allowed****

Note: 6% WITHHOLDING TAX DEDUCTION

PR NO.: 0124-174

Requested by:

GESEM R. CABAÑERO
Supervising Material
Planning Officer

Price quoted by:

Supplier

Date



Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT
 E. Fernandez St., Brgy. Lagao, General Santos City
 Telephone No. (083) 552-3824/ Telefax No. (083) 553-4960
 E-mail Address: gscwaterdistrict@yahoo.com
 www.gensanwater.gov.ph



TECHNICAL SPECIFICATION

TITLE: PURCHASE OF BRAND NEW DIGITAL EARTH TESTER

1.0 SCOPE OF CONTRACT

The scope shall be supply of Two (2) units brand Brand New Digital Earth Testers to General Santos City Water District (GSCWD).

Requirements	Statement of Compliance
Earth resistance measurement with 3 and 2 wires	
Automatic checking of current spike resistance	
Measurement ranges: Earth resistance : 0-20Ω/O-200 Ω /O-2000 Ω Earth voltage (50,60Hz) : 0-200V AC	
Accuracy: Earth resistance : ±2%rdg±0.1 Ω (20 Ω range) Earth Voltage : ± 1 %rdg±4dgt	
Overload protection: Earth resistance : 280V AC for 10 seconds across 2 of the 3 terminals Earth voltage : 300V AC for 1 minute	
Applicable standards: IEC61010-1 CAT III 300V Pollution degree 2, IEC61557-1 IEC61010-031, IEC60529 (IP54)	
Power source: (AA) 1.5V x 6	
Dimensions: 105 (L) x 158 (W) x 70 (D) mm	
Accessories: 7095A (Earth resistance test leads) x 1 set (red-20m,yellow-10m,green-5m) 8032 (Auxiliary earth spikes) x 1set 7127 A (Simplified measurement probe) x 1set 9121 (Shoulder strap), R6(AA) x 6, Instruction manual 7100A(Precision measurement cord set) 8259(Adapter for measurement terminal)	



Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT
E. Fernandez St., Brgy. Lagao, General Santos City
Telephone No. (083) 552-3824/ Telefax No. (083) 553-4960
E-mail Address: gscwaterdistrict@yahoo.com
www.gensanwater.gov.ph



Terms and Conditions

1. The scope of work shall be supply and delivery of two (2) units brand new Digital Earth Testers to General Santos City Water District (GSCWD).
2. The winning bidder is required to submit actual documents (manuals, data sheets, manufacturer's test results, name plate Specifications and etc.)
3. The winning bidder shall deliver brand new Digital Earth Testers within Thirty (30) calendar days upon receipt of Purchase Order (PO).
4. The winning bidder shall be subjected to Liquidated Damages (LD) for each day of delay as provided by the IRR of RA 9184.
5. That the winning bidder shall issue a warranty certificate of not less than one (1) year.

Prepared by:


EDMUND L. BADAL, REE
TWG - Member


MICHAEL G. GABALES, REE
TWG - HEAD