



Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT
E. Fernandez Street, Barangay Lagao General Santos
Telephone No.: 552-3824; Telefax No.: 553-4960
Email Address: gscwdprocurement@yahoo.com

GPM-014-2

REQUEST FOR QUOTATION

RFQ #: 3-0322-112 DATE: 03/22/2022

SUPPLIER: _____
ADDRESS: _____
TELEPHONE NO. : _____
TIN NO. : _____

Dear Sir/Madam,


Pls. quote your lowest price on the item/s listed below subject to general condition stating the shortest time of delivery and submit your quotation duly signed by your representative not later than 03/28/2022, Pls. furnish this office the following articles subject to the terms and conditions contained therein.

ITEM NO.	DESCRIPTION	QTY.	UNIT	UNIT PRICE
1	TRANSFORMER DRY TYPE STEP DOWN 10 KVA : STEP DOWN TRANSFORMER 460V/230V, SINGLE PHASE, PLEASE SEE ATTACHED SPECIFICATIONS-ABC: PHP 150,000.00 ##### nothing follows #####	1	unit	P

Date of Delivery: _____
Price Validity : _____
Terms of Payment: _____

Place of Delivery: GSCWD Bodega
****No partial delivery allowed****
Note: 6% WITHHOLDING TAX DEDUCTION
PR NO.: 0222-092

Requested by:


GESEM R. CABAÑERO
MATERIAL PROCUREMENT
OFFICER A

Price quoted by:

Supplier

Date



TECHNICAL SPECIFICATION

TITLE: PURCHASE OF DRY TYPE STEP DOWN TRANSFORMER

1.0 General Scope

The scope of work shall be supply and delivery of Dry type step down transformer to General Santos City Water District.

2.0 General Specification

Item	Technical Specification	Statement of Compliance
1	Dry Type Transformer, 60Hz, 1P, copper windings with powder coated enclosure	
2	Capacity: 10kVA	
3	Primary: 460V	
4	Secondary: 230V	
5	Voltage drop: 3.3%	
6	Primary and secondary connections on copper plates	
7	IP21 degree of protection	
8	220°C insulation materials	

3.0 TERMS AND CONDITIONS

1. The scope of work shall be supply and delivery of Dry type step down transformer to General Santos City Water District (GSCWD).
2. The winning bidder is required to submit the following but not limited to data sheets and operating manual.



Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT (GSCWD)

GSCWD Bldg., E. Fernandez Street (Emergency Road), Lagao, General Santos City
Telephone No.: 552-3824/554-7231; Telefax No.: 553-4960
E-mail Address: gscwaterdistrict@yahoo.com

3. The winning bidder shall deliver the Dry type step down transformer within **Sixty (60)** calendar days upon receipt of Purchase Order (PO).
4. That the winning bidder shall have an available qualified and trained technicians 24/7 in case of equipment failure.
5. The winning bidder shall be subjected to Liquidated Damages (LD) for each day of delay as provided by the IRR of RA 9184.
6. That the winning bidder shall issue a warranty certificate of not less than one (1) year and the warranty shall commence from the date of commissioning of the unit.

Prepared by:


EDMUND L. BADAL, REE
TWG - Member


JUDY LIM-PASMAN, LLB
TWG - Member


MICHAEL G. GABALES, REE
TWG - HEAD

Recommending Approval:


ROGELIO A. BESANA JR. C.E./RMP
Assistant General Manager

Approval:

ARN B. GELLANGARIN, PME
General Manager A