



Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT
E. Fernandez Street, Barangay Lagao General Santos
Telephone No.: 552-3824; Telefax No.: 553-4960
Email Address: gscwdprocurement@yahoo.com

GPM-014-3

REQUEST FOR QUOTATION

RFQ #: 3-0323-082 DATE: 03/28/2023

SUPPLIER: _____
ADDRESS: _____
TELEPHONE NO. : _____
TIN NO. : _____

Dear Sir/Madam,

Pls. quote your lowest price on the item/s listed below subject to general condition stating the shortest time of delivery and submit your quotation duly signed by your representative not later than 04/03/2023, Pls. furnish this office the following articles subject to the terms and conditions contained therein.

ITEM NO.	DESCRIPTION	QTY.	UNIT	UNIT PRICE
1	MECHANICAL FLOWMETER W/ PULSER 4" 100MM : ABC: PHP 56,000.00 ##### nothing follows #####	1	pcs.	P

Delivery term: _____
Price Validity : _____
Terms of Payment: _____

Place of Delivery: GSCWD Bodega
*****No partial delivery allowed****
Note: 6% WITHHOLDING TAX DEDUCTION
PR NO.: 0223-057

Requested by:

GESEM R. CABANERO
MATERIAL PROCUREMENT
OFFICER A

Price quoted by:

Supplier

Date



TECHNICAL SPECIFICATION

TITLE: PURCHASE OF MECHANICAL WATER METER

1.0 SCOPE OF CONTRACT

The scope shall be supply and delivery of brand new Mechanical Water Meter to General Santos City Water District (GSCWD).

Particulars	Requirements	Statement of Compliance
SIZE mm (inches)	100 (4)	
Number Of Unit	1	
Type	Mechanical Water Meter	
Qmax (m ³ /hr)	280-300	
Qcontinuous (m ³ /hr)	220-230	
QTransitional (m ³ /hr)	1 to 1.8	
Qmin (m ³ /hr)	0.5 to 0.8	
Operating Temperature	50°C	
Connection	Flanged Type, PN 16	
Body	PN 16, Cast Iron	
Rating	IP 68	

TERMS AND CONDITIONS

Item No.	Requirements	Statement of Compliance
1	The scope of work shall be supply and delivery of brand new Mechanical Water Meter to General Santos City Water District (GSCWD).	



Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT (GSCWD)

GSCWD Bldg., E. Fernandez Street (Emergency Road), Lagao, General Santos City
Telephone No.: 552-3824/554-7231; Telefax No.: 553-4960
E-mail Address: gscwaterdistrict@yahoo.com

2	All bidder is required to submit and include documents but not limited to manuals, data sheets and name plate specifications	
3	Field testing shall be made once the unit is ready for operation and when both the GSCWD and winning bidder have finished their scopes of work on the installed unit. GSCWD engineers shall conduct field testing with the presence of winning bidder's representative. In case the unit/units failed to pass the field testing, the winning bidder shall make necessary corrections / changes or replace the unit without cost to GSCWD.	
4	The winning bidder shall deliver brand new Mechanical Water Meter , within Sixty (30) calendar days upon receipt of Purchase Order (PO).	
5	The winning bidder shall be subjected to Liquidated Damages (LD) for each day of delay as provided by the IRR of RA 9184.	
6	That the winning bidder shall issue a warranty certificate of not less than one (1) year and the warranty shall commence from the date of commissioning of the unit. That the bidder must have an available qualified and trained technicians 24/7 in case of equipment failure.	

Prepared by:


EDMUND L. BADAL, REE

TWG - Member


MICHAEL G. GABALES, REE

TWG - HEAD