



Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT
E. Fernandez Street, Barangay Lagao General Santos
Telephone No.: 552-3824; Telefax No.: 553-4960
Email Address: gscwdprocurement@yahoo.com

GPM-014-3

REQUEST FOR QUOTATION

RFQ #: 3-0423-035 DATE: 04/26/2023

SUPPLIER: _____
ADDRESS: _____
TELEPHONE NO. : _____
TIN NO. : _____

Dear Sir/Madam,

Pls. quote your lowest price on the item/s listed below subject to general condition stating the shortest time of delivery and submit your quotation duly signed by your representative not later than 05/02/2023, Pls. furnish this office the following articles subject to the terms and conditions contained therein.

ITEM NO.	DESCRIPTION	QTY.	UNIT	UNIT PRICE
1	SUBMERSIBLE CABLE ROUND : 80MM ² , PLEASE SEE ATTACHED SPECIFICATIONS-ABC: PHP 280,000.00	80	mtrs	P
2	SUBMERSIBLE CABLE ROUND : 60MM ² , PLEASE SEE ATTACHED SPECIFICATIONS-ABC: PHP 220,000.00 ##### nothing follows #####	80	mtrs	P

Delivery term: _____
Price Validity : _____
Terms of Payment: _____


Place of Delivery: GSCWD Bodega

****No partial delivery allowed****

Note: 6% WITHHOLDING TAX DEDUCTION

PR NO.: 0423-004

Requested by:


GESEM R. CABANERO
MATERIAL PROCUREMENT
OFFICER A

Price quoted by:

Supplier

Date



TECHNICAL SPECIFICATION

TITLE: PURCHASE OF ASSORTED SUBMERSIBLE CABLE

1.0 SCOPE OF CONTRACT

The scope shall be supply and delivery of two (2) sets brand new Submersible Cable to General Santos City Water District (GSCWD).

2.0 Submersible cable requirements

Particulars	Requirement No.1	Requirement No.2	Statement of Compliance
Type	Round	Round	
Size (mm²)	60	80	
Length (meters)	80	80	
No. of Leads	3	3	
Maximum Operating Temperature (°C)	75	75	
All Submersible Cables shall be PVC- insulated with PVC & PE jacket			

3.0 TERMS AND CONDITIONS

1. The scope of work shall be supply and delivery of two (2) sets brand new Submersible Cable to General Santos City Water District (GSCWD).
2. The winning bidder is required to submit actual documents (manuals, data sheets, manufacturer's test results, name plate Specifications and etc.)
3. The winning bidder shall deliver the submersible cable within Sixty (60) calendar days upon receipt of Purchase Order (PO).
4. The winning bidder shall be subjected to Liquidated Damages (LD) for each day of delay as provided by the IRR of RA 9184.



Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT (GSCWD)
GSCWD Bldg., E. Fernández Street, Lagao, General Santos City
Telephone No.: 552-3824/554-7231; Telefax No.: 553-4960
E-mail Address: gscwaterdistrict@yahoo.com

5. The submersible cable must comply with PEC standard as to their current rating.
6. That the winning bidder shall issue a warranty certificate of not less than one (1) year.

Prepared by:


EDMUND L. BADAL, REE
TWG - Member


MICHAEL C. GABALES, REE
TWG - HEAD

Approval:


ROGELIO A. BESANA JR., C.E., RMP
Acting General Manager