



Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT
E. Fernandez Street, Barangay Lagao General Santos
Telephone No.: 552-3824; Telefax No.: 553-4960
Email Address: gscwdprocurement@yahoo.com

GPM-014-4

REQUEST FOR QUOTATION

RFQ #: 3-0424-003 DATE: 4/1/2024

SUPPLIER: _____
ADDRESS: _____
TELEPHONE NO. : _____
TIN NO. : _____

Dear Sir/Madam,

Pls. quote your lowest price on the item/s listed below subject to general condition stating the shortest time of delivery and submit your quotation duly signed by your representative not later than 4/5/2024, Pls. furnish this office the following articles subject to the terms and conditions contained therein.

Instructions :

1. Accomplish this Request for Quotation duly, correctly, and completely.
2. Do not alter the contents of this form in any way.
3. If Technical Specifications/ Terms of Reference is provided, prospect bidder (supplier / service provider) must indicate and signify compliance to every parameter in the specification.

ITEM NO.	DESCRIPTION	QTY.	UNIT	UNIT PRICE
1	VOLTAGE MONITOR 460V, 3PHASE : PLEASE SEE ATTACHED SPECIFICATIONS/ PICTURE--ABC: PHP 60,000.00 ##### nothing follows #####	9	<ignor	P

Date of Delivery: _____
Price Validity : _____
Mode of Payment: _____

Place of Delivery: GSCWD Bodega
****No partial delivery allowed****
Note: 6% WITHHOLDING TAX DEDUCTION
PR NO.: 0324-056

Requested by:

GESEM R. CABAÑERO
Supervising Material
Planning Officer

Price quoted by:


Supplier

Date



Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT
 E. Fernandez St., Brgy. Lagao, General Santos City
 Telephone No. (083) 552-3824/ Telefax No. (083) 553-4960
 E-mail Address: gscwaterdistrict@yahoo.com
 www.gensanwater.gov.ph

Voltage Monitor 460V, 3Phase



REQUIREMENTS	
Operating voltage	440 volts
Allowable operating voltage	±5%~±20% of rated operating voltage
Rated frequency	50 / 60 Hz
Detecting method	Detect from supply voltage
Contact Rating	250 VAC 5A (resistive load)
Life expectancy	Mechanical: 5,000,000 times
	Electrical: 100,000 times

Prepared by:


Pithumpry C. Nobles, REE, RME
 Engineering Assistant

Approved by:


Edmund L. Badal, REE
 Acting Division Manager – WQPMD

Safe Water... Our Thrust, Our Service, Our Commitment.