



Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT
E. Fernandez Street, Barangay Lagao General Santos
Telephone No.: 552-3824; Telefax No.: 553-4960
Email Address: gscwdprocurement@yahoo.com

GPM-014-4

REQUEST FOR QUOTATION

RFQ #: 3-0424-018 DATE: 4/2/2024

SUPPLIER: _____
ADDRESS: _____
TELEPHONE NO. : _____
TIN NO. : _____

Dear Sir/Madam,

Pls. quote your lowest price on the item/s listed below subject to general condition stating the shortest time of delivery and submit your quotation duly signed by your representative not later than 4/6/2024, Pls. furnish this office the following articles subject to the terms and conditions contained therein.

Instructions :

1. Accomplish this Request for Quotation duly, correctly, and completely.
2. Do not alter the contents of this form in any way.
3. If Technical Specifications/ Terms of Reference is provided, prospect bidder (supplier / service provider) must indicate and signify compliance to every perimeter in the specification.

ITEM NO.	DESCRIPTION	QTY.	UNIT	UNIT PRICE
1	15 MM DIA VOLUMETRIC BRASS WATER METER : PLEASE SEE ATTACHED SPECIFICATIONS (ABC: PHP975,000.00) ##### nothing follows #####	390	pc	P

Date of Delivery: _____
Price Validity : _____
Mode of Payment: _____

Place of Delivery: GSCWD Bodega
****No partial delivery allowed****
Note: 6% WITHHOLDING TAX DEDUCTION
PR NO.: 0324-062

Requested by:

[Signature]
ARNOLD B. BODEGA
Procurement Officer

Price quoted by:

Supplier

Date



PURCHASE OF THREE HUNDRED NINETY (390) PIECES 15 MM DN Ø VOLUMETRIC BRASS WATER METER

Project Title: Purchase of Three Hundred Ninety (390) pieces 15 mm DN Ø volumetric brass water meter.
 ABC: Php975, 000.00
 Owner: General Santos City Water District
 Scope of Work: The scope of work shall be the supply, delivery and testing of water meters to General Santos City Water District.

I. GENERAL REQUIREMENTS		STATEMENT OF COMPLIANCE
A. NOMINAL DIAMETER	15 MM	
B. METER TYPE	Volumetric, Dry Dial	
C. METROLOGICAL CLASS	ISO 4064-1:2014, Class II	
D. METER DESIGN	Hermetically sealed register (encapsulated to prevent moisture from entering)	
	Clear tempered high impact lens and abrasion resistant.	
	Anti-magnetic type	
	Meter capacity should be indicated in the top surface	
	Meter Register in Cubic Meters, minimum of four (4) digit registration.	
E. DIMENSION	Length without tailpieces = 115mm with ±5mm tolerance	
	Connectors = G 3/4 A, 2 pcs	
	Width of 85mm to 105mm	
	Height of 134mm with ±5mm tolerance	
	Weight = 0.60 - 0.90 kg	
F. WORKING CONDITION	Working Pressure: 10-16 Bars	
	The maximum working temperature shall be 50°C. Copy of ISO 4064-1:2014 certificate submitted by the supplier shall indicate that meters offered are T50 rated.	
G. METROLOGICAL CHARACTERISTICS (MINIMUM PERFORMANCE)	Minimum Flowrate (Q ₁) = 6.25 l/h; Allowable error in accuracy is ±5 %	
	Transitional Flowrate (Q ₂) = 10 l/h; Allowable error in accuracy is ±2 %	
	Nominal Flowrate (Q ₃) = 2.5 m ³ /h; Allowable error in accuracy is ±2 %	

	Maximum Flowrate (Q_4) = 3.125 m ³ /h; Allowable error in accuracy is $\pm 2\%$	
	$Q_3/Q_1 = 400$	
H. STRAINER SCREEN	Meter fitted with strainer on inlet to protect against dirt	

II. ADDITIONAL REQUIREMENTS:		STATEMENT OF COMPLIANCE
A. TECHNICAL BROCHURE	Bidders are required to submit technical brochure/specifications for further evaluation of the offered product.	
B. EFFICIENCY TEST	One percent (1%) of the total quantity shall undergo random water meter test in Meter Testing Laboratory. The winning bidder shall pay the corresponding cost of testing.	
	If twenty percent (20%) of the total number of water meters tested Failed the efficiency test, the procuring Entity (GSCWD) shall have the option to rescind or cancel the contract.	
	Random water meter testing shall be witnessed by three (3) GSCWD representatives. All costs such as transportation, hotel accommodation, meals, allowances and other related expenses shall be borne by the winning supplier. Testing shall be completed in one (1) day excluding travel period.	
	There shall be a representative from the winning bidder during random testing.	
	The water meters shall be randomly tested for accuracy in a Water Meter Laboratory for Transitional and Minimum flow rates. These flow rates shall be the basis for the meter to PASS or FAIL in the Accuracy Test.	
	After Delivery: All water meters delivered shall be subjected to accuracy test at GSCWD water meter laboratory. All cost related to the return of failed water meters and its replacement shall be borne by the supplier.	
C. TERMS OF DELIVERY	390 pcs 15mm Volumetric Brass Water Meter Complete Sets – 30 Calendar Days upon receipt of Purchase Order. (One time delivery)	
D. OTHER PACKAGE	With plastic end cap installed to both meter body thread ends.	
	Each meter individually packed in a small box containing 2 threaded tailpieces/connectors and 2 rubber gasket that fitted to its outlet design of the manufacturer.	
	The winning bidder shall provide additional 195 pcs rubber gaskets and an additional 195 pcs connectors/tailpieces.	

	Also, 600 pieces of non-return valve that fitted on the outlet design of water meter is required to maintain the meter registry irreversible and for maintenance purposes if necessary.	
	It shall be packed by 10's per batch with the meter serial numbers indicated in the external portion of carton/box.	
	The connectors shall be of the same material composition as the meter body.	
E. BIDDERS QUALIFICATION	Bidder shall be an authorized dealer / reseller of the offered product for after sales and support.	

Prepared by:

TECHNICAL WORKING GROUP FOR WATER METER

Agina
MARY ANN SANDY D. PINOS, ME
 TWG - Member

[Signature]
MICHAEL S. RABALES, REE
 TWG Head

Recommending Approval:

[Signature]
FERDINAND S. FERRER, MPA
 AGM - Administration

Approved by:

[Signature]
FRANCISCO R. ALOLOD JR., CPA, CESE
 Acting General Manager