



Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT
E. Fernandez Street, Barangay Lagao General Santos
Telephone No.: 552-3824; Telefax No.: 553-4960
Email Address: gscwdprocurement@yahoo.com

GPM-014-2

REQUEST FOR QUOTATION

RFQ #: 3-0622-014 DATE: 06/08/2022

SUPPLIER: _____
ADDRESS: _____
TELEPHONE NO. : _____
TIN NO. : _____

Dear Sir/Madam,

Pls. quote your lowest price on the item/s listed below subject to general condition stating the shortest time of delivery and submit your quotation duly signed by your representative not later than 06/14/2022, Pls. furnish this office the following articles subject to the terms and conditions contained therein.

ITEM NO.	DESCRIPTION	QTY.	UNIT	UNIT PRICE
1	BOOSTER PUMP ASSY. : PLEASE SEE ATTACH SPECIFICATION-ABC: PHP 680,000.00 ##### nothing follows #####	1	unit	P

Date of Delivery: _____
Price Validity : _____
Terms of Payment: _____

Place of Delivery: GSCWD Bodega

*****No partial delivery allowed*****

Note: 6% WITHHOLDING TAX DEDUCTION

PR NO.: 0522-040

Requested by: _____

Price quoted by: _____

GESSEM R. CABAÑERO
MATERIAL PROCUREMENT
OFFICER A

Supplier

Date



Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT (GSCWD)
GSCWD Bldg., E. Fernandez Street, Lagao, General Santos City
Telephone No.: 552-3824/554-7231; Telefax No.: 553-4960
E-mail Address: gscwaterdistrict@yahoo.com

TECHNICAL SPECIFICATION

TITLE: PURCHASE OF VERTICAL MULTISTAGE IN-LINE BOOSTER PUMP

1.0 SCOPE OF CONTRACT

The scope shall be supply and delivery of Vertical Multistage In-Line Booster Pump to General Santos City Water District (GSCWD).

2.0 Technical Specification and Operating Requirements

Particulars	Requirements	Statement of Compliance
Number Of Pump And Motor	1	
Type	CR64-2-1A-F-A-E	
Rated Total Capacity	77m ³ /hr	
Rated Total Head	54m	
Head Max	74m	
RPM	3450	
Maximum Operating Temperature	120°C	
Rated Motor Power Hp (kW)	25 (18.5)	
Motor Eff. %	92.4	



Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT (GSCWD)
 GSCWD Bldg., E. Fernandez Street, Lagao, General Santos City
 Telephone No.: 552-3824/554-7231; Telefax No.: 553-4960
 E-mail Address: gscwaterdistrict@yahoo.com

Rated Voltage	380-480v	
Rated Current	28A	
Max Current	31A	
Ingress Protection	IP 55	

3.0 TERMS AND CONDITIONS

No.	TERMS AND CONDITIONS	Statement of compliance
1	The scope of work shall be supply and delivery of Booster Pump Assembly to General Santos City Water District (GSCWD).	
2	The supplier is required to submit and include documents but not limited to manuals, data sheets, <i>Test Certificate</i> and <i>Manufacturers Certificate</i> .	
3	<i>The booster pump must exactly the same with existing Triplex booster pump with product name Grundfos HYDRO MPC-E 3 CR64-2-1.</i>	
4	The Booster Pump assembly shall be tested in an accredited laboratory before delivery to ensure conformance with the design parameters. The cost of the laboratory testing shall be borne entirely by the supplier.	
5	Laboratory testing shall be witnessed by three (3) GSCWD representatives together with the supplier's representatives for three (3) days. All relevant and incidental cost (Testing fee, transportation,	



Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT (GSCWD)
GSCWD Bldg., E. Fernandez Street, Lagao, General Santos City
Telephone No.: 552-3824/554-7231; Telefax No.: 553-4960
E-mail Address: gscwaterdistrict@yahoo.com

	accommodation, allowances and etc.) in the testing of the equipment shall be shouldered by the supplier.	
6	In case the unit failed to pass the testing requirements during laboratory testing, the supplier shall make necessary adjustment to correct and comply with the specifications.	
7	Field testing shall be made once the unit is ready for operation and when both the GSCWD and winning bidder have finished their scopes of work on the installed unit. GSCWD engineers shall conduct field testing with the presence of supplier's representative.	
8	The winning bidder shall deliver the unit within sixty (60) calendar days upon receipt of Purchase Order (PO).	
9	The winning bidder shall be subjected to Liquidated Damages (LD) for each day of delay as provided by the IRR of RA 9184.	
10	That the winning bidder shall issue a warranty certificate of not less than one (1) year and the warranty shall commence from the date of commissioning of the pumping equipment. That the bidder must have an available qualified and trained technicians 24/7 in case of equipment failure during its warranty period.	

Prepared by:


EDMUND L. BADAL, REE
TWG - Member


MICHAEL G. GABALES, REE
TWG - HEAD