



Republic of the Philippines
GENERAL SANTOS CITY WATER DISTRICT
E. Fernandez Street, Barangay Lagao General Santos
Telephone No.: 552-3824; Telefax No.: 553-4960
Email Address: gscwdprocurement@yahoo.com

GPM-014-2

REQUEST FOR QUOTATION

RFQ #: 3-0622-027 DATE: 6/16/2022

SUPPLIER: _____
ADDRESS: _____
TELEPHONE NO. : _____
TIN NO. : _____

Dear Sir/Madam,

Pls. quote your lowest price on the item/s listed below subject to general condition stating the shortest time of delivery and submit your quotation duly signed by your representative not later than 6/22/2022, Pls. furnish this office the following articles subject to the terms and conditions contained therein.

ITEM NO.	DESCRIPTION	QTY.	UNIT	UNIT PRICE
1	SOFT START/SOFT STOP (ELECTROMECHANICAL EQUIPMENT) : 125HP, 460V, 3PHASE, 60HZ, PLEASE SEE ATTACHED SPECIFICATIONS (ABC: PHP 230,000.00	2	unit	P
2	SOFT START/SOFT STOP (ELECTROMECHANICAL EQUIPMENT) : 100HP, 460V, 3PHASE, 60HZ, PLEASE SEE ATTACHED SPECIFICATIONS (ABC: PHP 110,000.00	1	unit	P
3	SOFT START/SOFT STOP (ELECTROMECHANICAL EQUIPMENT) : 75HP, 460V, 3PHASE, 60HZ, PLEASE SEE ATTACHED SPECIFICATIONS (ABC: PHP 150,000.00 ##### nothing follows #####	2	unit	P

Date of Delivery: _____
Price Validity : _____
Terms of Payment: _____


Place of Delivery: **GSCWD** Bodega

*****No partial delivery allowed****

Note: 6% WITHHOLDING TAX DEDUCTION

PR NO.: 0522-005

Requested by:


GESEM R. CABAÑERO
MATERIAL PROCUREMENT
OFFICER A

Price quoted by:

Supplier

Date



TECHNICAL SPECIFICATION

TITLE: PURCHASE OF SOFT STARTER MOTOR CONTROLLERS

1.0 SCOPE OF CONTRACT

The scope of work shall be supply and delivery of Soft start/soft stop motor controllers to General Santos City Water District (GSCWD).

2.0 SOFT START/SOFT STOP MOTOR CONTROLLERS

PARTICULARS	REQUIREMENT	No. of Units
Rated Power, Hp (kW)	125	2
Rated Power, Hp (kW)	100	1
Rated Power, Hp (kW)	75	2

2.1 SOFT START/SOFT STOP MOTOR CONTROLLER SPECIFICATIONS

PARTICULARS	REQUIREMENT	Statement of Compliance
AC Voltage Range	380v – 600v	
Voltage % Tolerance	+10%, -15%	
Supply number of phases	3 phases	
Short Circuit Current Rating (kAIC rating)	50kA	
Limiting Current	Adjustment range: 150% to 700% of the nominal motor current	
Protection Class	Severe Duty Application	
IP degree of protection	IP54	
Assembly style	With heat sink	



Supply frequency	50 to 60 Hz (- 5 to 5 %)	
Network frequency	47.5 to 63 Hz	
Type of Cooling	Forced Convection	
Protection	Phase rotation, over/ under voltage, lock rotor, ground fault, Thermal over current	

3.0 TERMS AND CONDITIONS

No.	TERMS AND CONDITIONS	Statement of Compliance
1	The scope of work shall be supply and delivery soft starter motor controllers to General Santos City Water District (GSCWD).	
2	The winning bidder is required to submit actual documents but not limited to manuals, wiring diagrams and data sheets. Also the winning bidder shall conduct technical orientation on Soft starter controller application and programming to the GSCWD technical personnel.	
3	The winning bidder shall deliver the soft starter motor controllers within Sixty (60) calendar days upon receipt of Purchase Order (PO).	
4	The winning bidder shall be subjected to Liquidated Damages (LD) for each day of delay as provided by the IRR of RA 9184.	
5	That the winning bidder shall issue a warranty certificate of not less than one (1) year.	
6	That the bidder must have an available qualified and trained technicians 24/7 in case of equipment failure.	

Prepared by:


EDMUND L. BADAL, REE
TWG - Member


MICHAEL G. GABALES, REE
TWG - HEAD