



Republic of the Philippines  
 GENERAL SANTOS CITY WATER DISTRICT  
 E. Fernandez Street, Barangay Lagao General Santos  
 Telephone No.: 552-3824; Telefax No.: 553-4960  
 Email Address: gscwdprocurement@yahoo.com

GPM-014-2

**REQUEST FOR QUOTATION**

RFQ #: 3-0722-015      DATE: 07/06/2022

SUPPLIER: \_\_\_\_\_  
 ADDRESS: \_\_\_\_\_  
 TELEPHONE NO. : \_\_\_\_\_  
 TIN NO. : \_\_\_\_\_

Dear Sir/Madam,

Pls. quote your lowest price on the item/s listed below subject to general condition stating the shortest time of delivery and submit your quotation duly signed by your representative not later than 07/12/2022, Pls. furnish this office the following articles subject to the terms and conditions contained therein.

ITEM NO.	DESCRIPTION	QTY.	UNIT	UNIT PRICE
1	CONSTRUCTION/LABOR AND MATERIALS : ABC: PHP 268,869.44 ##### nothing follows #####	1	LOT	P

Date of Delivery: \_\_\_\_\_  
 Price Validity : \_\_\_\_\_  
 Terms of Payment: \_\_\_\_\_

Place of Delivery: GSCWD Bodega  
 \*\*\*\*\*No partial delivery allowed\*\*\*\*\*  
 Note: 6% WITHHOLDING TAX DEDUCTION  
 PR NO.: 0722-003

Requested by:

**GESEM R. CABAÑERO**  
 MATERIAL PROCUREMENT  
 OFFICER A

Price quoted by:

\_\_\_\_\_  
 Supplier

\_\_\_\_\_  
 Date



Republic of the Philippines  
**GENERAL SANTOS CITY WATER DISTRICT**  
E. Fernandez St. Lagao, General Santos City  
Telephone No. (083) 552-3824/ Telefax No. (083) 553-4960  
E-mail Address: gscwaterdistrict@yahoo.com



*Prod*

## PROJECT DESCRIPTION

Project Name : REPAINTING OF 1500 CU.M. CYLINDRICAL  
GROUND STEEL TANK

Location : BRGY. SINAWAL, GENERAL SANTOS CITY

Undertaken by : CONTRACT

Estimated Amount : 268,869.44

Charge to : 2023 EOD CAPEX NO. \_\_\_\_\_

Date Started : UPON APPROVAL

Project Duration : 40 CALENDAR DAYS

Procurement, Quality Control and Compliance Division

Received by: CHEEZA AMOR R. DIAZ

Date Received: 7/10/22 Time: 5:30 PM



Republic of the Philippines  
**GENERAL SANTOS CITY WATER DISTRICT**  
 E. Fernandez st., Brgy. Lagao  
 General Santos City



Project: **REPAINTING OF 1500 CU.M. CYLINDRICAL GROUND STEEL T**  
 Location: **BRGY. SINAWAL, GENERAL SANTOS CITY**  
 Owner: **GENERAL SANTOS CITY WATER DISTRICT**

CONSTRUCTION GANTT CHART																																									
DESCRIPTION	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	
<b>A. PAINTING WORKS</b>																																									
1. Repainting of Shell & Roof Tank																																									
2. Repainting of Steel Pipes																																									
3. Repainting of Steel Ladder																																									
4. Repainting of Steel Railings																																									
5. Repainting of Air Vents																																									
6. Repainting of Manhole Covers																																									

Prepared by:


  
**EV SIEGFRED D. ALIM**  
 Principal Draftsman

Checked & Reviewed by:

  
**ENGR. MARIA CELIA N. DANDAN**  
 OIC - Planning & Design Division

Approved by:

  
**ENGR. ROGELIO A. BESANA, JR.**  
 AGM - Operations & Technical Services



LOT 49-A-1, PSD-116303-032341

LOT 49-A-2-B, PSD-11-056892  
AREA = 2,000 SQM

LOT 49-A-3, PSD-116303-032341

**THIS SITE**

ROAD

**SITE DEVELOPMENT PLAN**  
SCALE: \_\_\_\_\_ NTS



**1500 CU.M. CYLINDRICAL  
GROUND STEEL TANK**

**RESERVOIR PLAN**  
SCALE: \_\_\_\_\_ 1:125 M




**GENERAL SANTOS CITY WATER DISTRICT**  
E. FERNANDEZ STREET, BRGY. LAGAO, GEN. SANTOS CITY  
ENGINEERING & CONSTRUCTION DEPARTMENT  
PLANNING AND DESIGN DIVISION  
TEL NO. (082) 552 - 2824

PROJECT TITLE / LOCATION:  
**REPAINTING OF 1500 CU.M. CYLINDRICAL GROUND  
STEEL TANK**

CHECKED & REVIEWED BY:  
  
ENGR. MARIA CELIA N. DANDAN


APPROVED BY:  
  
ENGR. ROGELIO A. BESANA, JR.

CONTENT:  
**AS SHOWN**  
DRAWN: JEUNG      REVISION:



NOTE: REPAINTING OF LOGO AND SIGNAGES ARE INCLUDED

**TANK ELEVATION**  
SCALE 1:100MM



FONT SHALL HAVE WHITE OUTLINE

**1500 CUBIC METER**  
**CYLINDRICAL GROUND STEEL TANK**  
SM VILLAGE, BRGY. SINAWAL, GENERAL SANTOS CITY

WHITE COLOR

2000

150

250



## SCOPE OF WORK

Project Title: **Repainting of 1,500 cu.m Cylindrical Steel Ground Reservoir**  
Location: SM Village, Brgy. Sinawal, General Santos City

1. The contractor shall provide manpower, materials, tools, and other necessary equipment (scaffolds) for the said project such as the following:
  - 1.1 Cleaning/scraping of uneven surfaces and dirt.
  - 1.2 Painting of all portion of the said reservoir including stairs, railings, discharge lines, chamber, gratings, etc.
  - 1.3 Painting works are the following:
    - a. Steel Reservoir Surfaces
      - 1<sup>st</sup> and 2<sup>nd</sup> coat: Epoxy Enamel Paint; Ultra-Marine Blue, Gloss
    - b. Steel
      1. Railings:
        - 1<sup>st</sup> and 2<sup>nd</sup> coat: Epoxy Enamel Paint; Gold, Gloss
      2. Steel Pipes and Air Vent:
        - 1<sup>st</sup> and 2<sup>nd</sup> coat: Epoxy Enamel Paint; Ultra-Marine Blue, Gloss
      3. Steel Ladder:
        - 1<sup>st</sup> and 2<sup>nd</sup> coat: Epoxy Enamel Paint; Black, Gloss
      4. Steel Grating:
        - 1<sup>st</sup> and 2<sup>nd</sup> coat: Epoxy Enamel Paint; Ultra-Marine Blue, Gloss
      5. Concrete wall surface of the tank:
        - 1<sup>st</sup> and 2<sup>nd</sup> coat: Latex Paint; Ultra-Marine Blue, Gloss
  - 1.4 Lettering of name and logo of reservoir (*see attached plan*)
  - 1.5 Painting works shall be done during sunny weather only.
  - 1.6 Repair of crack portion of the concrete wall surface of the tank foundation and repainting thereafter.
2. The contractor shall commence five (5) days after the receipt of Notice to Proceed and inform the assigned representative of GSCWD.
3. All costs shall be shouldered by the winning bidder (contractor).
4. All works shall be observed by authorized representative of General Santos City Water District.
5. Warranty under normal condition shall be granted by service provider.
6. Accomplishment report and recommendations shall be submitted after work completion.

Prepared by:

Checked by:

  
**Lorevin V. Evangelio, RMEE**  
Engineering Asst. B

  
**Edmund L. Badal, REE**  
Principal Engineer C, WQPEMD

Approved by:

